



Bruce-Monroe Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003068	4/17/2024	4/17/2025	Ground Floor	Break Room	In Break Room 057	WF-04172024-003068	10/21/2024	FT-FY25-10032024-003068-A	<2	FT-FY25-10032024-003068-B	<2
WS-003662	4/17/2024	4/17/2025	Ground Floor	Cooler	In classroom 007	WF-04172024-003662	10/21/2024	FT-FY25-10032024-003662-A	<2	FT-FY25-10032024-003662-B	<2
WS-003663	4/17/2024	4/17/2025	Ground Floor	Cooler	In classroom 006	WF-04172024-003663	10/21/2024	FT-FY25-10032024-003663-A	<2	FT-FY25-10032024-003663-B	<2
WS-003664	4/17/2024	4/17/2025	Ground Floor	Cooler	In classroom 008	WF-04172024-003664	10/21/2024	FT-FY25-10032024-003664-A	<2	FT-FY25-10032024-003664-B	<2
WS-003665	4/17/2024	4/17/2025	Ground Floor	Cooler	In hallway 037	WF-04172024-003665	10/21/2024	FT-FY25-10032024-003665-A	<2	FT-FY25-10032024-003665-B	<2
WS-003666	4/17/2024	4/17/2025	Ground Floor	Cooler	In classroom 021	WF-04172024-003666	10/21/2024	FT-FY25-10032024-003666-A	<2	FT-FY25-10032024-003666-B	<2
WS-003667	4/17/2024	4/17/2025	Ground Floor	Cooler	In classroom 022	WF-04172024-003667	10/21/2024	FT-FY25-10032024-003667-A	<2	FT-FY25-10032024-003667-B	<2
WS-003668	9/26/2024	9/26/2025	Ground Floor	Cooler	In classroom 024	WF-09262024-003668	10/21/2024	FT-FY25-10032024-003668-A	<2	FT-FY25-10032024-003668-B	<2
WS-003670	4/17/2024	4/17/2025	1	Cooler	In hallway 156 adjacent to restroom	WF-04172024-003670	10/21/2024	FT-FY25-10032024-003670-A	<2	FT-FY25-10032024-003670-B	<2
WS-003671	4/17/2024	4/17/2025	1	Cooler	In classroom 126	WF-04172024-003671	10/21/2024	FT-FY25-10032024-003671-A	<2	FT-FY25-10032024-003671-B	<2
WS-003672	4/17/2024	4/17/2025	1	Cooler	In classroom 127	WF-04172024-003672	10/21/2024	FT-FY25-10032024-003672-A	<2	FT-FY25-10032024-003672-B	<2
WS-003673	4/17/2024	4/17/2025	1	Cooler	In classroom 123	WF-04172024-003673	10/21/2024	FT-FY25-10032024-003673-A	<2	FT-FY25-10032024-003673-B	<2
WS-003674	4/17/2024	4/17/2025	1	Cooler	In classroom 122	WF-04172024-003674	10/21/2024	FT-FY25-10032024-003674-A	<2	FT-FY25-10032024-003674-B	<2
WS-003675	4/17/2024	4/17/2025	1	Cooler	In hallway 144	WF-04172024-003675	10/21/2024	FT-FY25-10032024-003675-A	<2	FT-FY25-10032024-003675-B	<2
WS-003676	4/17/2024	4/17/2025	1	Health Suite	In health suite	WF-04172024-003676	10/21/2024	FT-FY25-10032024-003676-A	<2	FT-FY25-10032024-003676-B	<2
WS-003677	4/17/2024	4/17/2025	1	Break Room	In staff lounge	WF-04172024-003677	10/21/2024	FT-FY25-10032024-003677-A	<2	FT-FY25-10032024-003677-B	<2
WS-003679	4/17/2024	4/17/2025	1	Cooler	In hallway 151 adjacent to restroom	WF-04172024-003679	10/21/2024	FT-FY25-10032024-003679-A	<2	FT-FY25-10032024-003679-B	<2
WS-003681	4/17/2024	4/17/2025	2	Cooler	In hallway 229 adjacent to library	WF-04172024-003681	10/21/2024	FT-FY25-10032024-003681-A	<2	FT-FY25-10032024-003681-B	<2
WS-003682	4/17/2024	4/17/2025	2	Cooler	In hallway 240 adjacent to restroom	WF-04172024-003682	10/21/2024	FT-FY25-10032024-003682-A	<2	FT-FY25-10032024-003682-B	<2
WS-004281	4/17/2024	4/17/2025	Basement	Bottle Filler	In cafeteria	WF-04172024-004281	10/21/2024	FT-FY25-10032024-004281-A	<2	FT-FY25-10032024-004281-B	<2
WS-004282	4/17/2024	4/17/2025	Basement	Cooler	In cafeteria Low Left	WF-04172024-004282	10/21/2024	FT-FY25-10032024-004282-A	<2	FT-FY25-10032024-004282-B	<2
WS-004283	4/17/2024	4/17/2025	Basement	Cooler	In cafeteria High Right	WF-04172024-004283	10/21/2024	FT-FY25-10032024-004283-A	<2	FT-FY25-10032024-004283-B	<2
WS-004560	9/11/2024	9/11/2025	Ground Floor	Classroom Faucet	In classroom 022	WF-09112024-004560	10/21/2024	FT-FY25-10032024-004560-A	<2	FT-FY25-10032024-004560-B	<2
WS-004561	9/11/2024	9/11/2025	Ground Floor	Classroom Faucet	In classroom 021	WF-09112024-004561	10/21/2024	FT-FY25-10032024-004561-A	<2	FT-FY25-10032024-004561-B	<2
WS-004562	9/11/2024	9/11/2025	Ground Floor	Classroom Faucet	In classroom 024	WF-09112024-004562	10/21/2024	FT-FY25-10032024-004562-A	<2	FT-FY25-10032024-004562-B	<2
WS-004563	9/11/2024	9/11/2025	Ground Floor	Classroom Faucet	In classroom 008	WF-09112024-004563	10/21/2024	FT-FY25-10032024-004563-A	<2	FT-FY25-10032024-004563-B	<2
WS-004564	9/11/2024	9/11/2025	Ground Floor	Classroom Faucet	In classroom 007	WF-09112024-004564	10/21/2024	FT-FY25-10032024-004564-A	<2	FT-FY25-10032024-004564-B	<2
WS-004565	9/11/2024	9/11/2025	Ground Floor	Classroom Faucet	In classroom 006	WF-09112024-004565	10/21/2024	FT-FY25-10032024-004565-A	<2	FT-FY25-10032024-004565-B	<2
WS-004566	4/17/2024	4/17/2025	1	Bottle Filler	In hallway 156 adjacent to restroom	WF-04172024-004566	10/21/2024	FT-FY25-10032024-004566-A	<2	FT-FY25-10032024-004566-B	<2
WS-004567	4/17/2024	4/17/2025	1	Bottle Filler	In hallway 144	WF-04172024-004567	10/21/2024	FT-FY25-10032024-004567-A	<2	FT-FY25-10032024-004567-B	<2
WS-004568	4/17/2024	4/17/2025	1	Bottle Filler	In hallway 151 adjacent to restroom	WF-04172024-004568	10/21/2024	FT-FY25-10032024-004568-A	<2	FT-FY25-10032024-004568-B	<2
WS-004570	4/17/2024	4/17/2025	2	Bottle Filler	In hallway 229 adjacent to library	WF-04172024-004570	10/21/2024	FT-FY25-10032024-004570-A	<2	FT-FY25-10032024-004570-B	<2
WS-004571	4/17/2024	4/17/2025	2	Bottle Filler	In hallway 240 adjacent to restroom	WF-04172024-004571	10/21/2024	FT-FY25-10032024-004571-A	<2	FT-FY25-10032024-004571-B	<2

WS- 004572	4/17/2024	4/17/2025	2	Bottle Filler	In hallway across from 221	WF-04172024-004572	10/21/2024	FT-FY25-10032024-004572-A	<2	FT-FY25-10032024-004572-B	<2
WS- 004573	4/17/2024	4/17/2025	2	Cooler	In hallway across from 221	WF-04172024-004573	10/21/2024	FT-FY25-10032024-004573-A	<2	FT-FY25-10032024-004573-B	<2
WS- 004574	4/17/2024	4/17/2025	Ground Floor	Bottle Filler	In hallway 037	WF-04172024-004574	10/21/2024	FT-FY25-10032024-004574-A	<2	FT-FY25-10032024-004574-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003661	11/14/2023	11/14/2024	Ground Floor	Food Prep Sink	In kitchen	WF-11142023-003661	10/21/2024	FT-FY25-10032024-003661-A	<2	FT-FY25-10032024-003661-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.