



# Bruce Monroe Elementary School Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003068	4/9/2025	4/9/2026	Ground Floor	Break Room	In Break Room 015	WF-04092025-003068	10/15/2025	FT-FY26-09232025-003068-A	<2	FT-FY26-09232025-003068-B	<2
WS-003662	4/9/2025	4/9/2026	Ground Floor	Cooler	In classroom 007	WF-04092025-003662	10/15/2025	FT-FY26-09232025-003662-A	<2	FT-FY26-09232025-003662-B	<2
WS-003664	4/9/2025	4/9/2026	Ground Floor	Cooler	In classroom 008	WF-04092025-003664	10/15/2025	FT-FY26-09232025-003664-A	<2	FT-FY26-09232025-003664-B	<2
WS-003665	4/9/2025	4/9/2026	Ground Floor	Cooler	In hallway 037	WF-04092025-003665	10/15/2025	FT-FY26-09232025-003665-A	<2	FT-FY26-09232025-003665-B	<2
WS-003666	4/9/2025	4/9/2026	Ground Floor	Cooler	In classroom 021	WF-04092025-003666	10/15/2025	FT-FY26-09232025-003666-A	<2	FT-FY26-09232025-003666-B	<2
WS-003667	4/9/2025	4/9/2026	Ground Floor	Cooler	In classroom 022	WF-04092025-003667	10/15/2025	FT-FY26-09232025-003667-A	<2	FT-FY26-09232025-003667-B	<2
WS-003670	4/9/2025	4/9/2026	1	Cooler	In hallway 156 adjacent to restroom	WF-04092025-003670	10/15/2025	FT-FY26-09232025-003670-A	<2	FT-FY26-09232025-003670-B	<2
WS-003671	4/9/2025	4/9/2026	1	Cooler	In classroom 126	WF-04092025-003671	10/15/2025	FT-FY26-09232025-003671-A	<2	FT-FY26-09232025-003671-B	<2
WS-003672	4/9/2025	4/9/2026	1	Cooler	In classroom 127	WF-04092025-003672	10/15/2025	FT-FY26-09232025-003672-A	<2	FT-FY26-09232025-003672-B	<2
WS-003673	4/9/2025	4/9/2026	1	Cooler	In classroom 123	WF-04092025-003673	10/15/2025	FT-FY26-09232025-003673-A	<2	FT-FY26-09232025-003673-B	<2
WS-003674	4/9/2025	4/9/2026	1	Cooler	In classroom 122	WF-04092025-003674	10/15/2025	FT-FY26-09232025-003674-A	<2	FT-FY26-09232025-003674-B	<2
WS-003675	4/9/2025	4/9/2026	1	Cooler	In hallway 144	WF-04092025-003675	10/15/2025	FT-FY26-09232025-003675-A	<2	FT-FY26-09232025-003675-B	<2
WS-003676	4/9/2025	4/9/2026	1	Health Suite	In health suite	WF-04092025-003676	10/15/2025	FT-FY26-09232025-003676-A	<2	FT-FY26-09232025-003676-B	<2
WS-003677	4/9/2025	4/9/2026	1	Break Room	In staff lounge	WF-04092025-003677	10/15/2025	FT-FY26-09232025-003677-A	<2	FT-FY26-09232025-003677-B	<2
WS-003679	4/9/2025	4/9/2026	1	Cooler	In hallway 151 adjacent to restroom	WF-04092025-003679	10/15/2025	FT-FY26-09232025-003679-A	<2	FT-FY26-09232025-003679-B	<2
WS-003680	8/27/2025	8/27/2026	2	Cooler	In hallway 234 adjacent to restroom	WF-08272025-003680	10/15/2025	FT-FY26-09232025-003680-A	<2	FT-FY26-09232025-003680-B	<2
WS-003681	4/9/2025	4/9/2026	2	Cooler	In hallway 229 adjacent to library	WF-04092025-003681	10/15/2025	FT-FY26-09232025-003681-A	<2	FT-FY26-09232025-003681-B	<2
WS-003682	8/27/2025	8/27/2026	2	Cooler	In hallway 240 adjacent to restroom	WF-08272025-003682	10/15/2025	FT-FY26-09232025-003682-A	<2	FT-FY26-09232025-003682-B	<2
WS-004281	4/9/2025	4/9/2026	Basement	Bottle Filler	In cafeteria	WF-04092025-004281	10/15/2025	FT-FY26-09232025-004281-A	<2	FT-FY26-09232025-004281-B	<2
WS-004282	4/9/2025	4/9/2026	Basement	Cooler	In cafeteria Low Left	WF-04092025-004282	10/15/2025	FT-FY26-09232025-004282-A	<2	FT-FY26-09232025-004282-B	<2
WS-004560	9/4/2025	9/4/2026	Ground Floor	Classroom Faucet	In classroom 022	WF-09042025-004560	10/15/2025	FT-FY26-09232025-004560-A	<2	FT-FY26-09232025-004560-B	<2
WS-004561	9/4/2025	9/4/2026	Ground Floor	Classroom Faucet	In classroom 021	WF-09042025-004561	10/15/2025	FT-FY26-09232025-004561-A	<2	FT-FY26-09232025-004561-B	<2
WS-004562	9/4/2025	9/4/2026	Ground Floor	Classroom Faucet	In classroom 024	WF-09042025-004562	10/15/2025	FT-FY26-09232025-004562-A	<2	FT-FY26-09232025-004562-B	<2
WS-004563	9/4/2025	9/4/2026	Ground Floor	Classroom Faucet	In classroom 008	WF-09042025-004563	10/15/2025	FT-FY26-09232025-004563-A	<2	FT-FY26-09232025-004563-B	<2
WS-004564	9/4/2025	9/4/2026	Ground Floor	Classroom Faucet	In classroom 007	WF-09042025-004564	10/15/2025	FT-FY26-09232025-004564-A	<2	FT-FY26-09232025-004564-B	<2
WS-004565	9/4/2025	9/4/2026	Ground Floor	Classroom Faucet	In classroom 006	WF-09042025-004565	10/15/2025	FT-FY26-09232025-004565-A	<2	FT-FY26-09232025-004565-B	<2
WS-004566	4/9/2025	4/9/2026	1	Bottle Filler	In hallway 156 adjacent to restroom	WF-04092025-004566	10/15/2025	FT-FY26-09232025-004566-A	<2	FT-FY26-09232025-004566-B	<2
WS-004567	4/9/2025	4/9/2026	1	Bottle Filler	In hallway 144	WF-04092025-004567	10/15/2025	FT-FY26-09232025-004567-A	<2	FT-FY26-09232025-004567-B	<2
WS-004568	4/9/2025	4/9/2026	1	Bottle Filler	In hallway 151 adjacent to restroom	WF-04092025-004568	10/15/2025	FT-FY26-09232025-004568-A	<2	FT-FY26-09232025-004568-B	<2
WS-004569	8/27/2025	8/27/2026	2	Bottle Filler	In hallway 234 adjacent to restroom	WF-08272025-004569	10/15/2025	FT-FY26-09232025-004569-A	<2	FT-FY26-09232025-004569-B	<2
WS-004570	4/9/2025	4/9/2026	2	Bottle Filler	In hallway 229 adjacent to library	WF-04092025-004570	10/15/2025	FT-FY26-09232025-004570-A	<2	FT-FY26-09232025-004570-B	<2
WS-004571	8/27/2025	8/27/2026	2	Bottle Filler	In hallway 240 adjacent to restroom	WF-08272025-004571	10/15/2025	FT-FY26-09232025-004571-A	<2	FT-FY26-09232025-004571-B	<2
WS-004572	4/9/2025	4/9/2026	2	Bottle Filler	In hallway across from 221	WF-04092025-004572	10/15/2025	FT-FY26-09232025-004572-A	<2	FT-FY26-09232025-004572-B	<2
WS-004573	4/9/2025	4/9/2026	2	Cooler	In hallway across from 221	WF-04092025-004573	10/15/2025	FT-FY26-09232025-004573-A	<2	FT-FY26-09232025-004573-B	<2

WS- 004574	4/9/2025	4/9/2026	Ground Floor	Bottle Filler	in hallway 037	WF-04092025-004574	10/15/2025	FT-FY26-09232025-004574-A	<2	FT-FY26-09232025-004574-B	<2
------------	----------	----------	--------------	---------------	----------------	--------------------	------------	---------------------------	----	---------------------------	----

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003661	11/12/2024	11/12/2025	Ground Floor	Food Prep Sink	in kitchen	WF-11122024-003661	10/15/2025	FT-FY26-09232025-003661-A	<2	FT-FY26-09232025-003661-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.