



BRUCE MONROE PARKVIEW LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003659	Utility	Ground Floor	In stairwell 3	WT-042916-3676-A	24	WT-042916-3676-B	2.27	Non-drinking Water Source - Not accessible to children			
2	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003660	Other	Ground Floor	In kitchen (spray nozzle)	WT-042916-3677-A	< 1	WT-042916-3677-B	< 1				
3	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003661	Kitchen	Ground Floor	In kitchen	WT-042916-3678-A	< 1	WT-042916-3678-B	1.04				
4	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003662	Cooler	Ground Floor	In classroom 007	WT-042916-3679-A	< 1	WT-042916-3679-B	< 1				
5	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003663	Cooler	Ground Floor	In classroom 006	WT-042916-3680-A	< 1	WT-042916-3680-B	< 1				
6	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003664	Cooler	Ground Floor	In classroom 008	WT-042916-3681-A	< 1	WT-042916-3681-B	< 1				
7	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003665	Cooler	Ground Floor	In corridor 037	WT-042916-3682-A	< 1	WT-042916-3682-B	< 1				
8	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003666	Cooler	Ground Floor	In classroom 021	WT-042916-3683-A	< 1	WT-042916-3683-B	< 1				
9	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003667	Cooler	Ground Floor	In classroom 022	WT-042916-3684-A	< 1	WT-042916-3684-B	< 1				
10	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003668	Cooler	Ground Floor	In classroom 024	WT-042916-3685-A	< 1	WT-042916-3685-B	< 1				
11	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003669	Cooler	Ground Floor	In corridor 049 adjacent to gymnasium stairwell	WT-042916-3686-A	< 1	WT-042916-3686-B	< 1				
12	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003670	Cooler	1	In corridor 156 adjacent to restrooms	WT-042916-3687-A	< 1	WT-042916-3687-B	< 1				
13	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003671	Cooler	1	In classroom 126	WT-042916-3688-A	< 1	WT-042916-3688-B	< 1				
14	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003672	Cooler	1	In classroom 127	WT-042916-3689-A	< 1	WT-042916-3689-B	< 1				
15	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003673	Cooler	1	In classroom 123	WT-042916-3690-A	< 1	WT-042916-3690-B	< 1				
16	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003674	Cooler	1	In classroom 122	WT-042916-3691-A	< 1	WT-042916-3691-B	< 1				
17	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003675	Cooler	1	In corridor 144	WT-042916-3692-A	< 1	WT-042916-3692-B	< 1				
18	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003676	Health Suite	1	In health suite	WT-042916-3693-A	< 1	WT-042916-3693-B	< 1				
19	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003677	Break Room	1	In teachers lounge	WT-042916-3694-A	< 1	WT-042916-3694-B	< 1				
20	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003678	Other	1	In teacher's lounge (spray nozzle)	WT-042916-3695-A	< 1	WT-042916-3695-B	< 1				
21	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003679	Cooler	1	In corridor 151 adjacent to restrooms	WT-042916-3696-A	< 1	WT-042916-3696-B	< 1				
22	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003680	Cooler	2	In corridor 234 adjacent to restrooms	WT-042916-3697-A	< 1	WT-042916-3697-B	< 1				
23	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003681	Cooler	2	In corridor 229 adjacent to library	WT-042916-3698-A	< 1	WT-042916-3698-B	< 1				
24	PARKVIEW ELEMENTARY SCHOOL	5/7/2016	WS-003682	Cooler	2	In corridor 240 adjacent to restrooms	WT-042916-3699-A	< 1	WT-042916-3699-B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.