



Bruce-Monroe ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003663	6/12/2017	6/12/2018	Ground	Cooler	In classroom 006	WF-62017-003663	11/28/2017	FT-FY18-62017-003663-A	<1	FT-FY18-62017-003663-B	<1
WS- 003666	6/12/2017	6/12/2018	Ground	Cooler	In classroom 021	WF-62017-003666	11/28/2017	FT-FY18-62017-003666-A	<1	FT-FY18-62017-003666-B	<1
WS- 003672	6/12/2017	6/12/2018	1	Cooler	In classroom 127	WF-62017-003672	11/28/2017	FT-FY18-62017-003672-A	<1	FT-FY18-62017-003672-B	<1
WS- 003674	6/12/2017	6/12/2018	1	Cooler	In classroom 122	WF-62017-003674	11/28/2017	FT-FY18-62017-003674-A	<1	FT-FY18-62017-003674-B	<1
WS- 003675	6/12/2017	6/12/2018	1	Cooler	In hallway 144	WF-62017-003675	11/28/2017	FT-FY18-62017-003675-A	<1	FT-FY18-62017-003675-B	<1
WS- 003676	6/12/2017	6/12/2018	1	Health Suite	In health suite	WF-62017-003676	11/28/2017	FT-FY18-62017-003676-A	<1	FT-FY18-62017-003676-B	<1
WS- 003681	6/12/2017	6/12/2018	2	Cooler	In hallway 229 adjacent to	WF-62017-003681	11/28/2017	FT-FY18-62017-003681-A	<1	FT-FY18-62017-003681-B	<1
WS- 004560	11/14/2017	11/14/2018	Ground	Classroom	In classroom 022	WF-112017-004560	11/28/2017	FT-FY18-112017-004560-A	<1	FT-FY18-112017-004560-B	<1
WS- 004564	11/14/2017	11/14/2018	Ground	Classroom	In classroom 007	WF-112017-004564	11/28/2017	FT-FY18-112017-004564-A	<1	FT-FY18-112017-004564-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003661	Ground	Food Prep Sink	In kitchen	11/28/2017	FT-FY18-102017-003661-A	<1	FT-FY18-102017-003661-B	<1