



# Bruce Monroe ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003662	5/14/2018	5/14/2019	Ground Floor	Cooler	In classroom 007	WF-05142018-003662	11/28/2018	FT-FY19-112018-003662-A	<1	FT-FY19-112018-003662-B	<1
WS-003663	5/14/2018	5/14/2019	Ground Floor	Cooler	In classroom 006	WF-05142018-003663	11/28/2018	FT-FY19-112018-003663-A	<1	FT-FY19-112018-003663-B	<1
WS-003664	5/14/2018	5/14/2019	Ground Floor	Cooler	In classroom 008	WF-05142018-003664	11/28/2018	FT-FY19-112018-003664-A	<1	FT-FY19-112018-003664-B	<1
WS-003665	11/16/2018	11/16/2019	Ground Floor	Cooler	In hallway 037	WF-11162018-003665	11/28/2018	FT-FY19-112018-003665-A	<1	FT-FY19-112018-003665-B	<1
WS-003666	5/14/2018	5/14/2019	Ground Floor	Cooler	In classroom 021	WF-05142018-003666	11/28/2018	FT-FY19-112018-003666-A	<1	FT-FY19-112018-003666-B	<1
WS-003667	5/14/2018	5/14/2019	Ground Floor	Cooler	In classroom 022	WF-05142018-003667	11/28/2018	FT-FY19-112018-003667-A	<1	FT-FY19-112018-003667-B	<1
WS-003668	5/14/2018	5/14/2019	Ground Floor	Cooler	In classroom 024	WF-05142018-003668	11/28/2018	FT-FY19-112018-003668-A	<1	FT-FY19-112018-003668-B	<1
WS-003670	5/14/2018	5/14/2019	1	Cooler	In hallway 156 adjacent to restroom	WF-05142018-003670	11/28/2018	FT-FY19-112018-003670-A	<1	FT-FY19-112018-003670-B	<1
WS-003671	5/14/2018	5/14/2019	1	Cooler	In classroom 126	WF-05142018-003671	11/28/2018	FT-FY19-112018-003671-A	<1	FT-FY19-112018-003671-B	<1
WS-003672	5/14/2018	5/14/2019	1	Cooler	In classroom 127	WF-05142018-003672	11/28/2018	FT-FY19-112018-003672-A	<1	FT-FY19-112018-003672-B	<1
WS-003673	5/14/2018	5/14/2019	1	Cooler	In classroom 123	WF-05142018-003673	11/28/2018	FT-FY19-112018-003673-A	<1	FT-FY19-112018-003673-B	<1
WS-003674	5/14/2018	5/14/2019	1	Cooler	In classroom 122	WF-05142018-003674	11/28/2018	FT-FY19-112018-003674-A	<1	FT-FY19-112018-003674-B	<1
WS-003675	5/14/2018	5/14/2019	1	Cooler	In hallway 144	WF-05142018-003675	11/28/2018	FT-FY19-112018-003675-A	<1	FT-FY19-112018-003675-B	<1
WS-003676	5/14/2018	5/14/2019	1	Health Suite	In health suite	WF-05142018-003676	11/28/2018	FT-FY19-112018-003676-A	<1	FT-FY19-112018-003676-B	<1
WS-003677	5/14/2018	5/14/2019	1	Break Room	In staff lounge	WF-05142018-003677	11/28/2018	FT-FY19-112018-003677-A	<1	FT-FY19-112018-003677-B	<1
WS-003679	5/14/2018	5/14/2019	1	Cooler	In hallway 151 adjacent to restroom	WF-05142018-003679	11/28/2018	FT-FY19-112018-003679-A	<1	FT-FY19-112018-003679-B	<1
WS-003680	11/16/2018	11/16/2019	2	Cooler	In hallway 234 adjacent to restroom	WF-11162018-003680	11/28/2018	FT-FY19-112018-003680-A	<1	FT-FY19-112018-003680-B	<1
WS-003681	11/16/2018	11/16/2019	2	Cooler	In hallway 229 adjacent to library	WF-11162018-003681	11/28/2018	FT-FY19-112018-003681-A	<1	FT-FY19-112018-003681-B	<1
WS-003682	5/14/2018	5/14/2019	2	Cooler	In hallway 240 adjacent to restroom	WF-05142018-003682	11/28/2018	FT-FY19-112018-003682-A	<1	FT-FY19-112018-003682-B	<1
WS-004281	11/16/2018	11/16/2019	1	Bottle Filler	In cafeteria	WF-11162018-004281	11/28/2018	FT-FY19-112018-004281-A	<1	FT-FY19-112018-004281-B	<1
WS-004282	11/16/2018	11/16/2019	1	Cooler	In cafeteria Low Left	WF-11162018-004282	11/28/2018	FT-FY19-112018-004282-A	<1	FT-FY19-112018-004282-B	<1
WS-004283	11/16/2018	11/16/2019	1	Cooler	In cafeteria High Right	WF-11162018-004283	11/28/2018	FT-FY19-112018-004283-A	<1	FT-FY19-112018-004283-B	<1
WS-004560	10/22/2018	10/22/2019	Ground Floor	Classroom Faucet	In classroom 022	WF-10222018-004560	11/28/2018	FT-FY19-112018-004560-A	<1	FT-FY19-112018-004560-B	<1
WS-004561	10/22/2018	10/22/2019	Ground Floor	Classroom Faucet	In classroom 021	WF-10222018-004561	11/28/2018	FT-FY19-112018-004561-A	<1	FT-FY19-112018-004561-B	<1
WS-004562	10/22/2018	10/22/2019	Ground Floor	Classroom Faucet	In classroom 024	WF-10222018-004562	11/28/2018	FT-FY19-112018-004562-A	<1	FT-FY19-112018-004562-B	<1
WS-004563	10/22/2018	10/22/2019	Ground Floor	Classroom Faucet	In classroom 008	WF-10222018-004563	11/28/2018	FT-FY19-112018-004563-A	<1	FT-FY19-112018-004563-B	<1
WS-004564	10/22/2018	10/22/2019	Ground Floor	Classroom Faucet	In classroom 007	WF-10222018-004564	11/28/2018	FT-FY19-112018-004564-A	<1	FT-FY19-112018-004564-B	<1
WS-004565	10/22/2018	10/22/2019	Ground Floor	Classroom Faucet	In classroom 006	WF-10222018-004565	11/28/2018	FT-FY19-112018-004565-A	<1	FT-FY19-112018-004565-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003661	Ground Floor	Food Prep Sink	In kitchen	11/28/2018	FT-FY19-112018-003661-A	<1	FT-FY19-112018-003661-B	<1	