



# Bunker Hill Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002942	8/22/2023	8/22/2024	1	Bathroom	In classroom 103 in bathroom	WF-08222023-002942	12/7/2023	FT-FY24-11012023-002942-A	2.0	FT-FY24-11012023-002942-B	<1	
WS-002943	8/22/2023	8/22/2024	1	Bathroom	In classroom 105 in bathroom	WF-08222023-002943	12/7/2023	FT-FY24-11012023-002943-A	2.1	FT-FY24-11012023-002943-B	<1	
WS-002944	8/22/2023	8/22/2024	1	Bathroom	In classroom 106 in bathroom	WF-08222023-002944	12/7/2023	FT-FY24-11012023-002944-A	<1	FT-FY24-11012023-002944-B	<1	
WS-002945	8/22/2023	8/22/2024	1	Bathroom	In classroom 108 in bathroom	WF-08222023-002945	12/7/2023	FT-FY24-11012023-002945-A	2.6	FT-FY24-11012023-002945-B	<1	
WS-002946	8/22/2023	8/22/2024	1	Bathroom	In classroom 109 in bathroom	WF-08222023-002946	12/7/2023	FT-FY24-11012023-002946-A	1.3	FT-FY24-11012023-002946-B	<1	
WS-002947	8/22/2023	8/22/2024	1	Bathroom	In classroom 110 in bathroom	WF-08222023-002947	12/7/2023	FT-FY24-11012023-002947-A	1.1	FT-FY24-11012023-002947-B	<1	
WS-002948	8/22/2023	8/22/2024	1	Bathroom	In classroom 111 in bathroom	WF-08222023-002948	12/7/2023	FT-FY24-11012023-002948-A	3.9	FT-FY24-11012023-002948-B	<1	
WS-002950	4/3/2023	4/3/2024	Basement	Cooler	In kitchen	WF-04032023-002950	12/7/2023	FT-FY24-11012023-002950-A	<1	FT-FY24-11012023-002950-B	<1	
WS-002954	4/3/2023	4/3/2024	1	Cooler	In hallway adjacent to room 144	WF-04032023-002954	12/7/2023	FT-FY24-11012023-002954-A	<1	FT-FY24-11012023-002954-B	<1	
WS-002955	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 105	Right	WF-08222023-002955	12/7/2023	FT-FY24-11012023-002955-A	2.1	FT-FY24-11012023-002955-B	<1
WS-002956	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 105	Left	WF-04032023-002956	12/7/2023	FT-FY24-11012023-002956-A	<1	FT-FY24-11012023-002956-B	<1
WS-002957	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 106	Left	WF-04032023-002957	12/7/2023	FT-FY24-11012023-002957-A	1.4	FT-FY24-11012023-002957-B	<1
WS-002960	4/3/2023	4/3/2024	1	Cooler	In health suite	WF-04032023-002960	12/7/2023	FT-FY24-11012023-002960-A	<1	FT-FY24-11012023-002960-B	<1	
WS-002961	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 108	Left	WF-04032023-002961	12/7/2023	FT-FY24-11012023-002961-A	<1	FT-FY24-11012023-002961-B	<1
WS-002962	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 108	Right	WF-08222023-002962	12/7/2023	FT-FY24-11012023-002962-A	<1	FT-FY24-11012023-002962-B	<1
WS-002963	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 109	Left	WF-04032023-002963	12/7/2023	FT-FY24-11012023-002963-A	<1	FT-FY24-11012023-002963-B	<1
WS-002964	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 109	Right	WF-08222023-002964	12/7/2023	FT-FY24-11012023-002964-A	<1	FT-FY24-11012023-002964-B	<1
WS-002965	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 110	Left	WF-04032023-002965	12/7/2023	FT-FY24-11012023-002965-A	<1	FT-FY24-11012023-002965-B	<1
WS-002966	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 110	Right	WF-08222023-002966	12/7/2023	FT-FY24-11012023-002966-A	1.6	FT-FY24-11012023-002966-B	<1
WS-002967	4/3/2023	4/3/2024	1	Cooler	In hallway adjacent to room 110	WF-04032023-002967	12/7/2023	FT-FY24-11012023-002967-A	<1	FT-FY24-11012023-002967-B	<1	
WS-002968	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 111	Left	WF-04032023-002968	12/7/2023	FT-FY24-11012023-002968-A	<1	FT-FY24-11012023-002968-B	<1
WS-002969	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 111	Right	WF-08222023-002969	12/7/2023	FT-FY24-11012023-002969-A	4.6	FT-FY24-11012023-002969-B	<1
WS-002978	4/3/2023	4/3/2024	2	Cooler	In hallway adjacent to room 214	WF-04032023-002978	12/7/2023	FT-FY24-11012023-002978-A	<1	FT-FY24-11012023-002978-B	<1	
WS-002979	4/3/2023	4/3/2024	2	Cooler	In hallway adjacent to room 212	WF-04032023-002979	12/7/2023	FT-FY24-11012023-002979-A	<1	FT-FY24-11012023-002979-B	<1	
WS-002980	4/3/2023	4/3/2024	2	Cooler	In hallway adjacent to boys restroom	WF-04032023-002980	12/7/2023	FT-FY24-11012023-002980-A	<1	FT-FY24-11012023-002980-B	<1	
WS-002981	4/3/2023	4/3/2024	2	Cooler	In hallway adjacent to room 203	WF-04032023-002981	12/7/2023	FT-FY24-11012023-002981-A	<1	FT-FY24-11012023-002981-B	<1	
WS-002982	8/22/2023	8/22/2024	2	Classroom Faucet	In classroom 203	Mid	WF-08222023-002982	12/7/2023	FT-FY24-11012023-002982-A	4.1	FT-FY24-11012023-002982-B	<1
WS-002997	4/3/2023	4/3/2024	1	Bottle Filler	In lobby adjacent to auditorium	WF-04032023-002997	12/7/2023	FT-FY24-11012023-002997-A	<1	FT-FY24-11012023-002997-B	<1	
WS-002998	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 104	WF-04032023-002998	12/7/2023	FT-FY24-11012023-002998-A	1.1	FT-FY24-11012023-002998-B	<1	

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002951	1/9/2023	1/9/2024	Basement	Food Prep Sink	In kitchen	WF-01092023-002951	12/7/2023	FT-FY24-11012023-002951-A	<1	FT-FY24-11012023-002951-B	<1

## FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002958	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 106 Right	WF-08222023-002958	12/7/2023	FT-FY24-11012023-002958-A	10.6	FT-FY24-11012023-002958-B	<1
WS- 002999	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 104	WF-08222023-002999	12/7/2023	FT-FY24-11012023-002999-A	7.2	FT-FY24-11012023-002999-B	<1