



Bunker Hill Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002942	9/16/2020	9/16/2021	1	Bathroom	In classroom 103 in bathroom	WF-09162020-002942	1/28/2021	FT-FY21-012021-002942-A	2.0	FT-FY21-012021-002942-B	<1
WS- 002943	9/16/2020	9/16/2021	1	Bathroom	In classroom 105 in bathroom	WF-09162020-002943	1/28/2021	FT-FY21-012021-002943-A	<1	FT-FY21-012021-002943-B	<1
WS- 002944	9/16/2020	9/16/2021	1	Bathroom	In classroom 106 in bathroom	WF-09162020-002944	1/28/2021	FT-FY21-012021-002944-A	<1	FT-FY21-012021-002944-B	<1
WS- 002945	9/16/2020	9/16/2021	1	Bathroom	In classroom 108 in bathroom	WF-09162020-002945	1/28/2021	FT-FY21-012021-002945-A	<1	FT-FY21-012021-002945-B	<1
WS- 002946	9/16/2020	9/16/2021	1	Bathroom	In classroom 109 in bathroom	WF-09162020-002946	1/28/2021	FT-FY21-012021-002946-A	<1	FT-FY21-012021-002946-B	<1
WS- 002947	9/16/2020	9/16/2021	1	Bathroom	In classroom 110 in bathroom	WF-09162020-002947	1/28/2021	FT-FY21-012021-002947-A	<1	FT-FY21-012021-002947-B	<1
WS- 002948	9/16/2020	9/16/2021	1	Bathroom	In classroom 111 in bathroom	WF-09162020-002948	1/28/2021	FT-FY21-012021-002948-A	<1	FT-FY21-012021-002948-B	<1
WS- 002950	5/20/2020	5/20/2021	Basement	Cooler	In kitchen	WF-05202020-002950	1/28/2021	FT-FY21-012021-002950-A	<1	FT-FY21-012021-002950-B	<1
WS- 002952	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 103 Right	WF-09162020-002952	1/28/2021	FT-FY21-012021-002952-A	1.2	FT-FY21-012021-002952-B	<1
WS- 002953	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 103 Left	WF-05202020-002953	1/28/2021	FT-FY21-012021-002953-A	<1	FT-FY21-012021-002953-B	<1
WS- 002954	5/20/2020	5/20/2021	1	Cooler	In hallway adjacent to room 144	WF-05202020-002954	1/28/2021	FT-FY21-012021-002954-A	<1	FT-FY21-012021-002954-B	<1
WS- 002955	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 105 Right	WF-09162020-002955	1/28/2021	FT-FY21-012021-002955-A	1.4	FT-FY21-012021-002955-B	2.3
WS- 002956	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 105 Left	WF-05202020-002956	1/28/2021	FT-FY21-012021-002956-A	2.0	FT-FY21-012021-002956-B	2.4
WS- 002957	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 106 Left	WF-05202020-002957	1/28/2021	FT-FY21-012021-002957-A	<1	FT-FY21-012021-002957-B	<1
WS- 002958	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 106 Right	WF-09162020-002958	1/28/2021	FT-FY21-012021-002958-A	<1	FT-FY21-012021-002958-B	<1
WS- 002960	5/20/2020	5/20/2021	1	Cooler	In health suite	WF-05202020-002960	1/28/2021	FT-FY21-012021-002960-A	<1	FT-FY21-012021-002960-B	<1
WS- 002961	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 108 Left	WF-05202020-002961	1/28/2021	FT-FY21-012021-002961-A	<1	FT-FY21-012021-002961-B	<1
WS- 002962	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 108 Right	WF-09162020-002962	1/28/2021	FT-FY21-012021-002962-A	<1	FT-FY21-012021-002962-B	<1
WS- 002963	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 109 Left	WF-05202020-002963	1/28/2021	FT-FY21-012021-002963-A	<1	FT-FY21-012021-002963-B	<1
WS- 002964	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 109 Right	WF-09162020-002964	1/28/2021	FT-FY21-012021-002964-A	<1	FT-FY21-012021-002964-B	<1
WS- 002965	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 110 Left	WF-05202020-002965	1/28/2021	FT-FY21-012021-002965-A	<1	FT-FY21-012021-002965-B	<1
WS- 002966	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 110 Right	WF-09162020-002966	1/28/2021	FT-FY21-012021-002966-A	<1	FT-FY21-012021-002966-B	<1
WS- 002967	5/20/2020	5/20/2021	1	Cooler	In hallway adjacent to room 110	WF-05202020-002967	1/28/2021	FT-FY21-012021-002967-A	<1	FT-FY21-012021-002967-B	<1
WS- 002968	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 111 Left	WF-05202020-002968	1/28/2021	FT-FY21-012021-002968-A	<1	FT-FY21-012021-002968-B	<1
WS- 002969	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 111 Right	WF-09162020-002969	1/28/2021	FT-FY21-012021-002969-A	<1	FT-FY21-012021-002969-B	<1
WS- 002972	5/20/2020	5/20/2021	1	Cooler	In hallway across from room 131	WF-05202020-002972	1/28/2021	FT-FY21-012021-002972-A	<1	FT-FY21-012021-002972-B	<1
WS- 002978	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 214	WF-05202020-002978	1/28/2021	FT-FY21-012021-002978-A	<1	FT-FY21-012021-002978-B	<1
WS- 002979	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 212	WF-05202020-002979	1/28/2021	FT-FY21-012021-002979-A	<1	FT-FY21-012021-002979-B	<1
WS- 002980	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to boys restroom	WF-05202020-002980	1/28/2021	FT-FY21-012021-002980-A	<1	FT-FY21-012021-002980-B	<1
WS- 002981	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 203	WF-05202020-002981	1/28/2021	FT-FY21-012021-002981-A	<1	FT-FY21-012021-002981-B	<1
WS- 002982	9/16/2020	9/16/2021	2	Classroom Faucet	In classroom 203 Mid	WF-09162020-002982	1/28/2021	FT-FY21-012021-002982-A	<1	FT-FY21-012021-002982-B	<1
WS- 002998	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 104	WF-05202020-002998	1/28/2021	FT-FY21-012021-002998-A	<1	FT-FY21-012021-002998-B	<1
WS- 002999	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 104	WF-09162020-002999	1/28/2021	FT-FY21-012021-002999-A	<1	FT-FY21-012021-002999-B	<1

WS- 003000	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 204	WF-05202020-003000	1/28/2021	FT-FY21-012021-003000-A	<1	FT-FY21-012021-003000-B	<1
------------	-----------	-----------	---	--------	---------------------------------	--------------------	-----------	-------------------------	----	-------------------------	----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002951	2/12/2020	2/12/2021	Basement	Food Prep Sink	In kitchen	WF-02122020-002951	1/28/2021	FT-FY21-012021-002951-A	<1	FT-FY21-012021-002951-B	<1

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002971	5/20/2020	5/20/2021	1	Break Room	In staff lounge adjacent to room 112	WF-05202020-002971	1/28/2021	FT-FY21-012021-002971-A	10	FT-FY21-012021-002971-B	12