



# Bunker Hill Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002942	8/30/2022	8/30/2023	1	Bathroom	In classroom 103 in bathroom	WF-08302022-002942	1/4/2023	FT-FY23-11182022-002942-A	<1	FT-FY23-11182022-002942-B	<1
WS- 002943	8/30/2022	8/30/2023	1	Bathroom	In classroom 105 in bathroom	WF-08302022-002943	1/4/2023	FT-FY23-11182022-002943-A	<1	FT-FY23-11182022-002943-B	<1
WS- 002944	8/30/2022	8/30/2023	1	Bathroom	In classroom 106 in bathroom	WF-08302022-002944	1/4/2023	FT-FY23-11182022-002944-A	<1	FT-FY23-11182022-002944-B	<1
WS- 002945	8/30/2022	8/30/2023	1	Bathroom	In classroom 108 in bathroom	WF-08302022-002945	1/4/2023	FT-FY23-11182022-002945-A	<1	FT-FY23-11182022-002945-B	<1
WS- 002946	8/30/2022	8/30/2023	1	Bathroom	In classroom 109 in bathroom	WF-08302022-002946	1/4/2023	FT-FY23-11182022-002946-A	<1	FT-FY23-11182022-002946-B	<1
WS- 002947	8/30/2022	8/30/2023	1	Bathroom	In classroom 110 in bathroom	WF-08302022-002947	1/4/2023	FT-FY23-11182022-002947-A	<1	FT-FY23-11182022-002947-B	<1
WS- 002948	8/30/2022	8/30/2023	1	Bathroom	In classroom 111 in bathroom	WF-08302022-002948	1/4/2023	FT-FY23-11182022-002948-A	<1	FT-FY23-11182022-002948-B	<1
WS- 002950	4/10/2022	4/10/2023	Basement	Cooler	In kitchen	WF-04102022-002950	1/4/2023	FT-FY23-11182022-002950-A	<1	FT-FY23-11182022-002950-B	<1
WS- 002954	4/10/2022	4/10/2023	1	Cooler	In hallway adjacent to room 144	WF-04102022-002954	1/4/2023	FT-FY23-11182022-002954-A	<1	FT-FY23-11182022-002954-B	<1
WS- 002955	8/30/2022	8/30/2023	1	Combo Faucet	In classroom 105 Right	WF-08302022-002955	1/4/2023	FT-FY23-11182022-002955-A	<1	FT-FY23-11182022-002955-B	<1
WS- 002956	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 105 Left	WF-04102022-002956	1/4/2023	FT-FY23-11182022-002956-A	<1	FT-FY23-11182022-002956-B	<1
WS- 002957	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 106 Left	WF-04102022-002957	1/4/2023	FT-FY23-11182022-002957-A	<1	FT-FY23-11182022-002957-B	<1
WS- 002958	8/30/2022	8/30/2023	1	Combo Faucet	In classroom 106 Right	WF-08302022-002958	1/4/2023	FT-FY23-11182022-002958-A	<1	FT-FY23-11182022-002958-B	<1
WS- 002960	4/10/2022	4/10/2023	1	Cooler	In health suite	WF-04102022-002960	1/4/2023	FT-FY23-11182022-002960-A	<1	FT-FY23-11182022-002960-B	<1
WS- 002961	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 108 Left	WF-04102022-002961	1/4/2023	FT-FY23-11182022-002961-A	<1	FT-FY23-11182022-002961-B	<1
WS- 002962	8/30/2022	8/30/2023	1	Combo Faucet	In classroom 108 Right	WF-08302022-002962	1/4/2023	FT-FY23-11182022-002962-A	<1	FT-FY23-11182022-002962-B	<1
WS- 002963	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 109 Left	WF-04102022-002963	1/4/2023	FT-FY23-11182022-002963-A	<1	FT-FY23-11182022-002963-B	<1
WS- 002964	8/30/2022	8/30/2023	1	Combo Faucet	In classroom 109 Right	WF-08302022-002964	1/4/2023	FT-FY23-11182022-002964-A	1.7	FT-FY23-11182022-002964-B	<1
WS- 002965	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 110 Left	WF-04102022-002965	1/4/2023	FT-FY23-11182022-002965-A	<1	FT-FY23-11182022-002965-B	<1
WS- 002966	8/30/2022	8/30/2023	1	Combo Faucet	In classroom 110 Right	WF-08302022-002966	1/4/2023	FT-FY23-11182022-002966-A	<1	FT-FY23-11182022-002966-B	<1
WS- 002967	4/10/2022	4/10/2023	1	Cooler	In hallway adjacent to room 110	WF-04102022-002967	1/4/2023	FT-FY23-11182022-002967-A	<1	FT-FY23-11182022-002967-B	<1
WS- 002968	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 111 Left	WF-04102022-002968	1/4/2023	FT-FY23-11182022-002968-A	<1	FT-FY23-11182022-002968-B	<1
WS- 002969	8/30/2022	8/30/2023	1	Combo Faucet	In classroom 111 Right	WF-08302022-002969	1/4/2023	FT-FY23-11182022-002969-A	<1	FT-FY23-11182022-002969-B	<1
WS- 002972	4/10/2022	4/10/2023	1	Cooler	In hallway across from room 131	WF-04102022-002972	1/4/2023	FT-FY23-11182022-002972-A	<1	FT-FY23-11182022-002972-B	2.9
WS- 002978	4/10/2022	4/10/2023	2	Cooler	In hallway adjacent to room 214	WF-04102022-002978	1/4/2023	FT-FY23-11182022-002978-A	1.6	FT-FY23-11182022-002978-B	<1
WS- 002979	4/10/2022	4/10/2023	2	Cooler	In hallway adjacent to room 212	WF-04102022-002979	1/4/2023	FT-FY23-11182022-002979-A	<1	FT-FY23-11182022-002979-B	<1
WS- 002980	4/10/2022	4/10/2023	2	Cooler	In hallway adjacent to boys restroom	WF-04102022-002980	1/4/2023	FT-FY23-11182022-002980-A	1.5	FT-FY23-11182022-002980-B	<1
WS- 002981	4/10/2022	4/10/2023	2	Cooler	In hallway adjacent to room 203	WF-04102022-002981	1/4/2023	FT-FY23-11182022-002981-A	1.6	FT-FY23-11182022-002981-B	<1
WS- 002982	8/30/2022	8/30/2023	2	Classroom Faucet	In classroom 203 Mid	WF-08302022-002982	1/4/2023	FT-FY23-11182022-002982-A	1.6	FT-FY23-11182022-002982-B	<1
WS- 002998	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 104	WF-04102022-002998	1/4/2023	FT-FY23-11182022-002998-A	<1	FT-FY23-11182022-002998-B	<1
WS- 002999	8/30/2022	8/30/2023	1	Combo Faucet	In classroom 104	WF-08302022-002999	1/4/2023	FT-FY23-11182022-002999-A	<1	FT-FY23-11182022-002999-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002951	2/2/2022	2/2/2023	Basement	Food Prep Sink	In kitchen	WF-02022022-002951	1/4/2023	FT-FY23-11182022-002951-A	<1	FT-FY23-11182022-002951-B	<1