



# Bunker Hill ES Lead Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002942	9/24/2019	9/24/2020	1	Bathroom	In classroom 103 in bathroom	WF-09242019-002942	11/4/2019	FT-FY20-102019-002942-A	<1	FT-FY20-102019-002942-B	<1
WS- 002943	9/24/2019	9/24/2020	1	Bathroom	In classroom 105 in bathroom	WF-09242019-002943	11/4/2019	FT-FY20-102019-002943-A	<1	FT-FY20-102019-002943-B	<1
WS- 002944	9/24/2019	9/24/2020	1	Bathroom	In classroom 106 in bathroom	WF-09242019-002944	11/4/2019	FT-FY20-102019-002944-A	<1	FT-FY20-102019-002944-B	<1
WS- 002945	9/24/2019	9/24/2020	1	Bathroom	In classroom 108 in bathroom	WF-09242019-002945	11/4/2019	FT-FY20-102019-002945-A	<1	FT-FY20-102019-002945-B	<1
WS- 002946	9/24/2019	9/24/2020	1	Bathroom	In classroom 109 in bathroom	WF-09242019-002946	11/4/2019	FT-FY20-102019-002946-A	<1	FT-FY20-102019-002946-B	<1
WS- 002947	9/24/2019	9/24/2020	1	Bathroom	In classroom 110 in bathroom	WF-09242019-002947	11/4/2019	FT-FY20-102019-002947-A	<1	FT-FY20-102019-002947-B	<1
WS- 002948	9/24/2019	9/24/2020	1	Bathroom	In classroom 111 in bathroom	WF-09242019-002948	11/4/2019	FT-FY20-102019-002948-A	<1	FT-FY20-102019-002948-B	<1
WS- 002950	6/3/2019	6/3/2020	Basement	Cooler	In kitchen	WF-06032019-002950	11/4/2019	FT-FY20-102019-002950-A	<1	FT-FY20-102019-002950-B	<1
WS- 002952	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 103 Right	WF-09242019-002952	11/4/2019	FT-FY20-102019-002952-A	<1	FT-FY20-102019-002952-B	<1
WS- 002953	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 103 Left	WF-06032019-002953	11/4/2019	FT-FY20-102019-002953-A	<1	FT-FY20-102019-002953-B	<1
WS- 002954	6/3/2019	6/3/2020	1	Cooler	In hallway adjacent to room 144	WF-06032019-002954	11/4/2019	FT-FY20-102019-002954-A	<1	FT-FY20-102019-002954-B	<1
WS- 002955	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 105 Right	WF-09242019-002955	11/4/2019	FT-FY20-102019-002955-A	<1	FT-FY20-102019-002955-B	<1
WS- 002956	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 105 Left	WF-06032019-002956	11/4/2019	FT-FY20-102019-002956-A	<1	FT-FY20-102019-002956-B	<1
WS- 002957	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 106 Left	WF-06032019-002957	11/4/2019	FT-FY20-102019-002957-A	<1	FT-FY20-102019-002957-B	<1
WS- 002958	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 106 Right	WF-09242019-002958	11/4/2019	FT-FY20-102019-002958-A	<1	FT-FY20-102019-002958-B	<1
WS- 002960	6/3/2019	6/3/2020	1	Cooler	In health suite	WF-06032019-002960	11/4/2019	FT-FY20-102019-002960-A	<1	FT-FY20-102019-002960-B	<1
WS- 002961	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 108 Left	WF-06032019-002961	11/4/2019	FT-FY20-102019-002961-A	<1	FT-FY20-102019-002961-B	<1
WS- 002962	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 108 Right	WF-09242019-002962	11/4/2019	FT-FY20-112019-002962-A	3.1	FT-FY20-112019-002962-B	<1
WS- 002963	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 109 Left	WF-06032019-002963	11/4/2019	FT-FY20-102019-002963-A	<1	FT-FY20-102019-002963-B	<1
WS- 002964	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 109 Right	WF-09242019-002964	11/4/2019	FT-FY20-102019-002964-A	<1	FT-FY20-102019-002964-B	<1
WS- 002965	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 110 Left	WF-06032019-002965	11/4/2019	FT-FY20-102019-002965-A	<1	FT-FY20-102019-002965-B	<1
WS- 002966	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 110 Right	WF-09242019-002966	11/4/2019	FT-FY20-102019-002966-A	<1	FT-FY20-102019-002966-B	<1
WS- 002967	6/3/2019	6/3/2020	1	Cooler	In hallway adjacent to room 110	WF-06032019-002967	11/4/2019	FT-FY20-102019-002967-A	<1	FT-FY20-102019-002967-B	<1
WS- 002968	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 111 Left	WF-06032019-002968	11/4/2019	FT-FY20-102019-002968-A	<1	FT-FY20-102019-002968-B	<1
WS- 002969	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 111 Right	WF-09242019-002969	11/4/2019	FT-FY20-102019-002969-A	<1	FT-FY20-102019-002969-B	<1
WS- 002971	6/3/2019	6/3/2020	1	Break Room	In staff lounge adjacent to room 112	WF-06032019-002971	11/4/2019	FT-FY20-102019-002971-A	<1	FT-FY20-102019-002971-B	<1
WS- 002972	6/3/2019	6/3/2020	1	Cooler	In hallway across from room 131	WF-06032019-002972	11/4/2019	FT-FY20-102019-002972-A	<1	FT-FY20-102019-002972-B	<1
WS- 002978	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to room 214	WF-06032019-002978	11/4/2019	FT-FY20-102019-002978-A	<1	FT-FY20-102019-002978-B	<1
WS- 002979	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to room 212	WF-06032019-002979	11/4/2019	FT-FY20-102019-002979-A	<1	FT-FY20-102019-002979-B	<1
WS- 002980	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to boys restroom	WF-06032019-002980	11/4/2019	FT-FY20-102019-002980-A	<1	FT-FY20-102019-002980-B	<1
WS- 002981	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to room 203	WF-06032019-002981	11/4/2019	FT-FY20-102019-002981-A	<1	FT-FY20-102019-002981-B	<1
WS- 002982	9/24/2019	9/24/2020	2	Classroom Faucet	In classroom 203 Mid	WF-09242019-002982	11/4/2019	FT-FY20-102019-002982-A	<1	FT-FY20-102019-002982-B	<1
WS- 002998	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 104	WF-06032019-002998	11/4/2019	FT-FY20-102019-002998-A	<1	FT-FY20-102019-002998-B	<1

WS- 002999	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 104	WF-09242019-002999	11/4/2019	FT-FY20-102019-002999-A	2	FT-FY20-102019-002999-B	<1
WS- 003000	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to room 204	WF-06032019-003000	11/4/2019	FT-FY20-102019-003000-A	<1	FT-FY20-102019-003000-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002951	7/2/2019	7/2/2020	Basement	Food Prep Sink	In kitchen	WF-07022019-002951	11/4/2019	FT-FY20-102019-002951-A	<1	FT-FY20-102019-002951-B	<1