



# Bunker Hill Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002942	9/16/2020	9/16/2021	1	Bathroom	In classroom 103 in bathroom	WF-09162020-002942	1/28/2021	FT-FY21-012021-002942-A	2.0	FT-FY21-012021-002942-B	<1	
WS-002943	9/16/2020	9/16/2021	1	Bathroom	In classroom 105 in bathroom	WF-09162020-002943	1/28/2021	FT-FY21-012021-002943-A	<1	FT-FY21-012021-002943-B	<1	
WS-002944	9/16/2020	9/16/2021	1	Bathroom	In classroom 106 in bathroom	WF-09162020-002944	1/28/2021	FT-FY21-012021-002944-A	<1	FT-FY21-012021-002944-B	<1	
WS-002945	9/16/2020	9/16/2021	1	Bathroom	In classroom 108 in bathroom	WF-09162020-002945	1/28/2021	FT-FY21-012021-002945-A	<1	FT-FY21-012021-002945-B	<1	
WS-002946	9/16/2020	9/16/2021	1	Bathroom	In classroom 109 in bathroom	WF-09162020-002946	1/28/2021	FT-FY21-012021-002946-A	<1	FT-FY21-012021-002946-B	<1	
WS-002947	9/16/2020	9/16/2021	1	Bathroom	In classroom 110 in bathroom	WF-09162020-002947	1/28/2021	FT-FY21-012021-002947-A	<1	FT-FY21-012021-002947-B	<1	
WS-002948	9/16/2020	9/16/2021	1	Bathroom	In classroom 111 in bathroom	WF-09162020-002948	1/28/2021	FT-FY21-012021-002948-A	<1	FT-FY21-012021-002948-B	<1	
WS-002950	5/20/2020	5/20/2021	Basement	Cooler	In kitchen	WF-05202020-002950	1/28/2021	FT-FY21-012021-002950-A	<1	FT-FY21-012021-002950-B	<1	
WS-002952	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 103	Right	WF-09162020-002952	1/28/2021	FT-FY21-012021-002952-A	1.2	FT-FY21-012021-002952-B	<1
WS-002953	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 103	Left	WF-05202020-002953	1/28/2021	FT-FY21-012021-002953-A	<1	FT-FY21-012021-002953-B	<1
WS-002954	5/20/2020	5/20/2021	1	Cooler	In hallway adjacent to room 144		WF-05202020-002954	1/28/2021	FT-FY21-012021-002954-A	<1	FT-FY21-012021-002954-B	<1
WS-002955	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 105	Right	WF-09162020-002955	1/28/2021	FT-FY21-012021-002955-A	1.4	FT-FY21-012021-002955-B	2.3
WS-002956	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 105	Left	WF-05202020-002956	1/28/2021	FT-FY21-012021-002956-A	2.0	FT-FY21-012021-002956-B	2.4
WS-002957	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 106	Left	WF-05202020-002957	1/28/2021	FT-FY21-012021-002957-A	<1	FT-FY21-012021-002957-B	<1
WS-002958	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 106	Right	WF-09162020-002958	1/28/2021	FT-FY21-012021-002958-A	<1	FT-FY21-012021-002958-B	<1
WS-002960	5/20/2020	5/20/2021	1	Cooler	In health suite		WF-05202020-002960	1/28/2021	FT-FY21-012021-002960-A	<1	FT-FY21-012021-002960-B	<1
WS-002961	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 108	Left	WF-05202020-002961	1/28/2021	FT-FY21-012021-002961-A	<1	FT-FY21-012021-002961-B	<1
WS-002962	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 108	Right	WF-09162020-002962	1/28/2021	FT-FY21-012021-002962-A	<1	FT-FY21-012021-002962-B	<1
WS-002963	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 109	Left	WF-05202020-002963	1/28/2021	FT-FY21-012021-002963-A	<1	FT-FY21-012021-002963-B	<1
WS-002964	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 109	Right	WF-09162020-002964	1/28/2021	FT-FY21-012021-002964-A	<1	FT-FY21-012021-002964-B	<1
WS-002965	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 110	Left	WF-05202020-002965	1/28/2021	FT-FY21-012021-002965-A	<1	FT-FY21-012021-002965-B	<1
WS-002966	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 110	Right	WF-09162020-002966	1/28/2021	FT-FY21-012021-002966-A	<1	FT-FY21-012021-002966-B	<1
WS-002967	5/20/2020	5/20/2021	1	Cooler	In hallway adjacent to room 110		WF-05202020-002967	1/28/2021	FT-FY21-012021-002967-A	<1	FT-FY21-012021-002967-B	<1
WS-002968	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 111	Left	WF-05202020-002968	1/28/2021	FT-FY21-012021-002968-A	<1	FT-FY21-012021-002968-B	<1
WS-002969	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 111	Right	WF-09162020-002969	1/28/2021	FT-FY21-012021-002969-A	<1	FT-FY21-012021-002969-B	<1
WS-002972	5/20/2020	5/20/2021	1	Cooler	In hallway across from room 131		WF-05202020-002972	1/28/2021	FT-FY21-012021-002972-A	<1	FT-FY21-012021-002972-B	<1
WS-002978	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 214		WF-05202020-002978	1/28/2021	FT-FY21-012021-002978-A	<1	FT-FY21-012021-002978-B	<1
WS-002979	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 212		WF-05202020-002979	1/28/2021	FT-FY21-012021-002979-A	<1	FT-FY21-012021-002979-B	<1
WS-002980	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to boys restroom		WF-05202020-002980	1/28/2021	FT-FY21-012021-002980-A	<1	FT-FY21-012021-002980-B	<1
WS-002981	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 203		WF-05202020-002981	1/28/2021	FT-FY21-012021-002981-A	<1	FT-FY21-012021-002981-B	<1
WS-002982	9/16/2020	9/16/2021	2	Classroom Faucet	In classroom 203	Mid	WF-09162020-002982	1/28/2021	FT-FY21-012021-002982-A	<1	FT-FY21-012021-002982-B	<1
WS-002998	5/20/2020	5/20/2021	1	Combo Fountain	In classroom 104		WF-05202020-002998	1/28/2021	FT-FY21-012021-002998-A	<1	FT-FY21-012021-002998-B	<1

WS- 002999	9/16/2020	9/16/2021	1	Combo Faucet	In classroom 104	WF-09162020-002999	1/28/2021	FT-FY21-012021-002999-A	<1	FT-FY21-012021-002999-B	<1
WS- 003000	5/20/2020	5/20/2021	2	Cooler	In hallway adjacent to room 204	WF-05202020-003000	1/28/2021	FT-FY21-012021-003000-A	<1	FT-FY21-012021-003000-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002951	2/12/2020	2/12/2021	Basement	Food Prep Sink	In kitchen	WF-02122020-002951	1/28/2021	FT-FY21-012021-002951-A	<1	FT-FY21-012021-002951-B	<1

### FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002971	5/20/2020	5/20/2021	1	Break Room	In staff lounge adjacent to room 112	WF-05202020-002971	1/28/2021	FT-FY21-012021-002971-A	10	FT-FY21-012021-002971-B	12

### First Re-test (After Plumbing Check)

### FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002971	2/3/2021	2/3/2022	1	Break Room	In staff lounge adjacent to room 112	WF-02032021-002971	2/8/2021	FT-FY21-022021-002971-A	<1	FT-FY21-022021-002971-B	<1