



BUNKER HILL EC ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002950	8/21/2016	Basement	Cooler	In kitchen	FT-82016-002950-A	< 1	FT-82016-002950-B	< 1
2	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002951	8/21/2016	Basement	Food Prep Sink	In kitchen	FT-72016-002951-A	< 1	FT-72016-002951-B	< 1
3	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002953	8/21/2016	1	Fountain	In storage room 104 Left	FT-82016-002953-A	< 1	FT-82016-002953-B	< 1
4	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002954	8/21/2016	1	Cooler	In hallway adjacent to room 144	FT-82016-002954-A	< 1	FT-82016-002954-B	< 1
5	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002956	8/21/2016	1	Fountain	In classroom 105 Left	FT-82016-002956-A	< 1	FT-82016-002956-B	< 1
6	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002957	8/21/2016	1	Fountain	In classroom 106 Left	FT-82016-002957-A	< 1	FT-82016-002957-B	< 1
7	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002959	8/21/2016	1	Cooler	In lobby adjacent to auditorium	FT-82016-002959-A	< 1	FT-82016-002959-B	< 1
8	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002960	8/21/2016	1	Cooler	In health suite	FT-82016-002960-A	< 1	FT-82016-002960-B	< 1
9	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002961	8/21/2016	1	Fountain	In classroom 108 Left	FT-82016-002961-A	< 1	FT-82016-002961-B	< 1
10	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002963	8/21/2016	1	Fountain	In classroom 109 Left	FT-82016-002963-A	< 1	FT-82016-002963-B	< 1
11	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002965	8/21/2016	1	Fountain	In classroom 110 Left	FT-82016-002965-A	< 1	FT-82016-002965-B	< 1
12	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002967	8/21/2016	1	Cooler	In hallway adjacent to room 110	FT-82016-002967-A	3.8	FT-82016-002967-B	< 1
			10/10/2016				Re-test A	< 1	Re-test B	< 1
13	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002968	8/21/2016	1	Fountain	In classroom 111 Left	FT-82016-002968-A	< 1	FT-82016-002968-B	< 1
14	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002972	8/21/2016	1	Cooler	In hallway across from room 131	FT-82016-002972-A	< 1	FT-82016-002972-B	< 1
15	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002978	8/21/2016	2	Cooler	In hallway adjacent to room 210	FT-82016-002978-A	< 1	FT-82016-002978-B	< 1
16	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002979	8/21/2016	2	Cooler	In hallway across from room 223	FT-82016-002979-A	< 1	FT-82016-002979-B	< 1
17	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002980	8/21/2016	2	Cooler	In hallway adjacent to room 216	FT-82016-002980-A	< 1	FT-82016-002980-B	< 1
18	BUNKER HILL EDUCATIONAL CAMPUS	WS- 002981	8/21/2016	2	Cooler	In hallway adjacent to room 203	FT-82016-002981-A	< 1	FT-82016-002981-B	< 1
19	BUNKER HILL EDUCATIONAL CAMPUS	WS- 003000	8/21/2016	2	Cooler	In hallway adjacent to room 204	FT-82016-003000-A	< 1	FT-82016-003000-B	< 1