



BUNKER HILL EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BUNKER HILL	WS- 002971	12/11/2016	1	Break Room	In staff lounge adjacent to room 112	FT-102016-002971-A	< 1	FT-102016-002971-B	< 1
2	BUNKER HILL	WS- 002958	12/11/2016	1	Combo Faucet	In classroom 106 Right	FT-122016-002958-A	< 1	FT-122016-002958-B	< 1
3	BUNKER HILL	WS- 002944	12/11/2016	1	Bathroom	In classroom 106 in bathroom	FT-122016-002944-A	< 1	FT-122016-002944-B	< 1
4	BUNKER HILL	WS- 002952	12/11/2016	1	Combo Faucet	In classroom 103 Right	FT-122016-002952-A	< 1	FT-122016-002952-B	< 1
5	BUNKER HILL	WS- 002955	12/11/2016	1	Combo Faucet	In classroom 105 Right	FT-122016-002955-A	< 1	FT-122016-002955-B	< 1
6	BUNKER HILL	WS- 002943	12/11/2016	1	Bathroom	In classroom 105 in bathroom	FT-122016-002943-A	< 1	FT-122016-002943-B	< 1
7	BUNKER HILL	WS- 002942	12/11/2016	1	Bathroom	In classroom 103 in bathroom	FT-122016-002942-A	< 1	FT-122016-002942-B	< 1
8	BUNKER HILL	WS- 002948	12/11/2016	1	Bathroom	In classroom 111 in bathroom	FT-122016-002948-A	< 1	FT-122016-002948-B	< 1
9	BUNKER HILL	WS- 002945	12/11/2016	1	Bathroom	In classroom 108 in bathroom	FT-112016-002945-A	1	FT-112016-002945-B	< 1
10	BUNKER HILL	WS- 002946	12/11/2016	1	Bathroom	In classroom 109 in bathroom	FT-112016-002946-A	< 1	FT-112016-002946-B	< 1
11	BUNKER HILL	WS- 002969	12/11/2016	1	Combo Faucet	In classroom 111 Right	FT-112016-002969-A	< 1	FT-112016-002969-B	< 1
12	BUNKER HILL	WS- 002966	12/11/2016	1	Combo Faucet	In classroom 110 Right	FT-112016-002966-A	< 1	FT-112016-002966-B	< 1
13	BUNKER HILL	WS- 002962	12/11/2016	1	Combo Faucet	In classroom 108 Right	FT-112016-002962-A	< 1	FT-112016-002962-B	< 1
14	BUNKER HILL	WS- 002964	12/11/2016	1	Combo Faucet	In classroom 109 Right	FT-112016-002964-A	< 1	FT-112016-002964-B	< 1
15	BUNKER HILL	WS- 002947	12/11/2016	1	Bathroom	In classroom 110 in bathroom	FT-112016-002947-A	< 1	FT-112016-002947-B	< 1