



Bunker Hill ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002942	10/3/2018	10/3/2019	1	Bathroom	In classroom 103 in bathroom	WF-10032018-002942	11/5/2018	FT-FY19-102018-002942-A	< 1	FT-FY19-102018-002942-B	< 1	
WS- 002943	10/3/2018	10/3/2019	1	Bathroom	In classroom 105 in bathroom	WF-10032018-002943	11/5/2018	FT-FY19-102018-002943-A	< 1	FT-FY19-102018-002943-B	< 1	
WS- 002944	10/3/2018	10/3/2019	1	Bathroom	In classroom 106 in bathroom	WF-10032018-002944	11/5/2018	FT-FY19-102018-002944-A	< 1	FT-FY19-102018-002944-B	< 1	
WS- 002945	10/3/2018	10/3/2019	1	Bathroom	In classroom 108 in bathroom	WF-10032018-002945	11/5/2018	FT-FY19-102018-002945-A	< 1	FT-FY19-102018-002945-B	< 1	
WS- 002946	10/3/2018	10/3/2019	1	Bathroom	In classroom 109 in bathroom	WF-10032018-002946	11/5/2018	FT-FY19-102018-002946-A	< 1	FT-FY19-102018-002946-B	< 1	
WS- 002947	10/3/2018	10/3/2019	1	Bathroom	In classroom 110 in bathroom	WF-10032018-002947	11/5/2018	FT-FY19-102018-002947-A	< 1	FT-FY19-102018-002947-B	< 1	
WS- 002948	10/3/2018	10/3/2019	1	Bathroom	In classroom 111 in bathroom	WF-10032018-002948	11/5/2018	FT-FY19-102018-002948-A	< 1	FT-FY19-102018-002948-B	< 1	
WS- 002950	6/7/2018	6/7/2019	Basement	Cooler	In kitchen	WF-06072018-002950	11/5/2018	FT-FY19-102018-002950-A	< 1	FT-FY19-102018-002950-B	< 1	
WS- 002952	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 103	Right	WF-10032018-002952	11/5/2018	FT-FY19-102018-002952-A	< 1	FT-FY19-102018-002952-B	< 1
WS- 002953	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 103	Left	WF-06072018-002953	11/5/2018	FT-FY19-102018-002953-A	< 1	FT-FY19-102018-002953-B	< 1
WS- 002954	6/7/2018	6/7/2019	1	Cooler	In hallway adjacent to room 144	WF-06072018-002954	11/5/2018	FT-FY19-102018-002954-A	< 1	FT-FY19-102018-002954-B	< 1	
WS- 002955	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 105	Right	WF-10032018-002955	11/5/2018	FT-FY19-102018-002955-A	1.1	FT-FY19-102018-002955-B	< 1
WS- 002956	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 105	Left	WF-06072018-002956	11/5/2018	FT-FY19-102018-002956-A	< 1	FT-FY19-102018-002956-B	< 1
WS- 002957	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 106	Left	WF-06072018-002957	11/5/2018	FT-FY19-102018-002957-A	< 1	FT-FY19-102018-002957-B	< 1
WS- 002958	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 106	Right	WF-10032018-002958	11/5/2018	FT-FY19-102018-002958-A	< 1	FT-FY19-102018-002958-B	< 1
WS- 002959	6/7/2018	6/7/2019	1	Cooler	In lobby adjacent to auditorium	WF-06072018-002959	11/5/2018	FT-FY19-102018-002959-A	< 1	FT-FY19-102018-002959-B	< 1	
WS- 002960	6/7/2018	6/7/2019	1	Cooler	In health suite	WF-06072018-002960	11/5/2018	FT-FY19-102018-002960-A	< 1	FT-FY19-102018-002960-B	< 1	
WS- 002961	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 108	Left	WF-06072018-002961	11/5/2018	FT-FY19-102018-002961-A	< 1	FT-FY19-102018-002961-B	< 1
WS- 002962	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 108	Right	WF-10032018-002962	11/5/2018	FT-FY19-102018-002962-A	< 1	FT-FY19-102018-002962-B	< 1
WS- 002963	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 109	Left	WF-06072018-002963	11/5/2018	FT-FY19-102018-002963-A	< 1	FT-FY19-102018-002963-B	< 1
WS- 002964	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 109	Right	WF-10032018-002964	11/5/2018	FT-FY19-102018-002964-A	< 1	FT-FY19-102018-002964-B	< 1
WS- 002965	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 110	Left	WF-06072018-002965	11/5/2018	FT-FY19-102018-002965-A	< 1	FT-FY19-102018-002965-B	< 1
WS- 002966	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 110	Right	WF-10032018-002966	11/5/2018	FT-FY19-102018-002966-A	< 1	FT-FY19-102018-002966-B	< 1
WS- 002967	6/7/2018	6/7/2019	1	Cooler	In hallway adjacent to room 110	WF-06072018-002967	11/5/2018	FT-FY19-102018-002967-A	< 1	FT-FY19-102018-002967-B	< 1	
WS- 002968	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 111	Left	WF-06072018-002968	11/5/2018	FT-FY19-102018-002968-A	< 1	FT-FY19-102018-002968-B	< 1
WS- 002969	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 111	Right	WF-10032018-002969	11/5/2018	FT-FY19-102018-002969-A	< 1	FT-FY19-102018-002969-B	< 1
WS- 002971	6/7/2018	6/7/2019	1	Break Room	In staff lounge adjacent to room 112	WF-06072018-002971	11/5/2018	FT-FY19-102018-002971-A	< 1	FT-FY19-102018-002971-B	< 1	
WS- 002972	6/7/2018	6/7/2019	1	Cooler	In hallway across from room 131	WF-06072018-002972	11/5/2018	FT-FY19-102018-002972-A	< 1	FT-FY19-102018-002972-B	< 1	
WS- 002978	6/7/2018	6/7/2019	2	Cooler	In hallway adjacent to room 214	WF-06072018-002978	11/5/2018	FT-FY19-102018-002978-A	< 1	FT-FY19-102018-002978-B	< 1	
WS- 002979	6/7/2018	6/7/2019	2	Cooler	In hallway adjacent to room 212	WF-06072018-002979	11/5/2018	FT-FY19-102018-002979-A	< 1	FT-FY19-102018-002979-B	< 1	
WS- 002980	6/7/2018	6/7/2019	2	Cooler	In hallway adjacent to boys restroom	WF-06072018-002980	11/5/2018	FT-FY19-102018-002980-A	< 1	FT-FY19-102018-002980-B	< 1	
WS- 002981	6/7/2018	6/7/2019	2	Cooler	In hallway adjacent to room 203	WF-06072018-002981	11/5/2018	FT-FY19-102018-002981-A	< 1	FT-FY19-102018-002981-B	< 1	
WS- 002998	6/7/2018	6/7/2019	1	Combo Fountain	In classroom 104	WF-06072018-002998	11/5/2018	FT-FY19-102018-002998-A	< 1	FT-FY19-102018-002998-B	< 1	

WS- 002999	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 104	WF-10032018-002999	11/5/2018	FT-FY19-102018-002999-A	< 1	FT-FY19-102018-002999-B	< 1
------------	-----------	-----------	---	--------------	------------------	--------------------	-----------	-------------------------	-----	-------------------------	-----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 002951	Basement	Food Prep Sink	In kitchen	11/5/2018	FT-FY19-102018-002951-A	< 1	FT-FY19-102018-002951-B	< 1		