



BURDICK LEAD WATER TEST RESULTS



| | Building Location: Building Name | RECORD ID | Date Analyzed | Floor | Device Type | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) |
|----|----------------------------------|------------|---------------|-------|----------------|---|----------------------|--------------------------------|----------------------|--------------------------------|
| 1 | BURDICK | WS- 008541 | 8/19/2016 | 1 | Food Prep Sink | In kitchen Left | FT-72016-008541-A | < 1 | FT-72016-008541-B | < 1 |
| 2 | BURDICK | WS- 008542 | 8/19/2016 | 1 | Food Prep Sink | In kitchen Mid | FT-82016-008542-A | < 1 | FT-82016-008542-B | < 1 |
| 3 | BURDICK | WS- 008545 | 8/19/2016 | 1 | Cooler | In hallway adjacent to 104 High Left | FT-82016-008545-A | < 1 | FT-82016-008545-B | < 1 |
| 4 | BURDICK | WS- 008546 | 8/19/2016 | 1 | Cooler | In hallway adjacent to 105 Low Right | FT-82016-008546-A | < 1 | FT-82016-008546-B | < 1 |
| 5 | BURDICK | WS- 008548 | 8/19/2016 | 1 | Health Suite | In restroom in health suite 116 | FT-82016-008548-A | < 1 | FT-82016-008548-B | < 1 |
| 6 | BURDICK | WS- 008549 | 8/19/2016 | 2 | Cooler | In hallway adjacent to room 219 High Left | FT-82016-008549-A | < 1 | FT-82016-008549-B | < 1 |
| 7 | BURDICK | WS- 008550 | 8/19/2016 | 2 | Cooler | In hallway adjacent to room 219 Low Right | FT-82016-008550-A | < 1 | FT-82016-008550-B | < 1 |
| 8 | BURDICK | WS- 008553 | 8/19/2016 | 3 | Cooler | In hallway adjacent to room 310 High Left | FT-82016-008553-A | < 1 | FT-82016-008553-B | < 1 |
| 9 | BURDICK | WS- 008554 | 8/19/2016 | 3 | Cooler | In hallway adjacent to room 310 Low Right | FT-82016-008554-A | < 1 | FT-82016-008554-B | < 1 |
| 10 | BURDICK | WS- 008559 | 8/19/2016 | 1 | Cooler | Annex, in hallway adjacent to room 012 | FT-82016-008559-A | < 1 | FT-82016-008559-B | < 1 |
| 11 | BURDICK | WS- 008591 | 8/19/2016 | 1 | Cooler | Annex, in classroom 007 | FT-82016-008591-A | < 1 | FT-82016-008591-B | < 1 |