



Burroughs Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003686	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to classroom 8	WF-05122020-003686	2/24/2021	FT-FY21-022021-003686-A	<1	FT-FY21-022021-003686-B	<1
WS-003687	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to classroom 9A	WF-05122020-003687	2/24/2021	FT-FY21-022021-003687-A	<1	FT-FY21-022021-003687-B	<1
WS-003688	2/8/2021	2/8/2022	1	Food Prep Sink	In kitchen adjacent to office	WF-02082021-003688	2/24/2021	FT-FY21-022021-003688-A	<1	FT-FY21-022021-003688-B	<1
WS-008623	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to kitchen High Left	WF-05122020-008623	2/24/2021	FT-FY21-022021-008623-A	<1	FT-FY21-022021-008623-B	<1
WS-008624	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to kitchen Low Right	WF-05122020-008624	2/24/2021	FT-FY21-022021-008624-A	<1	FT-FY21-022021-008624-B	<1
WS-008625	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 34	WF-09232020-008625	2/24/2021	FT-FY21-022021-008625-A	<1	FT-FY21-022021-008625-B	<1
WS-008626	5/12/2020	5/12/2021	1	Combo Fountain	In classroom 34	WF-05122020-008626	2/24/2021	FT-FY21-022021-008626-A	<1	FT-FY21-022021-008626-B	<1
WS-008628	9/23/2020	9/23/2021	1	Classroom Faucet	In classroom 35	WF-09232020-008628	2/24/2021	FT-FY21-022021-008628-A	2.6	FT-FY21-022021-008628-B	<1
WS-008631	9/23/2020	9/23/2021	1	Classroom Faucet	In classroom 25	WF-09232020-008631	2/24/2021	FT-FY21-022021-008631-A	<1	FT-FY21-022021-008631-B	<1
WS-008632	5/12/2020	5/12/2021	1	Cooler	In hallway across from classroom 14	WF-05122020-008632	2/24/2021	FT-FY21-022021-008632-A	<1	FT-FY21-022021-008632-B	<1
WS-008633	5/12/2020	5/12/2021	1	Cooler	In hallway across from classroom 3	WF-05122020-008633	2/24/2021	FT-FY21-022021-008633-A	<1	FT-FY21-022021-008633-B	<1
WS-008634	5/12/2020	5/12/2021	Ground Floor	Cooler	In classroom 18	WF-05122020-008634	2/24/2021	FT-FY21-022021-008634-A	<1	FT-FY21-022021-008634-B	<1
WS-008635	5/12/2020	5/12/2021	Ground Floor	Cooler	In classroom 19	WF-05122020-008635	2/24/2021	FT-FY21-022021-008635-A	<1	FT-FY21-022021-008635-B	<1
WS-008636	5/12/2020	5/12/2021	Ground Floor	Cooler	In classroom 20	WF-05122020-008636	2/24/2021	FT-FY21-022021-008636-A	<1	FT-FY21-022021-008636-B	<1
WS-008637	5/12/2020	5/12/2021	Ground Floor	Cooler	In classroom 21	WF-05122020-008637	2/24/2021	FT-FY21-022021-008637-A	<1	FT-FY21-022021-008637-B	<1
WS-008638	5/12/2020	5/12/2021	Ground Floor	Cooler	In classroom 22	WF-05122020-008638	2/24/2021	FT-FY21-022021-008638-A	<1	FT-FY21-022021-008638-B	<1
WS-008639	5/12/2020	5/12/2021	1	Health Suite	In health suite	WF-05122020-008639	2/24/2021	FT-FY21-022021-008639-A	<1	FT-FY21-022021-008639-B	<1
WS-008824	9/23/2020	9/23/2021	Ground Floor	Classroom Faucet	In classroom 19	WF-09232020-008824	2/24/2021	FT-FY21-022021-008824-A	<1	FT-FY21-022021-008824-B	<1
WS-008825	9/23/2020	9/23/2021	Ground Floor	Classroom Faucet	In classroom 18	WF-09232020-008825	2/24/2021	FT-FY21-022021-008825-A	<1	FT-FY21-022021-008825-B	<1
WS-008826	9/23/2020	9/23/2021	Ground Floor	Classroom Faucet	In classroom 20	WF-09232020-008826	2/24/2021	FT-FY21-022021-008826-A	<1	FT-FY21-022021-008826-B	<1
WS-008827	9/23/2020	9/23/2021	Ground Floor	Classroom Faucet	In classroom 21	WF-09232020-008827	2/24/2021	FT-FY21-022021-008827-A	<1	FT-FY21-022021-008827-B	<1
WS-008828	9/23/2020	9/23/2021	Ground Floor	Classroom Faucet	In classroom 22	WF-09232020-008828	2/24/2021	FT-FY21-022021-008828-A	<1	FT-FY21-022021-008828-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003688	2/8/2021	2/8/2022	1	Food Prep Sink	In kitchen adjacent to office	WF-02082021-003688	2/24/2021	FT-FY21-022021-003688-A	<1	FT-FY21-022021-003688-B	<1