



# Burroughs ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003684	5/23/2019	5/23/2020	Ground Floor	Cooler	In hallway adjacent to boys restroom	WF-05232019-003684	12/3/2019	FT-FY20-112019-003684-A	<1	FT-FY20-112019-003684-B	<1
WS- 003685	5/23/2019	5/23/2020	Ground Floor	Cooler	In hallway adjacent to classroom 20	WF-05232019-003685	12/3/2019	FT-FY20-112019-003685-A	<1	FT-FY20-112019-003685-B	<1
WS- 003686	5/23/2019	5/23/2020	1	Cooler	In hallway adjacent to classroom 8	WF-05232019-003686	12/3/2019	FT-FY20-112019-003686-A	<1	FT-FY20-112019-003686-B	<1
WS- 003687	5/23/2019	5/23/2020	1	Cooler	In hallway adjacent to classroom 9A	WF-05232019-003687	12/3/2019	FT-FY20-112019-003687-A	<1	FT-FY20-112019-003687-B	<1
WS- 008623	5/23/2019	5/23/2020	1	Cooler	In hallway adjacent to kitchen High Left	WF-05232019-008623	12/3/2019	FT-FY20-112019-008623-A	<1	FT-FY20-112019-008623-B	<1
WS- 008624	5/23/2019	5/23/2020	1	Cooler	In hallway adjacent to kitchen Low Right	WF-05232019-008624	12/3/2019	FT-FY20-112019-008624-A	<1	FT-FY20-112019-008624-B	<1
WS- 008625	10/1/2019	10/1/2020	1	Combo Faucet	In classroom 34	WF-10012019-008625	12/3/2019	FT-FY20-112019-008625-A	<1	FT-FY20-112019-008625-B	<1
WS- 008626	5/23/2019	5/23/2020	1	Combo Fountain	In classroom 34	WF-05232019-008626	12/3/2019	FT-FY20-112019-008626-A	<1	FT-FY20-112019-008626-B	<1
WS- 008628	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 35	WF-10012019-008628	12/3/2019	FT-FY20-112019-008628-A	<1	FT-FY20-112019-008628-B	<1
WS- 008629	5/23/2019	5/23/2020	1	Cooler	In hallway across from classroom 27	WF-05232019-008629	12/3/2019	FT-FY20-112019-008629-A	<1	FT-FY20-112019-008629-B	<1
WS- 008630	5/23/2019	5/23/2020	1	Cooler	In classroom 25	WF-05232019-008630	12/3/2019	FT-FY20-112019-008630-A	<1	FT-FY20-112019-008630-B	<1
WS- 008631	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 25	WF-10012019-008631	12/3/2019	FT-FY20-112019-008631-A	<1	FT-FY20-112019-008631-B	<1
WS- 008632	5/23/2019	5/23/2020	1	Cooler	In hallway across from classroom 14	WF-05232019-008632	12/3/2019	FT-FY20-112019-008632-A	<1	FT-FY20-112019-008632-B	<1
WS- 008633	5/23/2019	5/23/2020	1	Cooler	In hallway across from classroom 3	WF-05232019-008633	12/3/2019	FT-FY20-112019-008633-A	<1	FT-FY20-112019-008633-B	<1
WS- 008634	5/23/2019	5/23/2020	Ground Floor	Cooler	In classroom 18	WF-05232019-008634	12/3/2019	FT-FY20-112019-008634-A	<1	FT-FY20-112019-008634-B	<1
WS- 008635	5/23/2019	5/23/2020	Ground Floor	Cooler	In classroom 19	WF-05232019-008635	12/3/2019	FT-FY20-112019-008635-A	<1	FT-FY20-112019-008635-B	<1
WS- 008636	5/23/2019	5/23/2020	Ground Floor	Cooler	In classroom 20	WF-05232019-008636	12/3/2019	FT-FY20-112019-008636-A	<1	FT-FY20-112019-008636-B	<1
WS- 008637	5/23/2019	5/23/2020	Ground Floor	Cooler	In classroom 21	WF-05232019-008637	12/3/2019	FT-FY20-112019-008637-A	<1	FT-FY20-112019-008637-B	<1
WS- 008638	5/23/2019	5/23/2020	Ground Floor	Cooler	In classroom 22	WF-05232019-008638	12/3/2019	FT-FY20-112019-008638-A	<1	FT-FY20-112019-008638-B	<1
WS- 008639	5/23/2019	5/23/2020	1	Health Suite	In health suite	WF-05232019-008639	12/3/2019	FT-FY20-112019-008639-A	<1	FT-FY20-112019-008639-B	<1
WS- 008824	10/1/2019	10/1/2020	Ground Floor	Classroom Faucet	In classroom 19	WF-10012019-008824	12/3/2019	FT-FY20-112019-008824-A	<1	FT-FY20-112019-008824-B	<1
WS- 008825	10/1/2019	10/1/2020	Ground Floor	Classroom Faucet	In classroom 18	WF-10012019-008825	12/3/2019	FT-FY20-112019-008825-A	<1	FT-FY20-112019-008825-B	<1
WS- 008826	10/1/2019	10/1/2020	Ground Floor	Classroom Faucet	In classroom 20	WF-10012019-008826	12/3/2019	FT-FY20-112019-008826-A	<1	FT-FY20-112019-008826-B	<1
WS- 008827	10/1/2019	10/1/2020	Ground Floor	Classroom Faucet	In classroom 21	WF-10012019-008827	12/3/2019	FT-FY20-112019-008827-A	<1	FT-FY20-112019-008827-B	<1
WS- 008828	10/1/2019	10/1/2020	Ground Floor	Classroom Faucet	In classroom 22	WF-10012019-008828	12/3/2019	FT-FY20-112019-008828-A	<1	FT-FY20-112019-008828-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003688	7/3/2019	7/3/2020	1	Food Prep Sink	In kitchen adjacent to office	WF-07032019-003688	12/3/2019	FT-FY20-112019-003688-A	<1	FT-FY20-112019-003688-B	<1