



BURROUGHS EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BURROUGHS EDUCATIONAL CAMPUS	WS- 003684	8/17/2016	Ground Floor	Cooler	In hallway adjacent to boys restroom	FT-82016-003684-A	< 1	FT-82016-003684-B	< 1
2	BURROUGHS EDUCATIONAL CAMPUS	WS- 003685	8/17/2016	Ground Floor	Cooler	In hallway adjacent to classroom 20	FT-82016-003685-A	< 1	FT-82016-003685-B	< 1
3	BURROUGHS EDUCATIONAL CAMPUS	WS- 003686	8/17/2016	1	Cooler	In hallway adjacent to classroom of Gloria Brown	FT-82016-003686-A	< 1	FT-82016-003686-B	< 1
4	BURROUGHS EDUCATIONAL CAMPUS	WS- 003687	8/17/2016	1	Cooler	In hallway adjacent to classroom 9A	FT-82016-003687-A	< 1	FT-82016-003687-B	< 1
5	BURROUGHS EDUCATIONAL CAMPUS	WS- 003688	8/17/2016	1	Food Prep Sink	In kitchen adjacent to office	FT-82016-003688-A	< 1	FT-82016-003688-B	< 1
6	BURROUGHS EDUCATIONAL CAMPUS	WS- 008623	8/17/2016	1	Cooler	In hallway adjacent to kitchen High Left	FT-82016-008623-A	< 1	FT-82016-008623-B	< 1
7	BURROUGHS EDUCATIONAL CAMPUS	WS- 008624	8/17/2016	1	Cooler	In hallway adjacent to kitchen Low Right	FT-82016-008624-A	< 1	FT-82016-008624-B	< 1
8	BURROUGHS EDUCATIONAL CAMPUS	WS- 008626	8/17/2016	1	Fountain	In classroom 34	FT-82016-008626-A	< 1	FT-82016-008626-B	< 1
9	BURROUGHS EDUCATIONAL CAMPUS	WS- 008627	8/17/2016	1	Cooler	In classroom 35	FT-82016-008627-A	< 1	FT-82016-008627-B	< 1
10	BURROUGHS EDUCATIONAL CAMPUS	WS- 008629	8/17/2016	1	Cooler	In hallway across from classroom 27	FT-82016-008629-A	< 1	FT-82016-008629-B	< 1
11	BURROUGHS EDUCATIONAL CAMPUS	WS- 008630	8/17/2016	1	Cooler	In classroom 25	FT-82016-008630-A	< 1	FT-82016-008630-B	< 1
12	BURROUGHS EDUCATIONAL CAMPUS	WS- 008632	8/17/2016	1	Cooler	In hallway across from classroom 14	FT-82016-008632-A	< 1	FT-82016-008632-B	< 1
13	BURROUGHS EDUCATIONAL CAMPUS	WS- 008633	8/17/2016	1	Cooler	In hallway across from classroom 3	FT-82016-008633-A	< 1	FT-82016-008633-B	< 1
14	BURROUGHS EDUCATIONAL CAMPUS	WS- 008634	8/17/2016	Ground Floor	Cooler	In classroom 18	FT-82016-008634-A	< 1	FT-82016-008634-B	< 1
15	BURROUGHS EDUCATIONAL CAMPUS	WS- 008635	8/17/2016	Ground Floor	Cooler	In classroom 19	FT-82016-008635-A	< 1	FT-82016-008635-B	< 1
16	BURROUGHS EDUCATIONAL CAMPUS	WS- 008636	8/17/2016	Ground Floor	Cooler	In classroom 20	FT-82016-008636-A	< 1	FT-82016-008636-B	< 1
17	BURROUGHS EDUCATIONAL CAMPUS	WS- 008637	8/17/2016	Ground Floor	Cooler	In classroom 21	FT-82016-008637-A	< 1	FT-82016-008637-B	< 1
18	BURROUGHS EDUCATIONAL CAMPUS	WS- 008638	8/17/2016	Ground Floor	Cooler	In classroom 22	FT-82016-008638-A	< 1	FT-82016-008638-B	< 1
19	BURROUGHS EDUCATIONAL CAMPUS	WS- 008639	8/17/2016	1	Health Suite	In health suite	FT-82016-008639-A	< 1	FT-82016-008639-B	< 1