



BURROUGHS LEAD WATER TEST RESULTS

May 16th, 2016



| Building Location | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|-------------------|-----------------------|-----------------|--------------|--------------|---|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|-----------------|-----------------|
| 1 BURROUGHS EC | 5/10/2016 | WS- 003683 | Utility | Ground Floor | In boys restroom adjacent to classroom 18 (closest tap to main source) | WT-042916-3700- A | 1.1 | WT-042916-3700- B | < 1 | | | | |
| 2 BURROUGHS EC | 5/10/2016 | WS- 003684 | Cooler | Ground Floor | In hallway adjacent to boys restroom | WT-042916-3701- A | 2.3 | WT-042916-3701- B | < 1 | | | | |
| 3 BURROUGHS EC | 5/10/2016 | WS- 003685 | Cooler | Ground Floor | In hallway adjacent to classroom 20 | WT-042916-3702- A | < 1 | WT-042916-3702- B | < 1 | | | | |
| 4 BURROUGHS EC | 5/10/2016 | WS- 003686 | Cooler | 1 | In hallway adjacent to classroom of Gloria Brown | WT-042916-3703- A | < 1 | WT-042916-3703- B | < 1 | | | | |
| 5 BURROUGHS EC | 5/10/2016 | WS- 003687 | Cooler | 1 | In hallway adjacent to classroom 9A | WT-042916-3704- A | < 1 | WT-042916-3704- B | < 1 | | | | |
| 6 BURROUGHS EC | 5/10/2016 | WS- 003688 | Other | 1 | In kitchen (in sink adjacent to office, spray nozzle) | WT-042916-3705- A | < 1 | WT-042916-3705- B | < 1 | | | | |
| 7 BURROUGHS EC | 5/10/2016 | WS- 003689 | Kitchen | 1 | In kitchen adjacent to janitorial closet (second sink clockwise from door) | WT-042916-3706- A | 1.7 | WT-042916-3706- B | < 1 | | | | |
| 8 BURROUGHS EC | 5/10/2016 | WS- 003690 | Other | 1 | In kitchen adjacent to janitorial closet (second spray nozzle clockwise from door) | WT-042916-3707- A | < 1 | WT-042916-3707- B | < 1 | | | | |
| 9 BURROUGHS EC | 5/10/2016 | WS- 008619 | Kitchen | 1 | In kitchen adjacent to janitorial closet (third sink clockwise from door) | WT-042916-8636- A | < 1 | WT-042916-8636- B | < 1 | | | | |
| 10 BURROUGHS EC | 5/10/2016 | WS- 008620 | Kitchen | 1 | In kitchen adjacent to janitorial closet (fourth sink clockwise from door) | WT-042916-8637- A | < 1 | WT-042916-8637- B | < 1 | | | | |
| 11 BURROUGHS EC | 5/10/2016 | WS- 008621 | Other | 1 | In kitchen adjacent to janitorial closet (spray nozzle in first sink clockwise from door) | WT-042916-8638- A | 4.8 | WT-042916-8638- B | < 1 | | | | |
| 12 BURROUGHS EC | 5/10/2016 | WS- 008622 | Kitchen | 1 | In kitchen adjacent to janitorial closet (first sink clockwise from door) | WT-042916-8639- A | 5.8 | WT-042916-8639- B | < 1 | | | | |
| 13 BURROUGHS EC | 5/10/2016 | WS- 008623 | Cooler | 1 | In hallway between cafeteria and restrooms Left High | WT-042916-8640- A | < 1 | WT-042916-8640- B | < 1 | | | | |
| 14 BURROUGHS EC | 5/10/2016 | WS- 008624 | Cooler | 1 | In hallway between cafeteria and restrooms Right Low | WT-042916-8641- A | < 1 | WT-042916-8641- B | < 1 | | | | |
| 15 BURROUGHS EC | 5/10/2016 | WS- 008625 | Classroom | 1 | In classroom 34 | WT-042916-8642- A | 8 | WT-042916-8642- B | < 1 | | | | |
| 16 BURROUGHS EC | 5/10/2016 | WS- 008626 | Fountain | 1 | In classroom 34 | WT-042916-8643- A | < 1 | WT-042916-8643- B | < 1 | | | | |
| 17 BURROUGHS EC | 5/10/2016 | WS- 008627 | Cooler | 1 | In classroom 35 | WT-042916-8644- A | < 1 | WT-042916-8644- B | < 1 | | | | |
| 18 BURROUGHS EC | 5/10/2016 | WS- 008628 | Classroom | 1 | In classroom 35 | WT-042916-8645- A | < 1 | WT-042916-8645- B | < 1 | | | | |
| 19 BURROUGHS EC | 5/10/2016 | WS- 008629 | Cooler | 1 | In hallway across from classroom 27 | WT-042916-8646- A | < 1 | WT-042916-8646- B | < 1 | | | | |
| 20 BURROUGHS EC | 5/10/2016 | WS- 008630 | Cooler | 1 | In classroom 25 | WT-042916-8647- A | < 1 | WT-042916-8647- B | < 1 | | | | |
| 21 BURROUGHS EC | 5/10/2016 | WS- 008631 | Classroom | 1 | In classroom 25 | WT-042916-8648- A | 2.9 | WT-042916-8648- B | < 1 | | | | |
| 22 BURROUGHS EC | 5/10/2016 | WS- 008632 | Cooler | 1 | In hallway across from classroom 14 | WT-042916-8649- A | < 1 | WT-042916-8649- B | < 1 | | | | |
| 23 BURROUGHS EC | 5/10/2016 | WS- 008633 | Cooler | 1 | In hallway across from classroom 3 | WT-042916-8650- A | < 1 | WT-042916-8650- B | < 1 | | | | |
| 24 BURROUGHS EC | 5/10/2016 | WS- 008634 | Cooler | Ground Floor | In classroom 18 | WT-042916-8651- A | < 1 | WT-042916-8651- B | < 1 | | | | |
| 25 BURROUGHS EC | 5/10/2016 | WS- 008635 | Cooler | Ground Floor | In classroom 19 | WT-042916-8652- A | < 1 | WT-042916-8652- B | < 1 | | | | |
| 26 BURROUGHS EC | 5/10/2016 | WS- 008636 | Cooler | Ground Floor | In classroom 20 | WT-042916-8653- A | < 1 | WT-042916-8653- B | < 1 | | | | |
| 27 BURROUGHS EC | 5/10/2016 | WS- 008637 | Cooler | Ground Floor | In classroom 21 | WT-042916-8654- A | < 1 | WT-042916-8654- B | < 1 | | | | |
| 28 BURROUGHS EC | 5/10/2016 | WS- 008638 | Cooler | Ground Floor | In classroom 22 | WT-042916-8655- A | < 1 | WT-042916-8655- B | 3.6 | | | | |
| 29 BURROUGHS EC | 5/10/2016 | WS- 008639 | Health Suite | 1 | In health suite | WT-042916-8656- A | 10.5 | WT-042916-8656- B | 1.4 | | | | |

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.