



Burroughs ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008624	6/20/2017	6/20/2018	1	Cooler	In hallway adjacent to kitchen	Right	Low	WF-62017-008624	11/21/2017	FT-FY18--62017-008624-A	<1	FT-FY18--62017-008624-B	<1
WS- 008625	11/1/2017	11/1/2018	1	Combo Faucet	In classroom 34			WF-112017-008625	11/21/2017	FT-FY18-112017-008625-A	<1	FT-FY18-112017-008625-B	<1
WS- 008626	6/20/2017	6/20/2018	1	Combo Fountain	In classroom 34			WF-62017-008626	11/21/2017	FT-FY18--62017-008626-A	<1	FT-FY18--62017-008626-B	<1
WS- 008627	6/20/2017	6/20/2018	1	Cooler	In classroom 35			WF-62017-008627	11/21/2017	FT-FY18--62017-008627-A	<1	FT-FY18--62017-008627-B	<1
WS- 008630	7/7/2017	7/7/2018	1	Cooler	In classroom 25			WF-72017-008630	11/21/2017	FT-FY18--72017-008630-A	<1	FT-FY18--72017-008630-B	<1
WS- 008824	11/1/2017	11/1/2018	Ground Floor	Classroom Faucet	In classroom 19			WF-112017-008824	11/21/2017	FT-FY18-112017-008824-A	<1	FT-FY18-112017-008824-B	<1
WS- 008825	11/1/2017	11/1/2018	Ground Floor	Classroom Faucet	In classroom 18			WF-112017-008825	11/21/2017	FT-FY18-112017-008825-A	<1	FT-FY18-112017-008825-B	<1
WS- 008826	11/1/2017	11/1/2018	Ground Floor	Classroom Faucet	In classroom 20			WF-112017-008826	11/21/2017	FT-FY18-112017-008826-A	<1	FT-FY18-112017-008826-B	<1
WS- 008828	11/1/2017	11/1/2018	Ground Floor	Classroom Faucet	In classroom 22			WF-112017-008828	11/21/2017	FT-FY18-112017-008828-A	<1	FT-FY18-112017-008828-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003688	1	Food Prep Sink	In kitchen adjacent to office				11/21/2017	FT-FY18-102017-003688-A	2.1	FT-FY18-102017-003688-B	<1