



Burroughs ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003684	5/31/2018	5/31/2019	Ground Floor	Cooler	In hallway adjacent to boys restroom	WF-05312018-003684	12/5/2018	FT-FY19-112018-003684-A	<1	FT-FY19-112018-003684-B	<1
WS-003685	5/31/2018	5/31/2019	Ground Floor	Cooler	In hallway adjacent to classroom 20	WF-05312018-003685	12/5/2018	FT-FY19-112018-003685-A	<1	FT-FY19-112018-003685-B	<1
WS-003686	5/31/2018	5/31/2019	1	Cooler	In hallway adjacent to classroom 8	WF-05312018-003686	12/5/2018	FT-FY19-112018-003686-A	<1	FT-FY19-112018-003686-B	<1
WS-003687	5/31/2018	5/31/2019	1	Cooler	In hallway adjacent to classroom 9A	WF-05312018-003687	12/5/2018	FT-FY19-112018-003687-A	<1	FT-FY19-112018-003687-B	<1
WS-008623	5/31/2018	5/31/2019	1	Cooler	In hallway adjacent to kitchen High Left	WF-05312018-008623	12/5/2018	FT-FY19-112018-008623-A	<1	FT-FY19-112018-008623-B	<1
WS-008624	5/31/2018	5/31/2019	1	Cooler	In hallway adjacent to kitchen Low Right	WF-05312018-008624	12/5/2018	FT-FY19-112018-008624-A	<1	FT-FY19-112018-008624-B	<1
WS-008625	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 34	WF-10092018-008625	12/5/2018	FT-FY19-112018-008625-A	<1	FT-FY19-112018-008625-B	<1
WS-008626	5/31/2018	5/31/2019	1	Combo Fountain	In classroom 34	WF-05312018-008626	12/5/2018	FT-FY19-112018-008626-A	<1	FT-FY19-112018-008626-B	<1
WS-008627	5/31/2018	5/31/2019	1	Cooler	In classroom 35	WF-05312018-008627	12/5/2018	FT-FY19-112018-008627-A	<1	FT-FY19-112018-008627-B	<1
WS-008628	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 35	WF-10092018-008628	12/5/2018	FT-FY19-112018-008628-A	<1	FT-FY19-112018-008628-B	<1
WS-008629	5/31/2018	5/31/2019	1	Cooler	In hallway across from classroom 27	WF-05312018-008629	12/5/2018	FT-FY19-112018-008629-A	<1	FT-FY19-112018-008629-B	<1
WS-008630	5/31/2018	5/31/2019	1	Cooler	In classroom 25	WF-05312018-008630	12/5/2018	FT-FY19-112018-008630-A	<1	FT-FY19-112018-008630-B	<1
WS-008631	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 25	WF-10092018-008631	12/5/2018	FT-FY19-112018-008631-A	<1	FT-FY19-112018-008631-B	<1
WS-008632	5/31/2018	5/31/2019	1	Cooler	In hallway across from classroom 14	WF-05312018-008632	12/5/2018	FT-FY19-112018-008632-A	<1	FT-FY19-112018-008632-B	<1
WS-008633	5/31/2018	5/31/2019	1	Cooler	In hallway across from classroom 3	WF-05312018-008633	12/5/2018	FT-FY19-112018-008633-A	<1	FT-FY19-112018-008633-B	<1
WS-008634	5/31/2018	5/31/2019	Ground Floor	Cooler	In classroom 18	WF-05312018-008634	12/5/2018	FT-FY19-112018-008634-A	<1	FT-FY19-112018-008634-B	<1
WS-008635	5/31/2018	5/31/2019	Ground Floor	Cooler	In classroom 19	WF-05312018-008635	12/5/2018	FT-FY19-112018-008635-A	<1	FT-FY19-112018-008635-B	<1
WS-008636	5/31/2018	5/31/2019	Ground Floor	Cooler	In classroom 20	WF-05312018-008636	12/5/2018	FT-FY19-112018-008636-A	<1	FT-FY19-112018-008636-B	<1
WS-008637	5/31/2018	5/31/2019	Ground Floor	Cooler	In classroom 21	WF-05312018-008637	12/5/2018	FT-FY19-112018-008637-A	<1	FT-FY19-112018-008637-B	<1
WS-008638	5/31/2018	5/31/2019	Ground Floor	Cooler	In classroom 22	WF-05312018-008638	12/5/2018	FT-FY19-112018-008638-A	<1	FT-FY19-112018-008638-B	<1
WS-008639	5/31/2018	5/31/2019	1	Health Suite	In health suite	WF-05312018-008639	12/5/2018	FT-FY19-112018-008639-A	<1	FT-FY19-112018-008639-B	<1
WS-008824	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom 19	WF-10092018-008824	12/5/2018	FT-FY19-112018-008824-A	<1	FT-FY19-112018-008824-B	<1
WS-008825	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom 18	WF-10092018-008825	12/5/2018	FT-FY19-112018-008825-A	<1	FT-FY19-112018-008825-B	<1
WS-008826	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom 20	WF-10092018-008826	12/5/2018	FT-FY19-112018-008826-A	<1	FT-FY19-112018-008826-B	<1
WS-008827	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom 21	WF-10092018-008827	12/5/2018	FT-FY19-112018-008827-A	<1	FT-FY19-112018-008827-B	<1
WS-008828	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom 22	WF-10092018-008828	12/5/2018	FT-FY19-112018-008828-A	<1	FT-FY19-112018-008828-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003688	1	Food Prep Sink	In kitchen adjacent to office	12/5/2018	FT-FY19-112018-003688-A	1.8	FT-FY19-112018-003688-B	<1