



# Burrville ES Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009207	2/19/2025	2/19/2026	1	Bottle Filler	In hallway adjacent to room 111	WF-02192025-009207	12/23/2025	FT-FY26-12112025-009207-A	<2	FT-FY26-12112025-009207-B	<2	
WS- 009210	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 108	WF-02192025-009210	12/23/2025	FT-FY26-12112025-009210-A	<2	FT-FY26-12112025-009210-B	<2	
WS- 009211	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 108	WF-07282025-009211	12/23/2025	FT-FY26-12112025-009211-A	<2	FT-FY26-12112025-009211-B	<2	
WS- 009212	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 114	WF-02192025-009212	12/23/2025	FT-FY26-12112025-009212-A	<2	FT-FY26-12112025-009212-B	<2	
WS- 009213	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 114	WF-07282025-009213	12/23/2025	FT-FY26-12112025-009213-A	<2	FT-FY26-12112025-009213-B	<2	
WS- 009214	2/19/2025	2/19/2026	1	Cooler	In hallway adjacent to room 111	High Left	WF-02192025-009214	12/23/2025	FT-FY26-12112025-009214-A	<2	FT-FY26-12112025-009214-B	<2
WS- 009215	2/19/2025	2/19/2026	1	Cooler	In hallway adjacent to room 111	Low Right	WF-02192025-009215	12/23/2025	FT-FY26-12112025-009215-A	<2	FT-FY26-12112025-009215-B	<2
WS- 009216	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 113	WF-02192025-009216	12/23/2025	FT-FY26-12112025-009216-A	<2	FT-FY26-12112025-009216-B	<2	
WS- 009217	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 113	WF-07282025-009217	12/23/2025	FT-FY26-12112025-009217-A	<2	FT-FY26-12112025-009217-B	<2	
WS- 009218	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 115	WF-02192025-009218	12/23/2025	FT-FY26-12112025-009218-A	<2	FT-FY26-12112025-009218-B	<2	
WS- 009219	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 115	WF-07282025-009219	12/23/2025	FT-FY26-12112025-009219-A	<2	FT-FY26-12112025-009219-B	<2	
WS- 009220	2/19/2025	2/19/2026	1	Combo Fountain	In Pre-K classroom 110	WF-02192025-009220	12/23/2025	FT-FY26-12112025-009220-A	<2	FT-FY26-12112025-009220-B	<2	
WS- 009221	7/28/2025	7/28/2026	1	Combo Faucet	In Pre-K classroom 110	WF-07282025-009221	12/23/2025	FT-FY26-12112025-009221-A	<2	FT-FY26-12112025-009221-B	<2	
WS- 009224	2/19/2025	2/19/2026	1	Cooler	In health suite	WF-02192025-009224	12/23/2025	FT-FY26-12112025-009224-A	<2	FT-FY26-12112025-009224-B	<2	
WS- 009228	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to gym	High Right	WF-02192025-009228	12/23/2025	FT-FY26-12112025-009228-A	<2	FT-FY26-12112025-009228-B	<2
WS- 009229	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to gym	Low Left	WF-02192025-009229	12/23/2025	FT-FY26-12112025-009229-A	<2	FT-FY26-12112025-009229-B	<2
WS- 009230	2/19/2025	2/19/2026	2	Cooler	In gym adjacent to kitchen	WF-02192025-009230	12/23/2025	FT-FY26-12112025-009230-A	<2	FT-FY26-12112025-009230-B	<2	
WS- 009236	2/19/2025	2/19/2026	2	Break Room	In staff lounge	WF-02192025-009236	12/23/2025	FT-FY26-12112025-009236-A	<2	FT-FY26-12112025-009236-B	<2	
WS- 009237	2/19/2025	2/19/2026	2	Cooler	In hallway near elevator	High Right	WF-02192025-009237	12/23/2025	FT-FY26-12112025-009237-A	<2	FT-FY26-12112025-009237-B	<2
WS- 009238	2/19/2025	2/19/2026	2	Cooler	In hallway near elevator	Low Left	WF-02192025-009238	12/23/2025	FT-FY26-12112025-009238-A	<2	FT-FY26-12112025-009238-B	<2
WS- 009239	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to media center	High Right	WF-02192025-009239	12/23/2025	FT-FY26-12112025-009239-A	<2	FT-FY26-12112025-009239-B	<2
WS- 009240	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to media center	Low Left	WF-02192025-009240	12/23/2025	FT-FY26-12112025-009240-A	<2	FT-FY26-12112025-009240-B	<2
WS- 009241	2/19/2025	2/19/2026	2	Cooler	In hallway across from music room 242	WF-02192025-009241	12/23/2025	FT-FY26-12112025-009241-A	<2	FT-FY26-12112025-009241-B	<2	
WS- 009242	2/19/2025	2/19/2026	2	Cooler	In music room 242	WF-02192025-009242	12/23/2025	FT-FY26-12112025-009242-A	<2	FT-FY26-12112025-009242-B	<2	
WS- 009243	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 228	WF-02192025-009243	12/23/2025	FT-FY26-12112025-009243-A	<2	FT-FY26-12112025-009243-B	<2	
WS- 009244	7/28/2025	7/28/2026	2	Combo Faucet	In classroom 228	WF-07282025-009244	12/23/2025	FT-FY26-12112025-009244-A	<2	FT-FY26-12112025-009244-B	<2	
WS- 009245	2/19/2025	2/19/2026	2	Cooler	In hallway across from room 228	High Left	WF-02192025-009245	12/23/2025	FT-FY26-12112025-009245-A	<2	FT-FY26-12112025-009245-B	<2
WS- 009246	2/19/2025	2/19/2026	2	Cooler	In hallway across from room 228	Low Right	WF-02192025-009246	12/23/2025	FT-FY26-12112025-009246-A	<2	FT-FY26-12112025-009246-B	<2
WS- 009247	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 227	WF-02192025-009247	12/23/2025	FT-FY26-12112025-009247-A	<2	FT-FY26-12112025-009247-B	<2	
WS- 009248	7/28/2025	7/28/2026	2	Combo Faucet	In classroom 227	WF-07282025-009248	12/23/2025	FT-FY26-12112025-009248-A	<2	FT-FY26-12112025-009248-B	<2	
WS- 009249	2/19/2025	2/19/2026	2	Combo Fountain	In art room 223	Left	WF-02192025-009249	12/23/2025	FT-FY26-12112025-009249-A	<2	FT-FY26-12112025-009249-B	<2
WS- 009251	2/19/2025	2/19/2026	2	Combo Fountain	In art room 223	Right	WF-02192025-009251	12/23/2025	FT-FY26-12112025-009251-A	<2	FT-FY26-12112025-009251-B	<2
WS- 009253	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 224	WF-02192025-009253	12/23/2025	FT-FY26-12112025-009253-A	<2	FT-FY26-12112025-009253-B	<2	
WS- 009254	7/28/2025	7/28/2026	2	Combo Faucet	In classroom 224	WF-07282025-009254	12/23/2025	FT-FY26-12112025-009254-A	<2	FT-FY26-12112025-009254-B	<2	

WS- 009255	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 221	WF-02192025-009255	12/23/2025	FT-FY26-12112025-009255-A	<2	FT-FY26-12112025-009255-B	<2
WS- 009256	7/28/2025	7/28/2026	2	Combo Faucet	In classroom 221	WF-07282025-009256	12/23/2025	FT-FY26-12112025-009256-A	<2	FT-FY26-12112025-009256-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009232	12/2/2025	12/2/2026	2	Food Prep Sink	In kitchen Right	WF-12022025-009232	12/23/2025	FT-FY26-12112025-009232-A	<2	FT-FY26-12112025-009232-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.