



# Burrville Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009209	3/24/2020	3/24/2021	1	Cooler	In hallway adjacent to boys' restroom near stairwell 1	WF-03242020-009209	1/16/2021	FT-FY21-012021-009209-A	<1	FT-FY21-012021-009209-B	<1	
WS-009210	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 108	WF-03242020-009210	1/16/2021	FT-FY21-012021-009210-A	<1	FT-FY21-012021-009210-B	<1	
WS-009211	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 108	WF-09012020-009211	1/16/2021	FT-FY21-012021-009211-A	<1	FT-FY21-012021-009211-B	<1	
WS-009212	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 114	WF-03242020-009212	1/16/2021	FT-FY21-012021-009212-A	<1	FT-FY21-012021-009212-B	<1	
WS-009213	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 114	WF-09012020-009213	1/16/2021	FT-FY21-012021-009213-A	<1	FT-FY21-012021-009213-B	<1	
WS-009214	3/24/2020	3/24/2021	1	Cooler	In hallway adjacent to room 112	High Left	WF-03242020-009214	1/16/2021	FT-FY21-012021-009214-A	<1	FT-FY21-012021-009214-B	<1
WS-009215	3/24/2020	3/24/2021	1	Cooler	In hallway adjacent to room 112	Low Right	WF-03242020-009215	1/16/2021	FT-FY21-012021-009215-A	<1	FT-FY21-012021-009215-B	<1
WS-009216	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 113	WF-03242020-009216	1/16/2021	FT-FY21-012021-009216-A	<1	FT-FY21-012021-009216-B	<1	
WS-009217	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 113	WF-09012020-009217	1/16/2021	FT-FY21-012021-009217-A	<1	FT-FY21-012021-009217-B	<1	
WS-009218	3/24/2020	3/24/2021	1	Combo Fountain	In classroom 115	WF-03242020-009218	1/16/2021	FT-FY21-012021-009218-A	<1	FT-FY21-012021-009218-B	<1	
WS-009219	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 115	WF-09012020-009219	1/16/2021	FT-FY21-012021-009219-A	<1	FT-FY21-012021-009219-B	<1	
WS-009220	3/24/2020	3/24/2021	1	Combo Fountain	In Pre-K classroom 110	WF-03242020-009220	1/16/2021	FT-FY21-012021-009220-A	<1	FT-FY21-012021-009220-B	<1	
WS-009221	9/1/2020	9/1/2021	1	Combo Faucet	In Pre-K classroom 110	WF-09012020-009221	1/16/2021	FT-FY21-012021-009221-A	<1	FT-FY21-012021-009221-B	<1	
WS-009222	3/24/2020	3/24/2021	1	Combo Fountain	In Pre-K classroom 111	WF-03242020-009222	1/16/2021	FT-FY21-012021-009222-A	<1	FT-FY21-012021-009222-B	<1	
WS-009223	9/1/2020	9/1/2021	1	Combo Faucet	In Pre-K classroom 111	WF-09012020-009223	1/16/2021	FT-FY21-012021-009223-A	<1	FT-FY21-012021-009223-B	<1	
WS-009224	3/24/2020	3/24/2021	1	Cooler	In health suite	WF-03242020-009224	1/16/2021	FT-FY21-012021-009224-A	<1	FT-FY21-012021-009224-B	<1	
WS-009226	3/24/2020	3/24/2021	2	Cooler	In hallway across from custodial closet	High Right	WF-03242020-009226	1/16/2021	FT-FY21-012021-009226-A	<1	FT-FY21-012021-009226-B	<1
WS-009227	3/24/2020	3/24/2021	2	Cooler	In hallway across from custodial closet	Low Left	WF-03242020-009227	1/16/2021	FT-FY21-012021-009227-A	<1	FT-FY21-012021-009227-B	<1
WS-009228	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to gym	High Right	WF-03242020-009228	1/16/2021	FT-FY21-012021-009228-A	<1	FT-FY21-012021-009228-B	<1
WS-009229	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to gym	Low Left	WF-03242020-009229	1/16/2021	FT-FY21-012021-009229-A	<1	FT-FY21-012021-009229-B	<1
WS-009230	3/24/2020	3/24/2021	2	Cooler	In gym adjacent to kitchen	WF-03242020-009230	1/16/2021	FT-FY21-012021-009230-A	<1	FT-FY21-012021-009230-B	<1	
WS-009233	3/24/2020	3/24/2021	2	Cooler	In girls' locker room in gym	WF-03242020-009233	1/16/2021	FT-FY21-012021-009233-A	<1	FT-FY21-012021-009233-B	<1	
WS-009234	3/24/2020	3/24/2021	2	Cooler	In boys' locker room in gym	WF-03242020-009234	1/16/2021	FT-FY21-012021-009234-A	<1	FT-FY21-012021-009234-B	<1	
WS-009235	3/24/2020	3/24/2021	2	Cooler	In staff lounge	WF-03242020-009235	1/16/2021	FT-FY21-012021-009235-A	<1	FT-FY21-012021-009235-B	<1	
WS-009236	3/24/2020	3/24/2021	2	Break Room	In staff lounge	WF-03242020-009236	1/16/2021	FT-FY21-012021-009236-A	<1	FT-FY21-012021-009236-B	<1	
WS-009237	3/24/2020	3/24/2021	2	Cooler	In hallway near elevator	High Right	WF-03242020-009237	1/16/2021	FT-FY21-012021-009237-A	<1	FT-FY21-012021-009237-B	<1
WS-009238	3/24/2020	3/24/2021	2	Cooler	In hallway near elevator	Low Left	WF-03242020-009238	1/16/2021	FT-FY21-012021-009238-A	<1	FT-FY21-012021-009238-B	<1
WS-009239	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to media center	High Right	WF-03242020-009239	1/16/2021	FT-FY21-012021-009239-A	<1	FT-FY21-012021-009239-B	<1
WS-009240	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to media center	Low Left	WF-03242020-009240	1/16/2021	FT-FY21-012021-009240-A	<1	FT-FY21-012021-009240-B	<1
WS-009241	3/24/2020	3/24/2021	2	Cooler	In hallway across from room 241	WF-03242020-009241	1/16/2021	FT-FY21-012021-009241-A	<1	FT-FY21-012021-009241-B	<1	
WS-009243	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 228	WF-03242020-009243	1/16/2021	FT-FY21-012021-009243-A	<1	FT-FY21-012021-009243-B	<1	
WS-009244	9/1/2020	9/1/2021	2	Combo Faucet	In classroom 228	WF-09012020-009244	1/16/2021	FT-FY21-012021-009244-A	<1	FT-FY21-012021-009244-B	<1	

WS- 009245	3/24/2020	3/24/2021	2	Cooler	In hallway across from room 228	High Left	WF-03242020-009245	1/16/2021	FT-FY21-012021-009245-A	1.3	FT-FY21-012021-009245-B	<1
WS- 009246	3/24/2020	3/24/2021	2	Cooler	In hallway across from room 228	Low Right	WF-03242020-009246	1/16/2021	FT-FY21-012021-009246-A	<1	FT-FY21-012021-009246-B	<1
WS- 009247	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 227		WF-03242020-009247	1/16/2021	FT-FY21-012021-009247-A	<1	FT-FY21-012021-009247-B	<1
WS- 009248	9/1/2020	9/1/2021	2	Combo Faucet	In classroom 227		WF-09012020-009248	1/16/2021	FT-FY21-012021-009248-A	2.1	FT-FY21-012021-009248-B	<1
WS- 009249	3/24/2020	3/24/2021	2	Combo Fountain	In art room 223	Left	WF-03242020-009249	1/16/2021	FT-FY21-012021-009249-A	<1	FT-FY21-012021-009249-B	<1
WS- 009251	3/24/2020	3/24/2021	2	Combo Faucet	In art room 223	Right	WF-03242020-009251	1/16/2021	FT-FY21-012021-009251-A	<1	FT-FY21-012021-009251-B	<1
WS- 009253	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 224		WF-03242020-009253	1/16/2021	FT-FY21-012021-009253-A	<1	FT-FY21-012021-009253-B	<1
WS- 009254	9/1/2020	9/1/2021	2	Combo Faucet	In classroom 224		WF-09012020-009254	1/16/2021	FT-FY21-012021-009254-A	1.1	FT-FY21-012021-009254-B	<1
WS- 009255	3/24/2020	3/24/2021	2	Combo Fountain	In classroom 221		WF-03242020-009255	1/16/2021	FT-FY21-012021-009255-A	1.1	FT-FY21-012021-009255-B	<1
WS- 009256	9/1/2020	9/1/2021	2	Combo Faucet	In classroom 221		WF-09012020-009256	1/16/2021	FT-FY21-012021-009256-A	<1	FT-FY21-012021-009256-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009232	2/24/2020	2/24/2021	2	Food Prep Sink	In kitchen	Right	WF-02242020-009232	1/16/2021	FT-FY21-012021-009232-A	<1	FT-FY21-012021-009232-B	<1