



# Burrville Elementary School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009209	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to boys' restroom near stairwell 1	WF-03162021-009209	1/26/2022	FT-FY22-01042022-009209-A	<1	FT-FY22-01042022-009209-B	<1	
WS-009210	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 108	WF-03162021-009210	1/26/2022	FT-FY22-01042022-009210-A	<1	FT-FY22-01042022-009210-B	<1	
WS-009211	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 108	WF-08252021-009211	1/26/2022	FT-FY22-01042022-009211-A	<1	FT-FY22-01042022-009211-B	<1	
WS-009212	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 114	WF-03162021-009212	1/26/2022	FT-FY22-01042022-009212-A	<1	FT-FY22-01042022-009212-B	<1	
WS-009213	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 114	WF-08252021-009213	1/26/2022	FT-FY22-01042022-009213-A	<1	FT-FY22-01042022-009213-B	<1	
WS-009214	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to room 112	High Left	WF-03162021-009214	1/26/2022	FT-FY22-01042022-009214-A	<1	FT-FY22-01042022-009214-B	<1
WS-009215	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to room 112	Low Right	WF-03162021-009215	1/26/2022	FT-FY22-01042022-009215-A	<1	FT-FY22-01042022-009215-B	<1
WS-009216	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 113	WF-03162021-009216	1/26/2022	FT-FY22-01042022-009216-A	1.5	FT-FY22-01042022-009216-B	1.1	
WS-009217	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 113	WF-08252021-009217	1/26/2022	FT-FY22-01042022-009217-A	<1	FT-FY22-01042022-009217-B	<1	
WS-009218	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 115	WF-03162021-009218	1/26/2022	FT-FY22-01042022-009218-A	<1	FT-FY22-01042022-009218-B	<1	
WS-009219	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 115	WF-08252021-009219	1/26/2022	FT-FY22-01042022-009219-A	<1	FT-FY22-01042022-009219-B	<1	
WS-009220	3/16/2021	3/16/2022	1	Combo Fountain	In Pre-K classroom 110	WF-03162021-009220	1/26/2022	FT-FY22-01042022-009220-A	<1	FT-FY22-01042022-009220-B	<1	
WS-009221	8/25/2021	8/25/2022	1	Combo Faucet	In Pre-K classroom 110	WF-08252021-009221	1/26/2022	FT-FY22-01042022-009221-A	<1	FT-FY22-01042022-009221-B	<1	
WS-009222	3/16/2021	3/16/2022	1	Combo Fountain	In Pre-K classroom 111	WF-03162021-009222	1/26/2022	FT-FY22-01042022-009222-A	<1	FT-FY22-01042022-009222-B	<1	
WS-009223	8/25/2021	8/25/2022	1	Combo Faucet	In Pre-K classroom 111	WF-08252021-009223	1/26/2022	FT-FY22-01042022-009223-A	<1	FT-FY22-01042022-009223-B	<1	
WS-009224	3/16/2021	3/16/2022	1	Cooler	In health suite	WF-03162021-009224	1/26/2022	FT-FY22-01042022-009224-A	<1	FT-FY22-01042022-009224-B	<1	
WS-009226	3/16/2021	3/16/2022	2	Cooler	In hallway across from custodial closet	High Right	WF-03162021-009226	1/26/2022	FT-FY22-01042022-009226-A	<1	FT-FY22-01042022-009226-B	<1
WS-009227	3/16/2021	3/16/2022	2	Cooler	In hallway across from custodial closet	Low Left	WF-03162021-009227	1/26/2022	FT-FY22-01042022-009227-A	<1	FT-FY22-01042022-009227-B	<1
WS-009228	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to gym	High Right	WF-03162021-009228	1/26/2022	FT-FY22-01042022-009228-A	<1	FT-FY22-01042022-009228-B	<1
WS-009229	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to gym	Low Left	WF-03162021-009229	1/26/2022	FT-FY22-01042022-009229-A	<1	FT-FY22-01042022-009229-B	<1
WS-009230	3/16/2021	3/16/2022	2	Cooler	In gym adjacent to kitchen	WF-03162021-009230	1/26/2022	FT-FY22-01042022-009230-A	<1	FT-FY22-01042022-009230-B	<1	
WS-009233	3/16/2021	3/16/2022	2	Cooler	In girls' locker room in gym	WF-03162021-009233	1/26/2022	FT-FY22-01042022-009233-A	<1	FT-FY22-01042022-009233-B	<1	
WS-009234	3/16/2021	3/16/2022	2	Cooler	In boys' locker room in gym	WF-03162021-009234	1/26/2022	FT-FY22-01042022-009234-A	<1	FT-FY22-01042022-009234-B	<1	
WS-009237	3/16/2021	3/16/2022	2	Cooler	In hallway near elevator	High Right	WF-03162021-009237	1/26/2022	FT-FY22-01042022-009237-A	<1	FT-FY22-01042022-009237-B	<1
WS-009238	3/16/2021	3/16/2022	2	Cooler	In hallway near elevator	Low Left	WF-03162021-009238	1/26/2022	FT-FY22-01042022-009238-A	<1	FT-FY22-01042022-009238-B	<1
WS-009239	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to media center	High Right	WF-03162021-009239	1/26/2022	FT-FY22-01042022-009239-A	<1	FT-FY22-01042022-009239-B	<1
WS-009240	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to media center	Low Left	WF-03162021-009240	1/26/2022	FT-FY22-01042022-009240-A	<1	FT-FY22-01042022-009240-B	<1
WS-009241	3/16/2021	3/16/2022	2	Cooler	In hallway across from room 241	WF-03162021-009241	1/26/2022	FT-FY22-01042022-009241-A	<1	FT-FY22-01042022-009241-B	<1	
WS-009242	3/16/2021	3/16/2022	2	Cooler	In classroom 241	WF-03162021-009242	1/26/2022	FT-FY22-01042022-009242-A	<1	FT-FY22-01042022-009242-B	<1	
WS-009243	3/16/2021	3/16/2022	2	Combo Fountain	In classroom 228	WF-03162021-009243	1/26/2022	FT-FY22-01042022-009243-A	<1	FT-FY22-01042022-009243-B	<1	
WS-009244	8/25/2021	8/25/2022	2	Combo Faucet	In classroom 228	WF-08252021-009244	1/26/2022	FT-FY22-01042022-009244-A	<1	FT-FY22-01042022-009244-B	<1	
WS-009245	3/16/2021	3/16/2022	2	Cooler	In hallway across from room 228	High Left	WF-03162021-009245	1/26/2022	FT-FY22-01042022-009245-A	<1	FT-FY22-01042022-009245-B	<1
WS-009246	3/16/2021	3/16/2022	2	Cooler	In hallway across from room 228	Low Right	WF-03162021-009246	1/26/2022	FT-FY22-01042022-009246-A	<1	FT-FY22-01042022-009246-B	<1
WS-009247	3/16/2021	3/16/2022	2	Combo Fountain	In classroom 227	WF-03162021-009247	1/26/2022	FT-FY22-01042022-009247-A	<1	FT-FY22-01042022-009247-B	1.0	
WS-009248	8/25/2021	8/25/2022	2	Combo Faucet	In classroom 227	WF-08252021-009248	1/26/2022	FT-FY22-01042022-009248-A	<1	FT-FY22-01042022-009248-B	<1	

WS- 009249	3/16/2021	3/16/2022	2	Combo Fountain	In art room 223	Left	WF-03162021-009249	1/26/2022	FT-FY22-01042022-009249-A	<1	FT-FY22-01042022-009249-B	<1
WS- 009251	3/16/2021	3/16/2022	2	Combo Faucet	In art room 223	Right	WF-03162021-009251	1/26/2022	FT-FY22-01042022-009251-A	<1	FT-FY22-01042022-009251-B	<1
WS- 009253	3/16/2021	3/16/2022	2	Combo Fountain	In classroom 224		WF-03162021-009253	1/26/2022	FT-FY22-01042022-009253-A	<1	FT-FY22-01042022-009253-B	<1
WS- 009254	8/25/2021	8/25/2022	2	Combo Faucet	In classroom 224		WF-08252021-009254	1/26/2022	FT-FY22-01042022-009254-A	<1	FT-FY22-01042022-009254-B	<1
WS- 009255	3/16/2021	3/16/2022	2	Combo Fountain	In classroom 221		WF-03162021-009255	1/26/2022	FT-FY22-01042022-009255-A	<1	FT-FY22-01042022-009255-B	1.3
WS- 009256	8/25/2021	8/25/2022	2	Combo Faucet	In classroom 221		WF-08252021-009256	1/26/2022	FT-FY22-01042022-009256-A	<1	FT-FY22-01042022-009256-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009232	1/21/2021	1/21/2022	2	Food Prep Sink	In kitchen	Right	WF-01212021-009232	1/26/2022	FT-FY22-01042022-009232-A	<1	FT-FY22-01042022-009232-B	<1