



Burrville Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009207	3/1/2023	3/1/2024	1	Bottle Filler	In hallway adjacent to room 112	WF-03012023-009207	12/24/2023	FT-FY24-11272023-009207-A	<1	FT-FY24-11272023-009207-B	<1	
WS-009209	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to boys' restroom near stairwell 1	WF-03012023-009209	12/24/2023	FT-FY24-11272023-009209-A	<1	FT-FY24-11272023-009209-B	<1	
WS-009210	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 108	WF-03012023-009210	12/24/2023	FT-FY24-11272023-009210-A	<1	FT-FY24-11272023-009210-B	<1	
WS-009211	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 108	WF-08072023-009211	12/24/2023	FT-FY24-11272023-009211-A	<1	FT-FY24-11272023-009211-B	<1	
WS-009214	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 111	High Left	WF-03012023-009214	12/24/2023	FT-FY24-11272023-009214-A	<1	FT-FY24-11272023-009214-B	<1
WS-009215	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 111	Low Right	WF-03012023-009215	12/24/2023	FT-FY24-11272023-009215-A	<1	FT-FY24-11272023-009215-B	<1
WS-009216	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 113	WF-03012023-009216	12/24/2023	FT-FY24-11272023-009216-A	<1	FT-FY24-11272023-009216-B	<1	
WS-009217	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 113	WF-08072023-009217	12/24/2023	FT-FY24-11272023-009217-A	<1	FT-FY24-11272023-009217-B	<1	
WS-009218	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 115	WF-03012023-009218	12/24/2023	FT-FY24-11272023-009218-A	<1	FT-FY24-11272023-009218-B	2.0	
WS-009219	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 115	WF-08072023-009219	12/24/2023	FT-FY24-11272023-009219-A	<1	FT-FY24-11272023-009219-B	<1	
WS-009220	3/1/2023	3/1/2024	1	Combo Fountain	In Pre-K classroom 110	WF-03012023-009220	12/24/2023	FT-FY24-11272023-009220-A	<1	FT-FY24-11272023-009220-B	<1	
WS-009221	8/7/2023	8/7/2024	1	Combo Faucet	In Pre-K classroom 110	WF-08072023-009221	12/24/2023	FT-FY24-11272023-009221-A	<1	FT-FY24-11272023-009221-B	<1	
WS-009222	3/1/2023	3/1/2024	1	Combo Fountain	In Pre-K classroom 111	WF-03012023-009222	12/24/2023	FT-FY24-11272023-009222-A	<1	FT-FY24-11272023-009222-B	<1	
WS-009223	8/7/2023	8/7/2024	1	Combo Faucet	In Pre-K classroom 111	WF-08072023-009223	12/24/2023	FT-FY24-11272023-009223-A	<1	FT-FY24-11272023-009223-B	<1	
WS-009224	3/1/2023	3/1/2024	1	Cooler	In health suite	WF-03012023-009224	12/24/2023	FT-FY24-11272023-009224-A	<1	FT-FY24-11272023-009224-B	<1	
WS-009226	3/1/2023	3/1/2024	2	Cooler	In hallway across from custodial closet	High Right	WF-03012023-009226	12/24/2023	FT-FY24-11272023-009226-A	<1	FT-FY24-11272023-009226-B	<1
WS-009227	3/1/2023	3/1/2024	2	Cooler	In hallway across from custodial closet	Low Left	WF-03012023-009227	12/24/2023	FT-FY24-11272023-009227-A	<1	FT-FY24-11272023-009227-B	<1
WS-009228	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to gym	High Right	WF-03012023-009228	12/24/2023	FT-FY24-11272023-009228-A	<1	FT-FY24-11272023-009228-B	<1
WS-009229	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to gym	Low Left	WF-03012023-009229	12/24/2023	FT-FY24-11272023-009229-A	<1	FT-FY24-11272023-009229-B	<1
WS-009235	3/1/2023	3/1/2024	2	Cooler	In staff lounge		WF-03012023-009235	12/24/2023	FT-FY24-11272023-009235-A	<1	FT-FY24-11272023-009235-B	<1
WS-009236	3/1/2023	3/1/2024	2	Break Room	In staff lounge		WF-03012023-009236	12/24/2023	FT-FY24-11272023-009236-A	<1	FT-FY24-11272023-009236-B	<1
WS-009237	3/1/2023	3/1/2024	2	Cooler	In hallway near elevator	High Right	WF-03012023-009237	12/24/2023	FT-FY24-11272023-009237-A	<1	FT-FY24-11272023-009237-B	<1
WS-009238	3/1/2023	3/1/2024	2	Cooler	In hallway near elevator	Low Left	WF-03012023-009238	12/24/2023	FT-FY24-11272023-009238-A	<1	FT-FY24-11272023-009238-B	<1
WS-009239	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to media center	High Right	WF-03012023-009239	12/24/2023	FT-FY24-11272023-009239-A	<1	FT-FY24-11272023-009239-B	<1
WS-009240	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to media center	Low Left	WF-03012023-009240	12/24/2023	FT-FY24-11272023-009240-A	<1	FT-FY24-11272023-009240-B	<1
WS-009241	3/1/2023	3/1/2024	2	Cooler	In hallway across from room 241		WF-03012023-009241	12/24/2023	FT-FY24-11272023-009241-A	<1	FT-FY24-11272023-009241-B	<1
WS-009242	3/1/2023	3/1/2024	2	Cooler	In classroom 241		WF-03012023-009242	12/24/2023	FT-FY24-11272023-009242-A	<1	FT-FY24-11272023-009242-B	<1
WS-009243	3/1/2023	3/1/2024	2	Combo Fountain	In classroom 228		WF-03012023-009243	12/24/2023	FT-FY24-11272023-009243-A	2.0	FT-FY24-11272023-009243-B	<1
WS-009244	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 228		WF-08072023-009244	12/24/2023	FT-FY24-11272023-009244-A	<1	FT-FY24-11272023-009244-B	<1
WS-009245	3/1/2023	3/1/2024	2	Cooler	In hallway across from room 228	High Left	WF-03012023-009245	12/24/2023	FT-FY24-11272023-009245-A	<1	FT-FY24-11272023-009245-B	<1
WS-009246	3/1/2023	3/1/2024	2	Cooler	In hallway across from room 228	Low Right	WF-03012023-009246	12/24/2023	FT-FY24-11272023-009246-A	<1	FT-FY24-11272023-009246-B	<1
WS-009247	3/1/2023	3/1/2024	2	Combo Fountain	In classroom 227		WF-03012023-009247	12/24/2023	FT-FY24-11272023-009247-A	<1	FT-FY24-11272023-009247-B	<1
WS-009248	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 227		WF-08072023-009248	12/24/2023	FT-FY24-11272023-009248-A	<1	FT-FY24-11272023-009248-B	<1
WS-009249	3/1/2023	3/1/2024	2	Combo Fountain	In art room 223	Left	WF-03012023-009249	12/24/2023	FT-FY24-11272023-009249-A	<1	FT-FY24-11272023-009249-B	<1
WS-009251	3/1/2023	3/1/2024	2	Combo Faucet	In art room 223	Right	WF-03012023-009251	12/24/2023	FT-FY24-11272023-009251-A	<1	FT-FY24-11272023-009251-B	<1

WS- 009253	3/1/2023	3/1/2024	2	Combo Fountain	In classroom 224	WF-03012023-009253	12/24/2023	FT-FY24-11272023-009253-A	<1	FT-FY24-11272023-009253-B	<1
WS- 009254	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 224	WF-08072023-009254	12/24/2023	FT-FY24-11272023-009254-A	<1	FT-FY24-11272023-009254-B	<1
WS- 009255	3/1/2023	3/1/2024	2	Combo Fountain	In classroom 221	WF-03012023-009255	12/24/2023	FT-FY24-11272023-009255-A	<1	FT-FY24-11272023-009255-B	<1
WS- 009256	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 221	WF-08072023-009256	12/24/2023	FT-FY24-11272023-009256-A	<1	FT-FY24-11272023-009256-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009232	12/21/2022	12/21/2023	2	Food Prep Sink	In kitchen Right	WF-12212022-009232	12/24/2023	FT-FY24-11272023-009232-A	<1	FT-FY24-11272023-009232-B	<1