



Burrville Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009209	3/8/2022	3/8/2023	1	Cooler	In hallway adjacent to boys' restroom near stairwell 1	WF-03082022-009209	11/15/2022	FT-FY23-10102022-009209-A	<1	FT-FY23-10102022-009209-B	<1	
WS-009210	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 108	WF-03082022-009210	11/15/2022	FT-FY23-10102022-009210-A	<1	FT-FY23-10102022-009210-B	4.5	
WS-009211	8/16/2022	8/16/2023	1	Combo Faucet	In classroom 108	WF-08162022-009211	11/15/2022	FT-FY23-10102022-009211-A	<1	FT-FY23-10102022-009211-B	<1	
WS-009212	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 114	WF-03082022-009212	11/15/2022	FT-FY23-10102022-009212-A	<1	FT-FY23-10102022-009212-B	<1	
WS-009213	8/16/2022	8/16/2023	1	Combo Faucet	In classroom 114	WF-08162022-009213	11/15/2022	FT-FY23-10102022-009213-A	<1	FT-FY23-10102022-009213-B	<1	
WS-009214	3/8/2022	3/8/2023	1	Cooler	In hallway adjacent to room 112	High Left	WF-03082022-009214	11/15/2022	FT-FY23-10102022-009214-A	<1	FT-FY23-10102022-009214-B	<1
WS-009215	3/8/2022	3/8/2023	1	Cooler	In hallway adjacent to room 112	Low Right	WF-03082022-009215	11/15/2022	FT-FY23-10102022-009215-A	<1	FT-FY23-10102022-009215-B	<1
WS-009216	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 113	WF-03082022-009216	11/15/2022	FT-FY23-10102022-009216-A	<1	FT-FY23-10102022-009216-B	<1	
WS-009217	8/16/2022	8/16/2023	1	Combo Faucet	In classroom 113	WF-08162022-009217	11/15/2022	FT-FY23-10102022-009217-A	<1	FT-FY23-10102022-009217-B	<1	
WS-009218	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 115	WF-03082022-009218	11/15/2022	FT-FY23-10102022-009218-A	<1	FT-FY23-10102022-009218-B	<1	
WS-009219	8/16/2022	8/16/2023	1	Combo Faucet	In classroom 115	WF-08162022-009219	11/15/2022	FT-FY23-10102022-009219-A	<1	FT-FY23-10102022-009219-B	<1	
WS-009220	3/8/2022	3/8/2023	1	Combo Fountain	In Pre-K classroom 110	WF-03082022-009220	11/15/2022	FT-FY23-10102022-009220-A	<1	FT-FY23-10102022-009220-B	<1	
WS-009221	8/16/2022	8/16/2023	1	Combo Faucet	In Pre-K classroom 110	WF-08162022-009221	11/15/2022	FT-FY23-10102022-009221-A	<1	FT-FY23-10102022-009221-B	<1	
WS-009222	3/8/2022	3/8/2023	1	Combo Fountain	In Pre-K classroom 111	WF-03082022-009222	11/15/2022	FT-FY23-10102022-009222-A	<1	FT-FY23-10102022-009222-B	<1	
WS-009223	8/16/2022	8/16/2023	1	Combo Faucet	In Pre-K classroom 111	WF-08162022-009223	11/15/2022	FT-FY23-10102022-009223-A	<1	FT-FY23-10102022-009223-B	<1	
WS-009224	3/8/2022	3/8/2023	1	Cooler	In health suite	WF-03082022-009224	11/15/2022	FT-FY23-10102022-009224-A	<1	FT-FY23-10102022-009224-B	<1	
WS-009228	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to gym	High Right	WF-03082022-009228	11/15/2022	FT-FY23-10102022-009228-A	<1	FT-FY23-10102022-009228-B	<1
WS-009229	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to gym	Low Left	WF-03082022-009229	11/15/2022	FT-FY23-10102022-009229-A	<1	FT-FY23-10102022-009229-B	<1
WS-009230	3/8/2022	3/8/2023	2	Cooler	In gym adjacent to kitchen	WF-03082022-009230	11/15/2022	FT-FY23-10102022-009230-A	<1	FT-FY23-10102022-009230-B	<1	
WS-009234	3/8/2022	3/8/2023	2	Cooler	In boys' locker room in gym	WF-03082022-009234	11/15/2022	FT-FY23-10102022-009234-A	<1	FT-FY23-10102022-009234-B	<1	
WS-009236	3/8/2022	3/8/2023	2	Break Room	In staff lounge	WF-03082022-009236	11/15/2022	FT-FY23-10102022-009236-A	<1	FT-FY23-10102022-009236-B	<1	
WS-009237	3/8/2022	3/8/2023	2	Cooler	In hallway near elevator	High Right	WF-03082022-009237	11/15/2022	FT-FY23-10102022-009237-A	<1	FT-FY23-10102022-009237-B	<1
WS-009238	3/8/2022	3/8/2023	2	Cooler	In hallway near elevator	Low Left	WF-03082022-009238	11/15/2022	FT-FY23-10102022-009238-A	<1	FT-FY23-10102022-009238-B	<1
WS-009239	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to media center	High Right	WF-03082022-009239	11/15/2022	FT-FY23-10102022-009239-A	<1	FT-FY23-10102022-009239-B	<1
WS-009240	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to media center	Low Left	WF-03082022-009240	11/15/2022	FT-FY23-10102022-009240-A	<1	FT-FY23-10102022-009240-B	<1
WS-009241	3/8/2022	3/8/2023	2	Cooler	In hallway across from room 241	WF-03082022-009241	11/15/2022	FT-FY23-10102022-009241-A	<1	FT-FY23-10102022-009241-B	<1	
WS-009245	3/8/2022	3/8/2023	2	Cooler	In hallway across from room 228	High Left	WF-03082022-009245	11/15/2022	FT-FY23-10102022-009245-A	<1	FT-FY23-10102022-009245-B	<1
WS-009246	3/8/2022	3/8/2023	2	Cooler	In hallway across from room 228	Low Right	WF-03082022-009246	11/15/2022	FT-FY23-10102022-009246-A	<1	FT-FY23-10102022-009246-B	<1
WS-009247	3/8/2022	3/8/2023	2	Combo Fountain	In classroom 227	WF-03082022-009247	11/15/2022	FT-FY23-10102022-009247-A	<1	FT-FY23-10102022-009247-B	<1	
WS-009248	8/16/2022	8/16/2023	2	Combo Faucet	In classroom 227	WF-08162022-009248	11/15/2022	FT-FY23-10102022-009248-A	<1	FT-FY23-10102022-009248-B	<1	
WS-009249	3/8/2022	3/8/2023	2	Combo Fountain	In art room 223	Left	WF-03082022-009249	11/15/2022	FT-FY23-10102022-009249-A	<1	FT-FY23-10102022-009249-B	<1
WS-009251	3/8/2022	3/8/2023	2	Combo Faucet	In art room 223	Right	WF-03082022-009251	11/15/2022	FT-FY23-10102022-009251-A	<1	FT-FY23-10102022-009251-B	<1
WS-009253	3/8/2022	3/8/2023	2	Combo Fountain	In classroom 224	WF-03082022-009253	11/15/2022	FT-FY23-10102022-009253-A	<1	FT-FY23-10102022-009253-B	<1	
WS-009254	8/16/2022	8/16/2023	2	Combo Faucet	In classroom 224	WF-08162022-009254	11/15/2022	FT-FY23-10102022-009254-A	<1	FT-FY23-10102022-009254-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009232	1/10/2022	1/10/2023	2	Food Prep Sink	In kitchen Right	WF-01102022-009232	11/15/2022	FT-FY23-10102022-009232-A	<1	FT-FY23-10102022-009232-B	<1