



Burrville ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009209	4/3/2019	4/3/2020	1	Cooler	In hallway adjacent to boys' restroom near stairwell 1	WF-04032019-009209	11/4/2019	FT-FY20-102019-009209-A	<1	FT-FY20-102019-009209-B	<1	
WS-009210	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 108	WF-04032019-009210	11/4/2019	FT-FY20-102019-009210-A	<1	FT-FY20-102019-009210-B	<1	
WS-009211	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 108	WF-09102019-009211	11/4/2019	FT-FY20-102019-009211-A	<1	FT-FY20-102019-009211-B	<1	
WS-009212	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 114	WF-04032019-009212	11/4/2019	FT-FY20-102019-009212-A	<1	FT-FY20-102019-009212-B	<1	
WS-009213	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 114	WF-09102019-009213	11/4/2019	FT-FY20-102019-009213-A	<1	FT-FY20-102019-009213-B	<1	
WS-009214	4/3/2019	4/3/2020	1	Cooler	In hallway adjacent to room 112	High Left	WF-04032019-009214	11/4/2019	FT-FY20-102019-009214-A	<1	FT-FY20-102019-009214-B	<1
WS-009215	4/3/2019	4/3/2020	1	Cooler	In hallway adjacent to room 112	Low Right	WF-04032019-009215	11/4/2019	FT-FY20-102019-009215-A	<1	FT-FY20-102019-009215-B	<1
WS-009216	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 113	WF-04032019-009216	11/4/2019	FT-FY20-102019-009216-A	<1	FT-FY20-102019-009216-B	<1	
WS-009217	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 113	WF-09102019-009217	11/4/2019	FT-FY20-102019-009217-A	1.7	FT-FY20-102019-009217-B	<1	
WS-009218	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 115	WF-04032019-009218	11/4/2019	FT-FY20-102019-009218-A	<1	FT-FY20-102019-009218-B	<1	
WS-009219	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 115	WF-09102019-009219	11/4/2019	FT-FY20-102019-009219-A	3	FT-FY20-102019-009219-B	<1	
WS-009220	4/3/2019	4/3/2020	1	Combo Fountain	In Pre-K classroom 110	WF-04032019-009220	11/4/2019	FT-FY20-102019-009220-A	<1	FT-FY20-102019-009220-B	<1	
WS-009221	9/10/2019	9/10/2020	1	Combo Faucet	In Pre-K classroom 110	WF-09102019-009221	11/4/2019	FT-FY20-102019-009221-A	<1	FT-FY20-102019-009221-B	<1	
WS-009222	4/3/2019	4/3/2020	1	Combo Fountain	In Pre-K classroom 111	WF-04032019-009222	11/4/2019	FT-FY20-102019-009222-A	<1	FT-FY20-102019-009222-B	<1	
WS-009223	9/10/2019	9/10/2020	1	Combo Faucet	In Pre-K classroom 111	WF-09102019-009223	11/4/2019	FT-FY20-102019-009223-A	1.5	FT-FY20-102019-009223-B	<1	
WS-009224	4/3/2019	4/3/2020	1	Cooler	In health suite	WF-04032019-009224	11/4/2019	FT-FY20-102019-009224-A	<1	FT-FY20-102019-009224-B	<1	
WS-009226	4/3/2019	4/3/2020	2	Cooler	In hallway across from custodial closet	High Right	WF-04032019-009226	11/4/2019	FT-FY20-102019-009226-A	<1	FT-FY20-102019-009226-B	<1
WS-009227	4/3/2019	4/3/2020	2	Cooler	In hallway across from custodial closet	Low Left	WF-04032019-009227	11/4/2019	FT-FY20-102019-009227-A	<1	FT-FY20-102019-009227-B	<1
WS-009228	4/3/2019	4/3/2020	2	Cooler	In hallway adjacent to gym	High Right	WF-04032019-009228	11/4/2019	FT-FY20-102019-009228-A	<1	FT-FY20-102019-009228-B	<1
WS-009229	4/3/2019	4/3/2020	2	Cooler	In hallway adjacent to gym	Low Left	WF-04032019-009229	11/4/2019	FT-FY20-102019-009229-A	<1	FT-FY20-102019-009229-B	<1
WS-009230	4/3/2019	4/3/2020	2	Cooler	In gym adjacent to kitchen	WF-04032019-009230	11/4/2019	FT-FY20-102019-009230-A	<1	FT-FY20-102019-009230-B	<1	
WS-009233	4/3/2019	4/3/2020	2	Cooler	In girls' locker room in gym	WF-04032019-009233	11/4/2019	FT-FY20-102019-009233-A	<1	FT-FY20-102019-009233-B	<1	
WS-009234	4/3/2019	4/3/2020	2	Cooler	In boys' locker room in gym	WF-04032019-009234	11/4/2019	FT-FY20-102019-009234-A	<1	FT-FY20-102019-009234-B	<1	
WS-009235	4/3/2019	4/3/2020	2	Cooler	In staff lounge	WF-04032019-009235	11/4/2019	FT-FY20-102019-009235-A	<1	FT-FY20-102019-009235-B	<1	
WS-009236	4/3/2019	4/3/2020	2	Break Room	In staff lounge	WF-04032019-009236	11/4/2019	FT-FY20-102019-009236-A	<1	FT-FY20-102019-009236-B	<1	
WS-009237	4/3/2019	4/3/2020	2	Cooler	In hallway near elevator	High Right	WF-04032019-009237	11/4/2019	FT-FY20-102019-009237-A	<1	FT-FY20-102019-009237-B	<1
WS-009238	4/3/2019	4/3/2020	2	Cooler	In hallway near elevator	Low Left	WF-04032019-009238	11/4/2019	FT-FY20-102019-009238-A	<1	FT-FY20-102019-009238-B	<1
WS-009239	4/3/2019	4/3/2020	2	Cooler	In hallway adjacent to media center	High Right	WF-04032019-009239	11/4/2019	FT-FY20-102019-009239-A	<1	FT-FY20-102019-009239-B	<1
WS-009240	4/3/2019	4/3/2020	2	Cooler	In hallway adjacent to media center	Low Left	WF-04032019-009240	11/4/2019	FT-FY20-102019-009240-A	<1	FT-FY20-102019-009240-B	<1
WS-009241	4/3/2019	4/3/2020	2	Cooler	In hallway across from room 241	WF-04032019-009241	11/4/2019	FT-FY20-102019-009241-A	<1	FT-FY20-102019-009241-B	<1	
WS-009242	4/3/2019	4/3/2020	2	Cooler	In classroom 241	WF-04032019-009242	11/4/2019	FT-FY20-102019-009242-A	<1	FT-FY20-102019-009242-B	<1	
WS-009243	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 228	WF-04032019-009243	11/4/2019	FT-FY20-102019-009243-A	<1	FT-FY20-102019-009243-B	<1	
WS-009244	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 228	WF-09102019-009244	11/4/2019	FT-FY20-102019-009244-A	<1	FT-FY20-102019-009244-B	<1	
WS-009245	4/3/2019	4/3/2020	2	Cooler	In hallway across from room 228	High Left	WF-04032019-009245	11/4/2019	FT-FY20-102019-009245-A	<1	FT-FY20-102019-009245-B	<1
WS-009246	4/3/2019	4/3/2020	2	Cooler	In hallway across from room 228	Low Right	WF-04032019-009246	11/4/2019	FT-FY20-102019-009246-A	<1	FT-FY20-102019-009246-B	<1

WS- 009247	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 227		WF-04032019-009247	11/4/2019	FT-FY20-102019-009247-A	<1	FT-FY20-102019-009247-B	<1
WS- 009248	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 227		WF-09102019-009248	11/4/2019	FT-FY20-102019-009248-A	<1	FT-FY20-102019-009248-B	<1
WS- 009249	4/3/2019	4/3/2020	2	Combo Fountain	In art room 223	Left	WF-04032019-009249	11/4/2019	FT-FY20-102019-009249-A	<1	FT-FY20-102019-009249-B	<1
WS- 009251	4/3/2019	4/3/2020	2	Combo Faucet	In art room 223	Right	WF-04032019-009251	11/4/2019	FT-FY20-102019-009251-A	<1	FT-FY20-102019-009251-B	<1
WS- 009253	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 224		WF-04032019-009253	11/4/2019	FT-FY20-102019-009253-A	<1	FT-FY20-102019-009253-B	<1
WS- 009254	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 224		WF-09102019-009254	11/4/2019	FT-FY20-102019-009254-A	<1	FT-FY20-102019-009254-B	<1
WS- 009255	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 221		WF-04032019-009255	11/4/2019	FT-FY20-102019-009255-A	<1	FT-FY20-102019-009255-B	<1
WS- 009256	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 221		WF-09102019-009256	11/4/2019	FT-FY20-102019-009256-A	<1	FT-FY20-102019-009256-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009232	7/1/2019	7/1/2020	2	Food Prep Sink	In kitchen		WF-07012019-009232	11/4/2019	FT-FY20-102019-009232-A	<1	FT-FY20-102019-009232-B	<1