



Burrville ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009209	4/12/2018	4/12/2019	1	Cooler	In hallway adjacent to boys' restroom near stairwell 1	WF-04122018-009209	10/30/2018	FT-FY19-102018-009209-A	< 1	FT-FY19-102018-009209-B	< 1	
WS-009210	4/12/2018	4/12/2019	1	Combo Fountain	In classroom 108	WF-04122018-009210	10/30/2018	FT-FY19-102018-009210-A	< 1	FT-FY19-102018-009210-B	< 1	
WS-009211	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 108	WF-09182018-009211	10/30/2018	FT-FY19-102018-009211-A	< 1	FT-FY19-102018-009211-B	< 1	
WS-009212	4/12/2018	4/12/2019	1	Combo Fountain	In classroom 114	WF-04122018-009212	10/30/2018	FT-FY19-102018-009212-A	< 1	FT-FY19-102018-009212-B	< 1	
WS-009213	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 114	WF-09182018-009213	10/30/2018	FT-FY19-102018-009213-A	< 1	FT-FY19-102018-009213-B	< 1	
WS-009214	4/12/2018	4/12/2019	1	Cooler	In hallway adjacent to room 112	High Left	WF-04122018-009214	10/30/2018	FT-FY19-102018-009214-A	< 1	FT-FY19-102018-009214-B	< 1
WS-009215	4/12/2018	4/12/2019	1	Cooler	In hallway adjacent to room 112	Low Right	WF-04122018-009215	10/30/2018	FT-FY19-102018-009215-A	< 1	FT-FY19-102018-009215-B	< 1
WS-009216	4/12/2018	4/12/2019	1	Combo Fountain	In classroom 113	WF-04122018-009216	10/30/2018	FT-FY19-102018-009216-A	< 1	FT-FY19-102018-009216-B	< 1	
WS-009217	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 113	WF-09182018-009217	10/30/2018	FT-FY19-102018-009217-A	< 1	FT-FY19-102018-009217-B	< 1	
WS-009218	4/12/2018	4/12/2019	1	Combo Fountain	In classroom 115	WF-04122018-009218	10/30/2018	FT-FY19-102018-009218-A	< 1	FT-FY19-102018-009218-B	< 1	
WS-009219	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 115	WF-09182018-009219	10/30/2018	FT-FY19-102018-009219-A	< 1	FT-FY19-102018-009219-B	< 1	
WS-009220	4/12/2018	4/12/2019	1	Combo Fountain	In Pre-K classroom 110	WF-04122018-009220	10/30/2018	FT-FY19-102018-009220-A	< 1	FT-FY19-102018-009220-B	< 1	
WS-009221	9/18/2018	9/18/2019	1	Combo Faucet	In Pre-K classroom 110	WF-09182018-009221	10/30/2018	FT-FY19-102018-009221-A	< 1	FT-FY19-102018-009221-B	< 1	
WS-009222	4/12/2018	4/12/2019	1	Combo Fountain	In Pre-K classroom 111	WF-04122018-009222	10/30/2018	FT-FY19-102018-009222-A	< 1	FT-FY19-102018-009222-B	< 1	
WS-009223	9/18/2018	9/18/2019	1	Combo Faucet	In Pre-K classroom 111	WF-09182018-009223	10/30/2018	FT-FY19-102018-009223-A	< 1	FT-FY19-102018-009223-B	< 1	
WS-009224	4/12/2018	4/12/2019	1	Cooler	In health suite	WF-04122018-009224	10/30/2018	FT-FY19-102018-009224-A	< 1	FT-FY19-102018-009224-B	< 1	
WS-009226	4/12/2018	4/12/2019	2	Cooler	In hallway across from custodial closet	High Right	WF-04122018-009226	10/30/2018	FT-FY19-102018-009226-A	< 1	FT-FY19-102018-009226-B	< 1
WS-009227	4/12/2018	4/12/2019	2	Cooler	In hallway across from custodial closet	Low Left	WF-04122018-009227	10/30/2018	FT-FY19-102018-009227-A	< 1	FT-FY19-102018-009227-B	< 1
WS-009228	4/12/2018	4/12/2019	2	Cooler	In hallway adjacent to gym	High Right	WF-04122018-009228	10/30/2018	FT-FY19-102018-009228-A	< 1	FT-FY19-102018-009228-B	< 1
WS-009229	4/12/2018	4/12/2019	2	Cooler	In hallway adjacent to gym	Low Left	WF-04122018-009229	10/30/2018	FT-FY19-102018-009229-A	< 1	FT-FY19-102018-009229-B	< 1
WS-009230	4/12/2018	4/12/2019	2	Cooler	In gym adjacent to kitchen	WF-04122018-009230	10/30/2018	FT-FY19-102018-009230-A	< 1	FT-FY19-102018-009230-B	< 1	
WS-009233	4/12/2018	4/12/2019	2	Cooler	In girls' locker room in gym	WF-04122018-009233	10/30/2018	FT-FY19-102018-009233-A	< 1	FT-FY19-102018-009233-B	< 1	
WS-009234	4/12/2018	4/12/2019	2	Cooler	In boys' locker room in gym	WF-04122018-009234	10/30/2018	FT-FY19-102018-009234-A	< 1	FT-FY19-102018-009234-B	< 1	
WS-009235	4/12/2018	4/12/2019	2	Cooler	In staff lounge	WF-04122018-009235	10/30/2018	FT-FY19-102018-009235-A	< 1	FT-FY19-102018-009235-B	< 1	
WS-009236	4/12/2018	4/12/2019	2	Break Room	In staff lounge	WF-04122018-009236	10/30/2018	FT-FY19-102018-009236-A	< 1	FT-FY19-102018-009236-B	< 1	
WS-009237	4/12/2018	4/12/2019	2	Cooler	In hallway near elevator	High Right	WF-04122018-009237	10/30/2018	FT-FY19-102018-009237-A	< 1	FT-FY19-102018-009237-B	< 1
WS-009238	4/12/2018	4/12/2019	2	Cooler	In hallway near elevator	Low Left	WF-04122018-009238	10/30/2018	FT-FY19-102018-009238-A	< 1	FT-FY19-102018-009238-B	< 1
WS-009239	4/12/2018	4/12/2019	2	Cooler	In hallway adjacent to media center	High Right	WF-04122018-009239	10/30/2018	FT-FY19-102018-009239-A	< 1	FT-FY19-102018-009239-B	< 1
WS-009240	4/12/2018	4/12/2019	2	Cooler	In hallway adjacent to media center	Low Left	WF-04122018-009240	10/30/2018	FT-FY19-102018-009240-A	< 1	FT-FY19-102018-009240-B	< 1
WS-009241	4/12/2018	4/12/2019	2	Cooler	In hallway across from room 241	WF-04122018-009241	10/30/2018	FT-FY19-102018-009241-A	< 1	FT-FY19-102018-009241-B	< 1	
WS-009242	4/12/2018	4/12/2019	2	Cooler	In classroom 241	WF-04122018-009242	10/30/2018	FT-FY19-102018-009242-A	< 1	FT-FY19-102018-009242-B	< 1	
WS-009243	4/12/2018	4/12/2019	2	Combo Fountain	In classroom 228	WF-04122018-009243	10/30/2018	FT-FY19-102018-009243-A	< 1	FT-FY19-102018-009243-B	< 1	
WS-009244	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 228	WF-09182018-009244	10/30/2018	FT-FY19-102018-009244-A	< 1	FT-FY19-102018-009244-B	< 1	
WS-009245	4/12/2018	4/12/2019	2	Cooler	In hallway across from room 228	High Left	WF-04122018-009245	10/30/2018	FT-FY19-102018-009245-A	< 1	FT-FY19-102018-009245-B	< 1
WS-009247	4/12/2018	4/12/2019	2	Combo Fountain	In classroom 227	WF-04122018-009247	10/30/2018	FT-FY19-102018-009247-A	< 1	FT-FY19-102018-009247-B	< 1	
WS-009248	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 227	WF-09182018-009248	10/30/2018	FT-FY19-102018-009248-A	< 1	FT-FY19-102018-009248-B	< 1	

WS- 009249	4/12/2018	4/12/2019	2	Combo Fountain	In art room 223	Left	WF-04122018-009249	10/30/2018	FT-FY19-102018-009249-A	< 1	FT-FY19-102018-009249-B	< 1
WS- 009251	4/12/2018	4/12/2019	2	Combo Faucet	In art room 223	Right	WF-04122018-009251	10/30/2018	FT-FY19-102018-009251-A	< 1	FT-FY19-102018-009251-B	< 1
WS- 009253	4/12/2018	4/12/2019	2	Combo Fountain	In classroom 224		WF-04122018-009253	10/30/2018	FT-FY19-102018-009253-A	< 1	FT-FY19-102018-009253-B	< 1
WS- 009254	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 224		WF-09182018-009254	10/30/2018	FT-FY19-102018-009254-A	< 1	FT-FY19-102018-009254-B	< 1
WS- 009255	4/12/2018	4/12/2019	2	Combo Fountain	In classroom 221		WF-04122018-009255	10/30/2018	FT-FY19-102018-009255-A	< 1	FT-FY19-102018-009255-B	< 1
WS- 009256	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 221		WF-09182018-009256	10/30/2018	FT-FY19-102018-009256-A	< 1	FT-FY19-102018-009256-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009232	2	Food Prep Sink	In kitchen			Right	10/30/2018	FT-FY19-102018-009232-A	< 1	FT-FY19-102018-009232-B	< 1