



BURVILLE LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	BURRVILLE ELEMENTARY SCHOOL	WS- 009236	12/14/2016	2	Break Room	In staff lounge	FT-102016-009236-A	< 1	FT-102016-009236-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	BURRVILLE ELEMENTARY SCHOOL	WS- 009248	12/14/2016	2	Combo Faucet	In classroom 227	FT-112016-009248-A	4.7	FT-112016-009248-B	< 1
2	BURRVILLE ELEMENTARY SCHOOL	WS- 009256	12/14/2016	2	Combo Faucet	In classroom 221	FT-112016-009256-A	14	FT-112016-009256-B	< 1
3	BURRVILLE ELEMENTARY SCHOOL	WS- 009254	12/14/2016	2	Combo Faucet	In classroom 224	FT-112016-009254-A	4.7	FT-112016-009254-B	< 1
4	BURRVILLE ELEMENTARY SCHOOL	WS- 009211	12/14/2016	1	Combo Faucet	In classroom 108	FT-112016-009211-A	2.7	FT-112016-009211-B	< 1
5	BURRVILLE ELEMENTARY SCHOOL	WS- 009221	12/14/2016	1	Combo Faucet	In Pre-K classroom 110	FT-112016-009221-A	7.9	FT-112016-009221-B	< 1
6	BURRVILLE ELEMENTARY SCHOOL	WS- 009217	12/14/2016	1	Combo Faucet	In classroom 113	FT-112016-009217-A	6.5	FT-112016-009217-B	< 1
7	BURRVILLE ELEMENTARY SCHOOL	WS- 009219	12/14/2016	1	Combo Faucet	In classroom 115	FT-112016-009219-A	1.9	FT-112016-009219-B	< 1
8	BURRVILLE ELEMENTARY SCHOOL	WS- 009223	12/14/2016	1	Combo Faucet	In Pre-K classroom 111	FT-112016-009223-A	8.8	FT-112016-009223-B	< 1
9	BURRVILLE ELEMENTARY SCHOOL	WS- 009213	12/14/2016	1	Combo Faucet	In classroom 114	FT-112016-009213-A	2	FT-112016-009213-B	< 1
10	BURRVILLE ELEMENTARY SCHOOL	WS- 009244	12/14/2016	2	Combo Faucet	In classroom 228	FT-112016-009244-A	1.2	FT-112016-009244-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	BURRVILLE ELEMENTARY SCHOOL	WS- 009248	1/25/2017	2	Combo Faucet	In classroom 227	FT-112016-009248-A	2.1	FT-112016-009248-B	< 1
2	BURRVILLE ELEMENTARY SCHOOL	WS- 009256	1/25/2017	2	Combo Faucet	In classroom 221	FT-112016-009256-A	2.6	FT-112016-009256-B	< 1
3	BURRVILLE ELEMENTARY SCHOOL	WS- 009254	1/25/2017	2	Combo Faucet	In classroom 224	FT-112016-009254-A	2.5	FT-112016-009254-B	< 1
4	BURRVILLE ELEMENTARY SCHOOL	WS- 009211	1/25/2017	1	Combo Faucet	In classroom 108	FT-112016-009211-A	1.1	FT-112016-009211-B	< 1
5	BURRVILLE ELEMENTARY SCHOOL	WS- 009221	1/25/2017	1	Combo Faucet	In Pre-K classroom 110	FT-112016-009221-A	1.7	FT-112016-009221-B	< 1
6	BURRVILLE ELEMENTARY SCHOOL	WS- 009217	1/25/2017	1	Combo Faucet	In classroom 113	FT-112016-009217-A	6.5	FT-112016-009217-B	< 1
7	BURRVILLE ELEMENTARY SCHOOL	WS- 009219	1/25/2017	1	Combo Faucet	In classroom 115	FT-112016-009219-A	1.9	FT-112016-009219-B	< 1
8	BURRVILLE ELEMENTARY SCHOOL	WS- 009223	1/25/2017	1	Combo Faucet	In Pre-K classroom 111	FT-112016-009223-A	8.8	FT-112016-009223-B	< 1
9	BURRVILLE ELEMENTARY SCHOOL	WS- 009213	1/25/2017	1	Combo Faucet	In classroom 114	FT-112016-009213-A	1.3	FT-112016-009213-B	< 1
10	BURRVILLE ELEMENTARY SCHOOL	WS- 009244	1/25/2017	2	Combo Faucet	In classroom 228	FT-112016-009244-A	1.1	FT-112016-009244-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	BURRVILLE ELEMENTARY SCHOOL	WS- 009248	3/30/2017	2	Combo Faucet	In classroom 227	FT-112016-009248-A	7.5	FT-112016-009248-B	< 1
2	BURRVILLE ELEMENTARY SCHOOL	WS- 009256	3/30/2017	2	Combo Faucet	In classroom 221	FT-112016-009256-A	4.4	FT-112016-009256-B	< 1
3	BURRVILLE ELEMENTARY SCHOOL	WS- 009254	3/30/2017	2	Combo Faucet	In classroom 224	FT-112016-009254-A	4	FT-112016-009254-B	< 1
4	BURRVILLE ELEMENTARY SCHOOL	WS- 009211	3/30/2017	1	Combo Faucet	In classroom 108	FT-112016-009211-A	4.1	FT-112016-009211-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb

DCPS ECE Sink and DCPS Requested Sink Filtration

5	BURRVILLE ELEMENTARY SCHOOL	WS- 009221	3/30/2017	1	Combo Faucet	In Pre-K classroom 110	FT-112016-009221-A	2.8	FT-112016-009221-B	< 1
6	BURRVILLE ELEMENTARY SCHOOL	WS- 009213	3/30/2017	1	Combo Faucet	In classroom 114	FT-112016-009213-A	4.4	FT-112016-009213-B	< 1
7	BURRVILLE ELEMENTARY SCHOOL	WS- 009244	3/30/2017	2	Combo Faucet	In classroom 228	FT-112016-009244-A	9.5	FT-112016-009244-B	< 1

Note :
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb