



BURVILLE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009208	Utility	1	In boiler room	WT-042916-9225- A	10.8	WT-042916-9225- B	1.8				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009209	Cooler	1	In hallway adjacent to boys restroom near stairwell 1	WT-042916-9226- A	1.94	WT-042916-9226- B	3.48				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009210	Fountain	1	In classroom 108	WT-042916-9227- A	< 1	WT-042916-9227- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009211	Classroom	1	In classroom 108	WT-042916-9228- A	1.17	WT-042916-9228- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009212	Fountain	1	In classroom 114	WT-042916-9229- A	< 1	WT-042916-9229- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009213	Classroom	1	In classroom 114	WT-042916-9230- A	2.92	WT-042916-9230- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009214	Cooler	1	In hallway adjacent to preschool	WT-042916-9231- A	< 1	WT-042916-9231- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009215	Cooler	1	In hallway adjacent to preschool	WT-042916-9232- A	< 1	WT-042916-9232- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009216	Fountain	1	In classroom 113	WT-042916-9233- A	< 1	WT-042916-9233- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009217	Classroom	1	In classroom 113	WT-042916-9234- A	1.43	WT-042916-9234- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009218	Fountain	1	In classroom 115	WT-042916-9235- A	< 1	WT-042916-9235- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009219	Classroom	1	In classroom 115	WT-042916-9236- A	2.54	WT-042916-9236- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009220	Fountain	1	In classroom prekindergarten	WT-042916-9237- A	< 1	WT-042916-9237- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009221	Classroom	1	In prekindergarten	WT-042916-9238- A	2.49	WT-042916-9238- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009222	Fountain	1	In classroom 111 preschool	WT-042916-9239- A	< 1	WT-042916-9239- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009223	Classroom	1	In preschool 111	WT-042916-9240- A	12.2	WT-042916-9240- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009224	Cooler	1	In health suite	WT-042916-9241- A	2.13	WT-042916-9241- B	1.84				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009225	Health Suite	1	In health suite eye wash	WT-042916-9242- A	4	WT-042916-9242- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009226	Cooler	2	In hallway across custodial closet	WT-042916-9243- A	< 1	WT-042916-9243- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009227	Cooler	2	In hallway across from custodial closet	WT-042916-9244- A	< 1	WT-042916-9244- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009228	Cooler	2	In hallway adjacent to gymnasium near exit	WT-042916-9245- A	< 1	WT-042916-9245- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009229	Cooler	2	In hallway adjacent gymnasium near exit	WT-042916-9246- A	< 1	WT-042916-9246- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009230	Cooler	2	In gymnasium adjacent kitchen	WT-042916-9247- A	< 1	WT-042916-9247- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009231	Other	2	In kitchen (spray nozzle)	WT-042916-9248- A	< 1	WT-042916-9248- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009232	Kitchen	2	In kitchen	WT-042916-9249- A	< 1	WT-042916-9249- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009233	Cooler	2	In gymnasium in girls locker room	WT-042916-9250- A	1.2	WT-042916-9250- B	2.41				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009234	Cooler	2	In gymnasium in boys locker room	WT-042916-9251- A	< 1	WT-042916-9251- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009235	Cooler	2	In teacher's lounge	WT-042916-9252- A	3.73	WT-042916-9252- B	7.1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009236	Break Room	2	In staff lounge	WT-042916-9253- A	17.6	WT-042916-9253- B	9.27	Filtered	6/15/2016	<1	<1
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009237	Cooler	2	In second floor hallway near elevator	WT-042916-9254- A	< 1	WT-042916-9254- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009238	Cooler	2	In second floor hallway near elevator	WT-042916-9255- A	< 1	WT-042916-9255- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009239	Cooler	2	In hallway adjacent to media center	WT-042916-9256- A	< 1	WT-042916-9256- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009240	Cooler	1	In hallway adjacent to media center	WT-042916-9257- A	< 1	WT-042916-9257- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009241	Cooler	1	In hallway across from room 241	WT-042916-9258- A	< 1	WT-042916-9258- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009242	Cooler	2	In room 241	WT-042916-9259- A	< 1	WT-042916-9259- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009243	Fountain	2	In classroom 228	WT-042916-9260- A	< 1	WT-042916-9260- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009244	Classroom	2	In classroom 228	WT-042916-9261- A	1.04	WT-042916-9261- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009245	Cooler	2	In second floor hallway across from classroom 228	WT-042916-9262- A	< 1	WT-042916-9262- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009246	Cooler	2	In second floor hallway across from classroom 228	WT-042916-9263- A	< 1	WT-042916-9263- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009247	Fountain	2	In classroom 227	WT-042916-9264- A	< 1	WT-042916-9264- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009248	Classroom	2	In classroom 227	WT-042916-9265- A	1.97	WT-042916-9265- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009249	Fountain	2	In art room 223	WT-042916-9266- A	< 1	WT-042916-9266- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009250	Classroom	2	In art room 223	WT-042916-9267- A	4.65	WT-042916-9267- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009251	Fountain	2	In art room 223	WT-042916-9268- A	< 1	WT-042916-9268- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009252	Classroom	2	In art room 223	WT-042916-9269- A	1.08	WT-042916-9269- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009253	Fountain	2	In classroom 224	WT-042916-9270- A	< 1	WT-042916-9270- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009254	Classroom	2	In classroom 224	WT-042916-9271- A	2.31	WT-042916-9271- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009255	Fountain	2	In classroom 221	WT-042916-9272- A	< 1	WT-042916-9272- B	< 1				
BURVILLE ELEMENTARY SCHOOL	5/7/2016	WS-009256	Classroom	2	In classroom 221	WT-042916-9273- A	2.77	WT-042916-9273- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.