



# Butler-Wyatt Clubhouse 2 Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001040	6/10/2022	6/10/2023	Ground Floor	Cooler	In hallway near the entrance	WF-06102022-001040	3/2/2023	FT-FY23-02022023-001040-A	<1	FT-FY23-02022023-001040-B	<1
WS- 001041	6/10/2022	6/10/2023	Ground Floor	Cooler	In hallway near the entrance High Left	WF-06102022-001041	3/2/2023	FT-FY23-02022023-001041-A	<1	FT-FY23-02022023-001041-B	<1