



CW Harris Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014150	5/24/2021	5/24/2022	1	Break Room	In room 178 UPO workroom	WF-05242021-014150	1/21/2022	FT-FY22-01042022-014150-A	<1	FT-FY22-01042022-014150-B	<1	
WS-014151	10/12/2021	10/12/2022	1	Combo Faucet	In room 176 UPO toddler	WF-10122021-014151	1/21/2022	FT-FY22-01042022-014151-A	<1	FT-FY22-01042022-014151-B	<1	
WS-014152	5/24/2021	5/24/2022	1	Combo Fountain	In room 176 UPO toddler	WF-05242021-014152	1/21/2022	FT-FY22-01042022-014152-A	<1	FT-FY22-01042022-014152-B	<1	
WS-014154	10/12/2021	10/12/2022	1	Combo Faucet	In room 174 UPO infant	WF-10122021-014154	1/21/2022	FT-FY22-01042022-014154-A	<1	FT-FY22-01042022-014154-B	<1	
WS-014157	10/12/2021	10/12/2022	1	Combo Faucet	In room 172 preschool classroom	WF-10122021-014157	1/21/2022	FT-FY22-01042022-014157-A	<1	FT-FY22-01042022-014157-B	<1	
WS-014158	5/24/2021	5/24/2022	1	Combo Fountain	In room 172 preschool classroom	WF-05242021-014158	1/21/2022	FT-FY22-01042022-014158-A	<1	FT-FY22-01042022-014158-B	<1	
WS-014160	10/12/2021	10/12/2022	1	Combo Faucet	In room 170 pre-k classroom	WF-10122021-014160	1/21/2022	FT-FY22-01042022-014160-A	<1	FT-FY22-01042022-014160-B	<1	
WS-014161	5/24/2021	5/24/2022	1	Combo Fountain	In room 170 pre-k classroom	WF-05242021-014161	1/21/2022	FT-FY22-01042022-014161-A	<1	FT-FY22-01042022-014161-B	<1	
WS-014162	10/12/2021	10/12/2022	1	Combo Faucet	In room 167 small group room	WF-10122021-014162	1/21/2022	FT-FY22-01042022-014162-A	<1	FT-FY22-01042022-014162-B	<1	
WS-014164	10/12/2021	10/12/2022	1	Combo Faucet	In room 163 speech/OT/PT	WF-10122021-014164	1/21/2022	FT-FY22-01042022-014164-A	<1	FT-FY22-01042022-014164-B	<1	
WS-014165	5/24/2021	5/24/2022	1	Combo Fountain	In room 163 speech/OT/PT	WF-05242021-014165	1/21/2022	FT-FY22-01042022-014165-A	<1	FT-FY22-01042022-014165-B	<1	
WS-014168	10/12/2021	10/12/2022	1	Combo Faucet	In room 160 EC self contained classroom	WF-10122021-014168	1/21/2022	FT-FY22-01042022-014168-A	<1	FT-FY22-01042022-014168-B	<1	
WS-014169	5/24/2021	5/24/2022	1	Combo Fountain	In room 160 EC self contained classroom	WF-05242021-014169	1/21/2022	FT-FY22-01042022-014169-A	<1	FT-FY22-01042022-014169-B	<1	
WS-014173	10/12/2021	10/12/2022	1	Combo Faucet	In room 150 pre-k classroom	WF-10122021-014173	1/21/2022	FT-FY22-01042022-014173-A	<1	FT-FY22-01042022-014173-B	<1	
WS-014174	5/24/2021	5/24/2022	1	Combo Fountain	In room 150 pre-k classroom	WF-05242021-014174	1/21/2022	FT-FY22-01042022-014174-A	<1	FT-FY22-01042022-014174-B	<1	
WS-014176	10/12/2021	10/12/2022	1	Combo Faucet	In room 148 pre-k classroom	WF-10122021-014176	1/21/2022	FT-FY22-01042022-014176-A	<1	FT-FY22-01042022-014176-B	<1	
WS-014177	5/24/2021	5/24/2022	1	Combo Fountain	In room 148 pre-k classroom	WF-05242021-014177	1/21/2022	FT-FY22-01042022-014177-A	<1	FT-FY22-01042022-014177-B	<1	
WS-014178	10/12/2021	10/12/2022	1	Combo Faucet	In room 146 kindergarten classroom	WF-10122021-014178	1/21/2022	FT-FY22-01042022-014178-A	<1	FT-FY22-01042022-014178-B	<1	
WS-014179	5/24/2021	5/24/2022	1	Combo Fountain	In room 146 kindergarten classroom	WF-05242021-014179	1/21/2022	FT-FY22-01042022-014179-A	<1	FT-FY22-01042022-014179-B	<1	
WS-014180	10/12/2021	10/12/2022	1	Combo Faucet	In room 144 kindergarten classroom	WF-10122021-014180	1/21/2022	FT-FY22-01042022-014180-A	<1	FT-FY22-01042022-014180-B	<1	
WS-014181	5/24/2021	5/24/2022	1	Combo Fountain	In room 144 kindergarten classroom	WF-05242021-014181	1/21/2022	FT-FY22-01042022-014181-A	<1	FT-FY22-01042022-014181-B	<1	
WS-014182	5/24/2021	5/24/2022	1	Bottle Filler	In hallway adjacent to room 144	WF-05242021-014182	1/21/2022	FT-FY22-01042022-014182-A	<1	FT-FY22-01042022-014182-B	<1	
WS-014183	5/24/2021	5/24/2022	1	Cooler	In hallway adjacent to room 144	High Left	WF-05242021-014183	1/21/2022	FT-FY22-01042022-014183-A	<1	FT-FY22-01042022-014183-B	<1
WS-014184	5/24/2021	5/24/2022	1	Cooler	In hallway adjacent to room 144	Low Right	WF-05242021-014184	1/21/2022	FT-FY22-01042022-014184-A	<1	FT-FY22-01042022-014184-B	<1
WS-014188	5/24/2021	5/24/2022	1	Combo Fountain	In room 140 1st grade classroom	WF-05242021-014188	1/21/2022	FT-FY22-01042022-014188-A	<1	FT-FY22-01042022-014188-B	<1	
WS-014192	5/24/2021	5/24/2022	2	Combo Fountain	In room 274 5th grade classroom	WF-05242021-014192	1/21/2022	FT-FY22-01042022-014192-A	<1	FT-FY22-01042022-014192-B	<1	
WS-014194	5/24/2021	5/24/2022	2	Combo Fountain	In room 272 4th grade classroom	WF-05242021-014194	1/21/2022	FT-FY22-01042022-014194-A	<1	FT-FY22-01042022-014194-B	<1	
WS-014198	5/24/2021	5/24/2022	2	Combo Fountain	In room 268 music classroom	WF-05242021-014198	1/21/2022	FT-FY22-01042022-014198-A	<1	FT-FY22-01042022-014198-B	<1	
WS-014200	5/24/2021	5/24/2022	2	Combo Fountain	In room 263 teacher collaboration	WF-05242021-014200	1/21/2022	FT-FY22-01042022-014200-A	<1	FT-FY22-01042022-014200-B	<1	
WS-014201	5/24/2021	5/24/2022	2	Bottle Filler	In hallway adjacent to room 263	WF-05242021-014201	1/21/2022	FT-FY22-01042022-014201-A	<1	FT-FY22-01042022-014201-B	<1	
WS-014202	5/24/2021	5/24/2022	2	Cooler	In hallway adjacent to room 263	High Left	WF-05242021-014202	1/21/2022	FT-FY22-01042022-014202-A	<1	FT-FY22-01042022-014202-B	<1
WS-014203	5/24/2021	5/24/2022	2	Cooler	In hallway adjacent to room 263	Low Right	WF-05242021-014203	1/21/2022	FT-FY22-01042022-014203-A	<1	FT-FY22-01042022-014203-B	<1
WS-014210	5/24/2021	5/24/2022	2	Combo Fountain	In room 253 science classroom	Right	WF-05242021-014210	1/21/2022	FT-FY22-01042022-014210-A	<1	FT-FY22-01042022-014210-B	<1
WS-014212	5/24/2021	5/24/2022	2	Combo Fountain	In room 250 3rd grade classroom	WF-05242021-014212	1/21/2022	FT-FY22-01042022-014212-A	<1	FT-FY22-01042022-014212-B	<1	
WS-014214	5/24/2021	5/24/2022	2	Combo Fountain	In room 248 3rd grade classroom	WF-05242021-014214	1/21/2022	FT-FY22-01042022-014214-A	<1	FT-FY22-01042022-014214-B	<1	

WS-014216	5/24/2021	5/24/2022	2	Combo Fountain	In room 246 self contained classroom	WF-05242021-014216	1/21/2022	FT-FY22-01042022-014216-A	<1	FT-FY22-01042022-014216-B	<1	
WS-014218	5/24/2021	5/24/2022	2	Combo Fountain	In room 244 self contained classroom	WF-05242021-014218	1/21/2022	FT-FY22-01042022-014218-A	<1	FT-FY22-01042022-014218-B	<1	
WS-014220	5/24/2021	5/24/2022	2	Combo Fountain	In room 242 2nd grade classroom	WF-05242021-014220	1/21/2022	FT-FY22-01042022-014220-A	<1	FT-FY22-01042022-014220-B	<1	
WS-014222	5/24/2021	5/24/2022	2	Combo Fountain	In room 240 2nd grade classroom	WF-05242021-014222	1/21/2022	FT-FY22-01042022-014222-A	<1	FT-FY22-01042022-014222-B	<1	
WS-014223	5/24/2021	5/24/2022	1	Break Room	In room 137 parent resource center	WF-05242021-014223	1/21/2022	FT-FY22-01042022-014223-A	<1	FT-FY22-01042022-014223-B	<1	
WS-014225	5/24/2021	5/24/2022	1	Break Room	In room 108 admin workroom	WF-05242021-014225	1/21/2022	FT-FY22-01042022-014225-A	<1	FT-FY22-01042022-014225-B	<1	
WS-014226	5/24/2021	5/24/2022	1	Health Suite	In health suite in room 115 treatment	WF-05242021-014226	1/21/2022	FT-FY22-01042022-014226-A	<1	FT-FY22-01042022-014226-B	<1	
WS-014235	5/24/2021	5/24/2022	1	Bottle Filler	In cafeteria adjacent to exit	WF-05242021-014235	1/21/2022	FT-FY22-01042022-014235-A	<1	FT-FY22-01042022-014235-B	<1	
WS-014236	5/24/2021	5/24/2022	1	Cooler	In cafeteria adjacent to exit	Low Left	WF-05242021-014236	1/21/2022	FT-FY22-01042022-014236-A	<1	FT-FY22-01042022-014236-B	<1
WS-014237	5/24/2021	5/24/2022	1	Cooler	In cafeteria adjacent to exit	High Right	WF-05242021-014237	1/21/2022	FT-FY22-01042022-014237-A	<1	FT-FY22-01042022-014237-B	<1
WS-014238	5/24/2021	5/24/2022	1	Bottle Filler	In gym adjacent to stage ramp	WF-05242021-014238	1/21/2022	FT-FY22-01042022-014238-A	<1	FT-FY22-01042022-014238-B	<1	
WS-014239	5/24/2021	5/24/2022	1	Cooler	In gym adjacent to stage ramp	Low Left	WF-05242021-014239	1/21/2022	FT-FY22-01042022-014239-A	<1	FT-FY22-01042022-014239-B	<1
WS-014240	5/24/2021	5/24/2022	1	Cooler	In gym adjacent to stage ramp	High Right	WF-05242021-014240	1/21/2022	FT-FY22-01042022-014240-A	<1	FT-FY22-01042022-014240-B	<1
WS-014241	5/24/2021	5/24/2022	2	Break Room	In room 237 wellness	WF-05242021-014241	1/21/2022	FT-FY22-01042022-014241-A	<1	FT-FY22-01042022-014241-B	<1	
WS-014242	5/24/2021	5/24/2022	2	Break Room	In room 238 staff lounge	WF-05242021-014242	1/21/2022	FT-FY22-01042022-014242-A	<1	FT-FY22-01042022-014242-B	<1	
WS-014243	5/24/2021	5/24/2022	2	Combo Fountain	In room 238 staff lounge	WF-05242021-014243	1/21/2022	FT-FY22-01042022-014243-A	1.9	FT-FY22-01042022-014243-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014233	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen seventh clockwise from entry	WF-02172021-014233	1/21/2022	FT-FY22-01042022-014233-A	<1	FT-FY22-01042022-014233-B	<1