



CW Harris Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014150	5/17/2022	5/17/2023	1	Break Room	In room 178 UPO workroom	WF-05172022-014150	11/11/2022	FT-FY23-10102022-014150-A	<1	FT-FY23-10102022-014150-B	<1	
WS-014151	9/26/2022	9/26/2023	1	Combo Faucet	In room 176 UPO toddler	WF-09262022-014151	11/11/2022	FT-FY23-10102022-014151-A	<1	FT-FY23-10102022-014151-B	<1	
WS-014152	5/17/2022	5/17/2023	1	Combo Fountain	In room 176 UPO toddler	WF-05172022-014152	11/11/2022	FT-FY23-10102022-014152-A	<1	FT-FY23-10102022-014152-B	<1	
WS-014154	9/26/2022	9/26/2023	1	Combo Faucet	In room 174 UPO infant	WF-09262022-014154	11/11/2022	FT-FY23-10102022-014154-A	<1	FT-FY23-10102022-014154-B	<1	
WS-014155	5/17/2022	5/17/2023	1	Combo Fountain	In room 174 UPO infant	WF-05172022-014155	11/11/2022	FT-FY23-10102022-014155-A	<1	FT-FY23-10102022-014155-B	<1	
WS-014157	9/26/2022	9/26/2023	1	Combo Faucet	In room 172 preschool classroom	WF-09262022-014157	11/11/2022	FT-FY23-10102022-014157-A	<1	FT-FY23-10102022-014157-B	<1	
WS-014158	5/17/2022	5/17/2023	1	Combo Fountain	In room 172 preschool classroom	WF-05172022-014158	11/11/2022	FT-FY23-10102022-014158-A	<1	FT-FY23-10102022-014158-B	<1	
WS-014160	9/26/2022	9/26/2023	1	Combo Faucet	In room 170 pre-k classroom	WF-09262022-014160	11/11/2022	FT-FY23-10102022-014160-A	<1	FT-FY23-10102022-014160-B	<1	
WS-014161	5/17/2022	5/17/2023	1	Combo Fountain	In room 170 pre-k classroom	WF-05172022-014161	11/11/2022	FT-FY23-10102022-014161-A	<1	FT-FY23-10102022-014161-B	<1	
WS-014162	9/26/2022	9/26/2023	1	Combo Faucet	In room 167 small group room	WF-09262022-014162	11/11/2022	FT-FY23-10102022-014162-A	<1	FT-FY23-10102022-014162-B	<1	
WS-014164	9/26/2022	9/26/2023	1	Combo Faucet	In room 163 speech/OT/PT	WF-09262022-014164	11/11/2022	FT-FY23-10102022-014164-A	<1	FT-FY23-10102022-014164-B	<1	
WS-014165	5/17/2022	5/17/2023	1	Combo Fountain	In room 163 speech/OT/PT	WF-05172022-014165	11/11/2022	FT-FY23-10102022-014165-A	<1	FT-FY23-10102022-014165-B	<1	
WS-014168	9/26/2022	9/26/2023	1	Combo Faucet	In room 160 EC self contained classroom	WF-09262022-014168	11/11/2022	FT-FY23-10102022-014168-A	<1	FT-FY23-10102022-014168-B	<1	
WS-014169	5/17/2022	5/17/2023	1	Combo Fountain	In room 160 EC self contained classroom	WF-05172022-014169	11/11/2022	FT-FY23-10102022-014169-A	<1	FT-FY23-10102022-014169-B	<1	
WS-014173	9/26/2022	9/26/2023	1	Combo Faucet	In room 150 pre-k classroom	WF-09262022-014173	11/11/2022	FT-FY23-10102022-014173-A	<1	FT-FY23-10102022-014173-B	<1	
WS-014174	5/17/2022	5/17/2023	1	Combo Fountain	In room 150 pre-k classroom	WF-05172022-014174	11/11/2022	FT-FY23-10102022-014174-A	<1	FT-FY23-10102022-014174-B	<1	
WS-014176	9/26/2022	9/26/2023	1	Combo Faucet	In room 148 pre-k classroom	WF-09262022-014176	11/11/2022	FT-FY23-10102022-014176-A	<1	FT-FY23-10102022-014176-B	<1	
WS-014177	5/17/2022	5/17/2023	1	Combo Fountain	In room 148 pre-k classroom	WF-05172022-014177	11/11/2022	FT-FY23-10102022-014177-A	<1	FT-FY23-10102022-014177-B	<1	
WS-014178	9/26/2022	9/26/2023	1	Combo Faucet	In room 146 kindergarten classroom	WF-09262022-014178	11/11/2022	FT-FY23-10102022-014178-A	<1	FT-FY23-10102022-014178-B	<1	
WS-014179	5/17/2022	5/17/2023	1	Combo Fountain	In room 146 kindergarten classroom	WF-05172022-014179	11/11/2022	FT-FY23-10102022-014179-A	<1	FT-FY23-10102022-014179-B	<1	
WS-014180	9/26/2022	9/26/2023	1	Combo Faucet	In room 144 kindergarten classroom	WF-09262022-014180	11/11/2022	FT-FY23-10102022-014180-A	<1	FT-FY23-10102022-014180-B	<1	
WS-014181	5/17/2022	5/17/2023	1	Combo Fountain	In room 144 kindergarten classroom	WF-05172022-014181	11/11/2022	FT-FY23-10102022-014181-A	<1	FT-FY23-10102022-014181-B	<1	
WS-014182	5/17/2022	5/17/2023	1	Bottle Filler	In hallway adjacent to room 144	WF-05172022-014182	11/11/2022	FT-FY23-10102022-014182-A	<1	FT-FY23-10102022-014182-B	<1	
WS-014183	5/17/2022	5/17/2023	1	Cooler	In hallway adjacent to room 144	High Left	WF-05172022-014183	11/11/2022	FT-FY23-10102022-014183-A	<1	FT-FY23-10102022-014183-B	<1
WS-014184	5/17/2022	5/17/2023	1	Cooler	In hallway adjacent to room 144	Low Right	WF-05172022-014184	11/11/2022	FT-FY23-10102022-014184-A	<1	FT-FY23-10102022-014184-B	<1
WS-014186	5/17/2022	5/17/2023	1	Combo Fountain	In room 142 1st grade classroom	WF-05172022-014186	11/11/2022	FT-FY23-10102022-014186-A	<1	FT-FY23-10102022-014186-B	<1	
WS-014188	5/17/2022	5/17/2023	1	Combo Fountain	In room 140 1st grade classroom	WF-05172022-014188	11/11/2022	FT-FY23-10102022-014188-A	<1	FT-FY23-10102022-014188-B	<1	
WS-014190	5/17/2022	5/17/2023	2	Combo Fountain	In room 276 5th grade classroom	WF-05172022-014190	11/11/2022	FT-FY23-10102022-014190-A	<1	FT-FY23-10102022-014190-B	<1	
WS-014192	5/17/2022	5/17/2023	2	Combo Fountain	In room 274 5th grade classroom	WF-05172022-014192	11/11/2022	FT-FY23-10102022-014192-A	<1	FT-FY23-10102022-014192-B	<1	
WS-014194	5/17/2022	5/17/2023	2	Combo Fountain	In room 272 4th grade classroom	WF-05172022-014194	11/11/2022	FT-FY23-10102022-014194-A	<1	FT-FY23-10102022-014194-B	<1	
WS-014196	5/17/2022	5/17/2023	2	Combo Fountain	In room 270 4th grade classroom	WF-05172022-014196	11/11/2022	FT-FY23-10102022-014196-A	<1	FT-FY23-10102022-014196-B	<1	
WS-014198	5/17/2022	5/17/2023	2	Combo Fountain	In room 268 music classroom	WF-05172022-014198	11/11/2022	FT-FY23-10102022-014198-A	<1	FT-FY23-10102022-014198-B	<1	
WS-014200	5/17/2022	5/17/2023	2	Combo Fountain	In room 263 teacher collaboration	WF-05172022-014200	11/11/2022	FT-FY23-10102022-014200-A	<1	FT-FY23-10102022-014200-B	<1	
WS-014201	5/17/2022	5/17/2023	2	Bottle Filler	In hallway adjacent to room 263	WF-05172022-014201	11/11/2022	FT-FY23-10102022-014201-A	<1	FT-FY23-10102022-014201-B	<1	
WS-014202	5/17/2022	5/17/2023	2	Cooler	In hallway adjacent to room 263	High Left	WF-05172022-014202	11/11/2022	FT-FY23-10102022-014202-A	<1	FT-FY23-10102022-014202-B	<1

WS-014203	5/17/2022	5/17/2023	2	Cooler	In hallway adjacent to room 263	Low Right	WF-05172022-014203	11/11/2022	FT-FY23-10102022-014203-A	<1	FT-FY23-10102022-014203-B	<1
WS-014205	5/17/2022	5/17/2023	2	Combo Fountain	In room 260 art classroom		WF-05172022-014205	11/11/2022	FT-FY23-10102022-014205-A	<1	FT-FY23-10102022-014205-B	<1
WS-014208	5/17/2022	5/17/2023	2	Combo Fountain	In room 253 science classroom	Left	WF-05172022-014208	11/11/2022	FT-FY23-10102022-014208-A	<1	FT-FY23-10102022-014208-B	<1
WS-014210	5/17/2022	5/17/2023	2	Combo Fountain	In room 253 science classroom	Right	WF-05172022-014210	11/11/2022	FT-FY23-10102022-014210-A	<1	FT-FY23-10102022-014210-B	<1
WS-014212	5/17/2022	5/17/2023	2	Combo Fountain	In room 250 3rd grade classroom		WF-05172022-014212	11/11/2022	FT-FY23-10102022-014212-A	<1	FT-FY23-10102022-014212-B	<1
WS-014214	5/17/2022	5/17/2023	2	Combo Fountain	In room 248 3rd grade classroom		WF-05172022-014214	11/11/2022	FT-FY23-10102022-014214-A	<1	FT-FY23-10102022-014214-B	<1
WS-014216	5/17/2022	5/17/2023	2	Combo Fountain	In room 246 self contained classroom		WF-05172022-014216	11/11/2022	FT-FY23-10102022-014216-A	<1	FT-FY23-10102022-014216-B	<1
WS-014218	5/17/2022	5/17/2023	2	Combo Fountain	In room 244 self contained classroom		WF-05172022-014218	11/11/2022	FT-FY23-10102022-014218-A	<1	FT-FY23-10102022-014218-B	<1
WS-014220	5/17/2022	5/17/2023	2	Combo Fountain	In room 242 2nd grade classroom		WF-05172022-014220	11/11/2022	FT-FY23-10102022-014220-A	<1	FT-FY23-10102022-014220-B	<1
WS-014222	5/17/2022	5/17/2023	2	Combo Fountain	In room 240 2nd grade classroom		WF-05172022-014222	11/11/2022	FT-FY23-10102022-014222-A	<1	FT-FY23-10102022-014222-B	<1
WS-014223	5/17/2022	5/17/2023	1	Break Room	In room 137 parent resource center		WF-05172022-014223	11/11/2022	FT-FY23-10102022-014223-A	<1	FT-FY23-10102022-014223-B	<1
WS-014224	5/17/2022	5/17/2023	1	Combo Fountain	In room 137 parent resource center		WF-05172022-014224	11/11/2022	FT-FY23-10102022-014224-A	<1	FT-FY23-10102022-014224-B	<1
WS-014225	5/17/2022	5/17/2023	1	Break Room	In room 108 admin workroom		WF-05172022-014225	11/11/2022	FT-FY23-10102022-014225-A	<1	FT-FY23-10102022-014225-B	<1
WS-014226	5/17/2022	5/17/2023	1	Health Suite	In health suite in room 115 treatment		WF-05172022-014226	11/11/2022	FT-FY23-10102022-014226-A	<1	FT-FY23-10102022-014226-B	<1
WS-014235	5/17/2022	5/17/2023	1	Bottle Filler	In cafeteria adjacent to exit		WF-05172022-014235	11/11/2022	FT-FY23-10102022-014235-A	<1	FT-FY23-10102022-014235-B	<1
WS-014236	5/17/2022	5/17/2023	1	Cooler	In cafeteria adjacent to exit	Low Left	WF-05172022-014236	11/11/2022	FT-FY23-10102022-014236-A	<1	FT-FY23-10102022-014236-B	<1
WS-014237	5/17/2022	5/17/2023	1	Cooler	In cafeteria adjacent to exit	High Right	WF-05172022-014237	11/11/2022	FT-FY23-10102022-014237-A	<1	FT-FY23-10102022-014237-B	<1
WS-014238	5/17/2022	5/17/2023	1	Bottle Filler	In gym adjacent to stage ramp		WF-05172022-014238	11/11/2022	FT-FY23-10102022-014238-A	<1	FT-FY23-10102022-014238-B	<1
WS-014239	5/17/2022	5/17/2023	1	Cooler	In gym adjacent to stage ramp	Low Left	WF-05172022-014239	11/11/2022	FT-FY23-10102022-014239-A	<1	FT-FY23-10102022-014239-B	<1
WS-014240	5/17/2022	5/17/2023	1	Cooler	In gym adjacent to stage ramp	High Right	WF-05172022-014240	11/11/2022	FT-FY23-10102022-014240-A	<1	FT-FY23-10102022-014240-B	<1
WS-014241	5/17/2022	5/17/2023	2	Break Room	In room 237 wellness		WF-05172022-014241	11/11/2022	FT-FY23-10102022-014241-A	<1	FT-FY23-10102022-014241-B	<1
WS-014242	5/17/2022	5/17/2023	2	Break Room	In room 238 staff lounge		WF-05172022-014242	11/11/2022	FT-FY23-10102022-014242-A	<1	FT-FY23-10102022-014242-B	<1
WS-014243	5/17/2022	5/17/2023	2	Combo Fountain	In room 238 staff lounge		WF-05172022-014243	11/11/2022	FT-FY23-10102022-014243-A	<1	FT-FY23-10102022-014243-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014233	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen seventh clockwise from entry	WF-02092022-014233	11/11/2022	FT-FY23-10102022-014233-A	<1	FT-FY23-10102022-014233-B	<1