



CW HARRIS ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HARRIS CW ELEMENTARY SCHOOL	WS- 004292	8/21/2016	1	Cooler	In hallway adjacent room 109	FT-82016-004292-A	< 1	FT-82016-004292-B	< 1
2	HARRIS CW ELEMENTARY SCHOOL	WS- 004293	8/21/2016	1	Cooler	In health suite	FT-82016-004293-A	< 1	FT-82016-004293-B	< 1
3	HARRIS CW ELEMENTARY SCHOOL	WS- 004294	8/21/2016	1	Health Suite	In treatment room in health suite	FT-82016-004294-A	< 1	FT-82016-004294-B	1.5
			10/10/2016				Re-test A	< 1	Re-test B	< 1
4	HARRIS CW ELEMENTARY SCHOOL	WS- 004295	8/21/2016	1	Cooler	In multi-purpose room	FT-82016-004295-A	< 1	FT-82016-004295-B	< 1
5	HARRIS CW ELEMENTARY SCHOOL	WS- 004296	8/21/2016	1	Food Prep Sink	In kitchen Right	FT-82016-004296-A	< 1	FT-82016-004296-B	< 1
6	HARRIS CW ELEMENTARY SCHOOL	WS- 004298	8/21/2016	1	Cooler	In hallway across from the custodian office	FT-82016-004298-A	< 1	FT-82016-004298-B	< 1
7	HARRIS CW ELEMENTARY SCHOOL	WS- 004308	8/21/2016	1	Classroom Faucet	In classroom 145	FT-72016-004308-A	< 1	FT-72016-004308-B	< 1
8	HARRIS CW ELEMENTARY SCHOOL	WS- 004314	8/21/2016	2	Cooler	In hallway across from room 218	FT-82016-004314-A	< 1	FT-82016-004314-B	< 1
9	HARRIS CW ELEMENTARY SCHOOL	WS- 004315	8/21/2016	2	Cooler	In hallway across from room 246	FT-82016-004315-A	< 1	FT-82016-004315-B	< 1