



C.W. Harris ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004292	6/29/2017	6/29/2018	1	Cooler	In hallway between restroom and custodial closet	WF-62017-004292	11/16/2017	FT-FY18--62017-004292-A	<1	FT-FY18--62017-004292-B	<1
WS- 004306	10/26/2017	10/26/2018	1	Classroom Faucet	In classroom 143	WF-102017-004306	11/16/2017	FT-FY18-102017-004306-A	<1	FT-FY18-102017-004306-B	<1
WS- 004307	10/26/2017	10/26/2018	1	Classroom Faucet	In classroom 144	WF-102017-004307	11/16/2017	FT-FY18-102017-004307-A	<1	FT-FY18-102017-004307-B	<1
WS- 004313	6/29/2017	6/29/2018	2	Break Room	In staff lounge across from room 222	WF-62017-004313	11/16/2017	FT-FY18--62017-004313-A	<1	FT-FY18--62017-004313-B	<1
WS- 004314	6/29/2017	6/29/2018	2	Cooler	In hallway across from room 218	WF-62017-004314	11/16/2017	FT-FY18--62017-004314-A	<1	FT-FY18--62017-004314-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 004296	1	Food Prep Sink	In kitchen Right	11/16/2017	FT-FY18-102017-004296-A	<1	FT-FY18-102017-004296-B	<1			