



CAPITOL HILL LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000024	Utility	Basement	Basement floor in boiler room(tub sink)	WT-042616-41- A	< 1	WT-042616-41- B	1.4				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000023	Hose Bib	1	Annex building, exterior water spigot north face	WT-042616-40- A	1	WT-042616-40- B	1.4				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000022	Hose Bib	1	Annex building, exterior water spigot south face	WT-042616-39- A	140	WT-042616-39- B	1.8	Non-drinking water source turned off until further analysis complete			
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000021	Bathroom	1	Annex building in womens restroom sink Right	WT-042616-38- A	3.3	WT-042616-38- B	1.2				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000020	Bathroom	1	Annex building in womens restroom sink Mid	WT-042616-37- A	2.1	WT-042616-37- B	1.6				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000019	Bathroom	1	Annex building in womens restroom sink Left	WT-042616-36- A	2	WT-042616-36- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000018	Bathroom	1	Annex building in womens restroom rear sink northeast	WT-042616-35- A	< 1	WT-042616-35- B	1.1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000017	Cooler	1	Annex building water fountain adjacent to staff restroom Left High	WT-042616-34- A	< 1	WT-042616-34- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000016	Cooler	1	Annex building water fountain adjacent to staff restroom Mid Low	WT-042616-33- A	< 1	WT-042616-33- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000015	Cooler	1	Annex building water fountain adjacent to staff restroom Right High	WT-042616-32- A	< 1	WT-042616-32- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000014	Bathroom	1	Annex building in staff restroom	WT-042616-31- A	< 1	WT-042616-31- B	1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000013	Bathroom	1	Annex building in mens bathroom sink Left	WT-042616-30- A	13	WT-042616-30- B	1.5				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000012	Bathroom	1	Annex building in mens bathroom sink Mid	WT-042616-29- A	2.8	WT-042616-29- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000011	Bathroom	1	Annex building in mens bathroom sink Right	WT-042616-28- A	< 1	WT-042616-28- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000010	Classroom	1	Annex building in science lab, storage room	WT-042616-27- A	4.4	WT-042616-27- B	2.1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000009	Classroom	1	Annex building in science lab fifth sink counter clockwise from west door	WT-042516-26- A	13	WT-042516-26- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000008	Classroom	1	Annex building in science lab fourth sink counter clockwise from west door	WT-042516-25- A	4.3	WT-042516-25- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000007	Classroom	1	Annex building in science lab third sink counter clockwise from west door	WT-042516-24- A	1.1	WT-042516-24- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000006	Classroom	1	Annex building in science lab second sink counter clockwise from west door	WT-042516-23- A	13	WT-042516-23- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000005	Classroom	1	Annex building in science lab first sink counter clockwise from west door	WT-042516-22- A	< 1	WT-042516-22- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000004	Break Room	1	Annex building in staff lounge area	WT-042516-21- A	< 1	WT-042516-21- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000098	Other	2	Second floor in classroom 213	WT-042716-115- A	< 1	WT-042716-115- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000097	Other	2	Second floor in classroom 203	WT-042716-114- A	< 1	WT-042716-114- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000096	Other	2	Second floor in classroom 202	WT-042716-113- A	< 1	WT-042716-113- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000095	Other	2	Second floor in classroom 201	WT-042716-112- A	< 1	WT-042716-112- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000094	Other	1	First floor in Classroom 105	WT-042716-111- A	< 1	WT-042716-111- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000093	Other	1	First floor in Classroom 101	WT-042716-110- A	< 1	WT-042716-110- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000092	Other	1	First floor in Classroom 104	WT-042716-109- A	< 1	WT-042716-109- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000091	Other	1	First floor in Classroom 102	WT-042716-108- A	< 1	WT-042716-108- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000090	Other	1	First floor in Classroom 107	WT-042716-107- A	< 1	WT-042716-107- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000089	Other	1	First floor in Classroom 111	WT-042716-106- A	< 1	WT-042716-106- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000088	Other	1	First floor in Classroom 110	WT-042716-105- A	< 1	WT-042716-105- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000087	Other	1	First floor in Classroom 109	WT-042716-104- A	< 1	WT-042716-104- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000085	Bathroom	2	Second floor in womens restroom adjacent to classroom 202 Right	WT-042616-102- A	< 1	WT-042616-102- B	< 1				



CAPITOL HILL LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000084	Classroom	2	Second floor in classroom 201	WT-042616-101- A	< 1	WT-042616-101- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000083	Bathroom	2	Second floor in womens restroom adjacent to classroom 202	WT-042616-100- A	2.6	WT-042616-100- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000082	Fountain	2	Second floor hallway adjacent to classroom 202	WT-042616-99- A	< 1	WT-042616-99- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000081	Fountain	2	Second floor hallway adjacent to classroom 202	WT-042616-98- A	< 1	WT-042616-98- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000080	Utility	2	Second floor men's restroom adjacent to classroom 202(tub sink)	WT-042616-97- A	< 1	WT-042616-97- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000079	Bathroom	2	Second floor in men's restroom adjacent to classroom 202	WT-042616-96- A	< 1	WT-042616-96- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000078	Classroom	2	Second floor in class room 202	WT-042616-95- A	< 1	WT-042616-95- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000077	Bathroom	2	Second floor in mens restroom adjacent to classroom 202	WT-042616-94- A	< 1	WT-042616-94- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000076	Classroom	2	Second floor in classroom 203	WT-042616-93- A	< 1	WT-042616-93- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000075	Utility	2	Second floor in mens restroom adjacent to 212 library(tub sink)	WT-042616-92- A	< 1	WT-042616-92- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000074	Bathroom	2	Second floor in mens restroom adjacent to 212 library	WT-042616-91- A	4.1	WT-042616-91- B	2.7				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000073	Cooler	2	Second floor hallway adjacent to library 212	WT-042616-90- A	< 1	WT-042616-90- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000072	Bathroom	2	Second floor in mens restroom adjacent to 212 library	WT-042616-89- A	1.5	WT-042616-89- B	6.2				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000071	Classroom	2	Second floor in art room 213	WT-042616-88- A	< 1	WT-042616-88- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000070	Classroom	2	Second floor in art room 213 sink	WT-042616-87- A	< 1	WT-042616-87- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000069	Bathroom	2	Second floor womens restroom adjacent to teachers lounge 214	WT-042616-86- A	< 1	WT-042616-86- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000068	Bathroom	2	Second floor in womens restroom adjacent to teachers lounge 214	WT-042616-85- A	1.2	WT-042616-85- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000067	Break Room	2	Second floor in teachers lounge 214	WT-042616-84- A	< 1	WT-042616-84- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000066	Utility	1	First floor in boys restroom adjacent to classroom 101(tub sink)	WT-042616-83- A	44	WT-042616-83- B	1.3	Filter will be installed and then retested			
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000065	Bathroom	1	First floor in boys restroom adjacent to classroom 101	WT-042616-82- A	1	WT-042616-82- B	1.7				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000064	Classroom	1	First floor in classroom 102	WT-042616-81- A	1.4	WT-042616-81- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000063	Bathroom	1	First floor in boys restroom adjacent to classroom 101	WT-042616-80- A	3.9	WT-042616-80- B	3.5				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000062	Cooler	1	First floor hallway adjacent to classroom 101	WT-042616-79- A	< 1	WT-042616-79- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000061	Classroom	1	First floor in classroom 104	WT-042616-78- A	1.2	WT-042616-78- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000060	Bathroom	1	First floor in women's restroom adjacent to classroom 101	WT-042616-77- A	1	WT-042616-77- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000059	Bathroom	1	First floor in womens restroom adjacent to classroom 101	WT-042616-76- A	1.3	WT-042616-76- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000058	Classroom	1	First floor in classroom 101	WT-042616-75- A	< 1	WT-042616-75- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000057	Bathroom	1	First floor in nurse's office 100 (restroom)	WT-042616-74- A	< 1	WT-042616-74- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000056	Other	1	First floor in nurse's office 100 (sink)	WT-042616-73- A	2.2	WT-042616-73- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000055	Classroom	1	First floor in classroom 105	WT-042616-72- A	1	WT-042616-72- B	1.5				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000054	Classroom	1	First floor in classroom 105	WT-042616-71- A	1.2	WT-042616-71- B	1.2				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000053	Bathroom	1	First floor in classroom 103 (nap room) bathroom	WT-042616-70- A	< 1	WT-042616-70- B	1.5				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000052	Bathroom	1	First floor within admin 106 bathroom sink	WT-042616-69- A	2.3	WT-042616-69- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000051	Break Room	1	First floor within admin 106 personnel kitchen	WT-042616-68- A	6.2	WT-042616-68- B	1.2				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000050	Classroom	1	First floor in classroom 111	WT-042616-67- A	< 1	WT-042616-67- B	< 1				



CAPITOL HILL LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000049	Bathroom	1	First floor in girls restroom sink Left Low	WT-042616-66- A	< 1	WT-042616-66- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000048	Bathroom	1	First floor in girls restroom sink Right High	WT-042616-65- A	< 1	WT-042616-65- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000047	Classroom	1	First floor in classroom 110	WT-042616-64- A	< 1	WT-042616-64- B	2.8				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000046	Classroom	1	First floor in classroom 107	WT-042616-63- A	2.5	WT-042616-63- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000045	Utility	1	First floor in boys restroom adjacent to classroom 110 (tub sink)	WT-042616-62- A	< 1	WT-042616-62- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000044	Bathroom	1	First floor in boys restroom adjacent to classroom 110 Left Low	WT-042616-61- A	< 1	WT-042616-61- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000043	Bathroom	1	First floor in boys restroom adjacent to classroom 110 Right High	WT-042616-60- A	1.6	WT-042616-60- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000042	Cooler	1	First floor hallway adjacent to classroom 109	WT-042616-59- A	< 1	WT-042616-59- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000041	Hose Bib	1	Exterior east wing east wall water spigot	WT-042616-58- A	34	WT-042616-58- B	8.7	Non-drinking water source turned off until further analysis complete			
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000040	Hose Bib	1	Exterior east wing north wall water spigot	WT-042616-57- A	6.3	WT-042616-57- B	1.5				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000039	Hose Bib	1	Exterior west wing west wall northern most water spigot	WT-042616-56- A	4.2	WT-042616-56- B	1.6				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000038	Hose Bib	1	Exterior west wing west wall southern most water spigot	WT-042616-55- A	6.3	WT-042616-55- B	1.7				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000037	Classroom	1	First floor in classroom 109	WT-042616-54- A	< 1	WT-042616-54- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000036	Bathroom	1	First floor in classroom 108 restroom Right Low	WT-042616-53- A	< 1	WT-042616-53- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000035	Bathroom	1	First floor in classroom 108 restroom Left High	WT-042616-52- A	1.2	WT-042616-52- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000034	Classroom	1	First floor in classroom 108 (nap room)	WT-042616-51- A	1.1	WT-042616-51- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000033	Bathroom	Basement	Basement floor in head custodians office	WT-042616-50- A	2.6	WT-042616-50- B	1.3				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000032	Bathroom	Basement	Basement floor in custodians office	WT-042616-49- A	5.6	WT-042616-49- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000031	Cooler	Basement	Basement floor inside cafeteria	WT-042616-48- A	< 1	WT-042616-48- B	1.7				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000030	Kitchen	Basement	Basement floor in kitchen - spray nozzle Right	WT-042616-47- A	< 1	WT-042616-47- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000029	Kitchen	Basement	Basement floor in kitchen Mid	WT-042616-46- A	1.4	WT-042616-46- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000028	Kitchen	Basement	Basement floor in kitchen Left	WT-042616-45- A	< 1	WT-042616-45- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000027	Utility	Basement	Basement floor in kitchen adjacent to locker area	WT-042616-44- A	1.1	WT-042616-44- B	< 1				
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000026	Bathroom	Basement	Basement floor in kitchen restroom	WT-042616-43- A	3.1	WT-042616-43- B	1	Device Change			
LOGAN - CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL	4/27/2016	WS- 000025	Fountain	Basement	Basement floor, exterior entry storage area southwest	WT-042616-42- A	< 1	WT-042616-42- B	1.3				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.