



# Capitol Hill Montessori @ Logan Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor    | Device Type    | Device Location                     | Water Filter's Name | Date Analyzed      | 1st Draw - Sample ID      | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID      | FT Final Result - 2nd Draw (ppb) |    |
|-----------|-----------------------|------------------------|----------|----------------|-------------------------------------|---------------------|--------------------|---------------------------|----------------------------------|---------------------------|----------------------------------|----|
| WS-001269 | 2/20/2024             | 2/20/2025              | Basement | Health Suite   | In wellness room B107               | WF-02202024-001269  | 12/31/2024         | FT-FY25-11082024-001269-A | <2                               | FT-FY25-11082024-001269-B | <2                               |    |
| WS-001271 | 2/20/2024             | 2/20/2025              | Basement | Bottle Filler  | In hallway adjacent to B111         | WF-02202024-001271  | 12/31/2024         | FT-FY25-11082024-001271-A | <2                               | FT-FY25-11082024-001271-B | <2                               |    |
| WS-001272 | 2/20/2024             | 2/20/2025              | Basement | Cooler         | In hallway adjacent to B111         | High Left           | WF-02202024-001272 | 12/31/2024                | FT-FY25-11082024-001272-A        | <2                        | FT-FY25-11082024-001272-B        | <2 |
| WS-001273 | 2/20/2024             | 2/20/2025              | Basement | Cooler         | In hallway adjacent to B111         | Low Right           | WF-02202024-001273 | 12/31/2024                | FT-FY25-11082024-001273-A        | <2                        | FT-FY25-11082024-001273-B        | <2 |
| WS-001274 | 2/20/2024             | 2/20/2025              | Basement | Break Room     | In staff lounge B113                |                     | WF-02202024-001274 | 12/31/2024                | FT-FY25-11082024-001274-A        | <2                        | FT-FY25-11082024-001274-B        | <2 |
| WS-001276 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In MS tech lab 103                  | Left                | WF-02202024-001276 | 12/31/2024                | FT-FY25-11082024-001276-A        | <2                        | FT-FY25-11082024-001276-B        | <2 |
| WS-001278 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In MS tech lab 103                  | Right               | WF-02202024-001278 | 12/31/2024                | FT-FY25-11082024-001278-A        | <2                        | FT-FY25-11082024-001278-B        | <2 |
| WS-001279 | 2/20/2024             | 2/20/2025              | 1        | Bottle Filler  | In hallway adjacent to 108          |                     | WF-02202024-001279 | 12/31/2024                | FT-FY25-11082024-001279-A        | <2                        | FT-FY25-11082024-001279-B        | <2 |
| WS-001282 | 2/20/2024             | 2/20/2025              | 1        | Cooler         | In hallway adjacent to 108          | High Left           | WF-02202024-001282 | 12/31/2024                | FT-FY25-11082024-001282-A        | <2                        | FT-FY25-11082024-001282-B        | <2 |
| WS-001283 | 2/20/2024             | 2/20/2025              | 1        | Cooler         | In hallway adjacent to 108          | Low Right           | WF-02202024-001283 | 12/31/2024                | FT-FY25-11082024-001283-A        | <2                        | FT-FY25-11082024-001283-B        | <2 |
| WS-001284 | 2/20/2024             | 2/20/2025              | 1        | Break Room     | In teacher collaboration room 111   |                     | WF-02202024-001284 | 12/31/2024                | FT-FY25-11082024-001284-A        | <2                        | FT-FY25-11082024-001284-B        | <2 |
| WS-001285 | 2/20/2024             | 2/20/2025              | 1        | Health Suite   | In health suite treatment room 110C |                     | WF-02202024-001285 | 12/31/2024                | FT-FY25-11082024-001285-A        | <2                        | FT-FY25-11082024-001285-B        | <2 |
| WS-001287 | 2/20/2024             | 2/20/2025              | 1        | Combo Faucet   | In classroom 125                    |                     | WF-02202024-001287 | 12/31/2024                | FT-FY25-11082024-001287-A        | <2                        | FT-FY25-11082024-001287-B        | <2 |
| WS-001288 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In classroom 125                    |                     | WF-02202024-001288 | 12/31/2024                | FT-FY25-11082024-001288-A        | <2                        | FT-FY25-11082024-001288-B        | <2 |
| WS-001289 | 2/20/2024             | 2/20/2025              | 1        | Combo Faucet   | In classroom 124                    |                     | WF-02202024-001289 | 12/31/2024                | FT-FY25-11082024-001289-A        | <2                        | FT-FY25-11082024-001289-B        | <2 |
| WS-001290 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In classroom 124                    |                     | WF-02202024-001290 | 12/31/2024                | FT-FY25-11082024-001290-A        | <2                        | FT-FY25-11082024-001290-B        | <2 |
| WS-001291 | 2/20/2024             | 2/20/2025              | 1        | Bottle Filler  | In hallway adjacent to 124A         |                     | WF-02202024-001291 | 12/31/2024                | FT-FY25-11082024-001291-A        | <2                        | FT-FY25-11082024-001291-B        | <2 |
| WS-001292 | 2/20/2024             | 2/20/2025              | 1        | Cooler         | In hallway adjacent to 124A         | High Left           | WF-02202024-001292 | 12/31/2024                | FT-FY25-11082024-001292-A        | <2                        | FT-FY25-11082024-001292-B        | <2 |
| WS-001293 | 2/20/2024             | 2/20/2025              | 1        | Cooler         | In hallway adjacent to 124A         | Low Right           | WF-02202024-001293 | 12/31/2024                | FT-FY25-11082024-001293-A        | <2                        | FT-FY25-11082024-001293-B        | <2 |
| WS-001294 | 2/20/2024             | 2/20/2025              | 1        | Combo Faucet   | In classroom 142                    |                     | WF-02202024-001294 | 12/31/2024                | FT-FY25-11082024-001294-A        | <2                        | FT-FY25-11082024-001294-B        | <2 |
| WS-001295 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In classroom 142                    |                     | WF-02202024-001295 | 12/31/2024                | FT-FY25-11082024-001295-A        | <2                        | FT-FY25-11082024-001295-B        | <2 |
| WS-001296 | 2/20/2024             | 2/20/2025              | 1        | Combo Faucet   | In classroom 141                    |                     | WF-02202024-001296 | 12/31/2024                | FT-FY25-11082024-001296-A        | <2                        | FT-FY25-11082024-001296-B        | <2 |
| WS-001297 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In classroom 141                    |                     | WF-02202024-001297 | 12/31/2024                | FT-FY25-11082024-001297-A        | <2                        | FT-FY25-11082024-001297-B        | <2 |
| WS-001404 | 2/20/2024             | 2/20/2025              | 1        | Bottle Filler  | In hallway adjacent to 154          |                     | WF-02202024-001404 | 12/31/2024                | FT-FY25-11082024-001404-A        | <2                        | FT-FY25-11082024-001404-B        | <2 |
| WS-001405 | 2/20/2024             | 2/20/2025              | 1        | Cooler         | In hallway adjacent to 154          | High Left           | WF-02202024-001405 | 12/31/2024                | FT-FY25-11082024-001405-A        | <2                        | FT-FY25-11082024-001405-B        | <2 |
| WS-001406 | 2/20/2024             | 2/20/2025              | 1        | Cooler         | In hallway adjacent to 154          | Low Right           | WF-02202024-001406 | 12/31/2024                | FT-FY25-11082024-001406-A        | <2                        | FT-FY25-11082024-001406-B        | <2 |
| WS-001407 | 2/20/2024             | 2/20/2025              | 1        | Combo Faucet   | In classroom 153                    |                     | WF-02202024-001407 | 12/31/2024                | FT-FY25-11082024-001407-A        | <2                        | FT-FY25-11082024-001407-B        | <2 |
| WS-001408 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In classroom 153                    |                     | WF-02202024-001408 | 12/31/2024                | FT-FY25-11082024-001408-A        | <2                        | FT-FY25-11082024-001408-B        | <2 |
| WS-001409 | 2/20/2024             | 2/20/2025              | 1        | Combo Faucet   | In classroom 147                    |                     | WF-02202024-001409 | 12/31/2024                | FT-FY25-11082024-001409-A        | <2                        | FT-FY25-11082024-001409-B        | <2 |
| WS-001410 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In classroom 147                    |                     | WF-02202024-001410 | 12/31/2024                | FT-FY25-11082024-001410-A        | <2                        | FT-FY25-11082024-001410-B        | <2 |
| WS-001412 | 2/20/2024             | 2/20/2025              | 1        | Break Room     | In teacher collaboration room 152   |                     | WF-02202024-001412 | 12/31/2024                | FT-FY25-11082024-001412-A        | <2                        | FT-FY25-11082024-001412-B        | <2 |
| WS-001413 | 2/20/2024             | 2/20/2025              | 1        | Combo Faucet   | In classroom 144                    |                     | WF-02202024-001413 | 12/31/2024                | FT-FY25-11082024-001413-A        | <2                        | FT-FY25-11082024-001413-B        | <2 |
| WS-001414 | 2/20/2024             | 2/20/2025              | 1        | Combo Fountain | In classroom 144                    |                     | WF-02202024-001414 | 12/31/2024                | FT-FY25-11082024-001414-A        | <2                        | FT-FY25-11082024-001414-B        | <2 |

|           |           |           |   |                |                                |           |                    |            |                           |    |                           |    |
|-----------|-----------|-----------|---|----------------|--------------------------------|-----------|--------------------|------------|---------------------------|----|---------------------------|----|
| WS-001415 | 2/20/2024 | 2/20/2025 | 1 | Combo Faucet   | In classroom 143               |           | WF-02202024-001415 | 12/31/2024 | FT-FY25-11082024-001415-A | <2 | FT-FY25-11082024-001415-B | <2 |
| WS-001416 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 143               |           | WF-02202024-001416 | 12/31/2024 | FT-FY25-11082024-001416-A | <2 | FT-FY25-11082024-001416-B | <2 |
| WS-001419 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 139               |           | WF-02202024-001419 | 12/31/2024 | FT-FY25-11082024-001419-A | <2 | FT-FY25-11082024-001419-B | <2 |
| WS-001421 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 136               |           | WF-02202024-001421 | 12/31/2024 | FT-FY25-11082024-001421-A | <2 | FT-FY25-11082024-001421-B | <2 |
| WS-001423 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 137               |           | WF-02202024-001423 | 12/31/2024 | FT-FY25-11082024-001423-A | <2 | FT-FY25-11082024-001423-B | <2 |
| WS-001425 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 134               |           | WF-02202024-001425 | 12/31/2024 | FT-FY25-11082024-001425-A | <2 | FT-FY25-11082024-001425-B | <2 |
| WS-001427 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 129               |           | WF-02202024-001427 | 12/31/2024 | FT-FY25-11082024-001427-A | <2 | FT-FY25-11082024-001427-B | <2 |
| WS-001429 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 128               |           | WF-02202024-001429 | 12/31/2024 | FT-FY25-11082024-001429-A | <2 | FT-FY25-11082024-001429-B | <2 |
| WS-001431 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In classroom 127               |           | WF-02202024-001431 | 12/31/2024 | FT-FY25-11082024-001431-A | <2 | FT-FY25-11082024-001431-B | <2 |
| WS-001432 | 2/20/2024 | 2/20/2025 | 1 | Bottle Filler  | In hallway adjacent to 133     |           | WF-02202024-001432 | 12/31/2024 | FT-FY25-11082024-001432-A | <2 | FT-FY25-11082024-001432-B | <2 |
| WS-001437 | 2/20/2024 | 2/20/2025 | 1 | Combo Fountain | In library room 101F           |           | WF-02202024-001437 | 12/31/2024 | FT-FY25-11082024-001437-A | <2 | FT-FY25-11082024-001437-B | <2 |
| WS-001439 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 206               |           | WF-02202024-001439 | 12/31/2024 | FT-FY25-11082024-001439-A | <2 | FT-FY25-11082024-001439-B | <2 |
| WS-001441 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 207               |           | WF-02202024-001441 | 12/31/2024 | FT-FY25-11082024-001441-A | <2 | FT-FY25-11082024-001441-B | <2 |
| WS-001445 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 211               |           | WF-02202024-001445 | 12/31/2024 | FT-FY25-11082024-001445-A | <2 | FT-FY25-11082024-001445-B | <2 |
| WS-001446 | 2/20/2024 | 2/20/2025 | 2 | Bottle Filler  | In hallway adjacent to 211     |           | WF-02202024-001446 | 12/31/2024 | FT-FY25-11082024-001446-A | <2 | FT-FY25-11082024-001446-B | <2 |
| WS-001447 | 2/20/2024 | 2/20/2025 | 2 | Cooler         | In hallway adjacent to 211     | High Left | WF-02202024-001447 | 12/31/2024 | FT-FY25-11082024-001447-A | <2 | FT-FY25-11082024-001447-B | <2 |
| WS-001448 | 2/20/2024 | 2/20/2025 | 2 | Cooler         | In hallway adjacent to 211     | Low Right | WF-02202024-001448 | 12/31/2024 | FT-FY25-11082024-001448-A | <2 | FT-FY25-11082024-001448-B | <2 |
| WS-001509 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 214               |           | WF-02202024-001509 | 12/31/2024 | FT-FY25-11082024-001509-A | <2 | FT-FY25-11082024-001509-B | <2 |
| WS-001511 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 215               |           | WF-02202024-001511 | 12/31/2024 | FT-FY25-11082024-001511-A | <2 | FT-FY25-11082024-001511-B | <2 |
| WS-001518 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In science lab prep room 219A  |           | WF-02202024-001518 | 12/31/2024 | FT-FY25-11082024-001518-A | <2 | FT-FY25-11082024-001518-B | <2 |
| WS-001524 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 232               |           | WF-02202024-001524 | 12/31/2024 | FT-FY25-11082024-001524-A | <2 | FT-FY25-11082024-001524-B | <2 |
| WS-001527 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 233               |           | WF-02202024-001527 | 12/31/2024 | FT-FY25-11082024-001527-A | <2 | FT-FY25-11082024-001527-B | <2 |
| WS-001529 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 234               |           | WF-02202024-001529 | 12/31/2024 | FT-FY25-11082024-001529-A | <2 | FT-FY25-11082024-001529-B | <2 |
| WS-001535 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 241               |           | WF-02202024-001535 | 12/31/2024 | FT-FY25-11082024-001535-A | <2 | FT-FY25-11082024-001535-B | <2 |
| WS-001537 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 240               |           | WF-02202024-001537 | 12/31/2024 | FT-FY25-11082024-001537-A | <2 | FT-FY25-11082024-001537-B | <2 |
| WS-001538 | 2/20/2024 | 2/20/2025 | 2 | Bottle Filler  | In hallway adjacent to 239     |           | WF-02202024-001538 | 12/31/2024 | FT-FY25-11082024-001538-A | <2 | FT-FY25-11082024-001538-B | <2 |
| WS-001539 | 2/20/2024 | 2/20/2025 | 2 | Cooler         | In hallway adjacent to 239     | High Left | WF-02202024-001539 | 12/31/2024 | FT-FY25-11082024-001539-A | <2 | FT-FY25-11082024-001539-B | <2 |
| WS-001540 | 2/20/2024 | 2/20/2025 | 2 | Cooler         | In hallway adjacent to 239     | Low Right | WF-02202024-001540 | 12/31/2024 | FT-FY25-11082024-001540-A | <2 | FT-FY25-11082024-001540-B | <2 |
| WS-001542 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 238               |           | WF-02202024-001542 | 12/31/2024 | FT-FY25-11082024-001542-A | <2 | FT-FY25-11082024-001542-B | <2 |
| WS-001545 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 236               |           | WF-02202024-001545 | 12/31/2024 | FT-FY25-11082024-001545-A | <2 | FT-FY25-11082024-001545-B | <2 |
| WS-001552 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 220               | Left      | WF-02202024-001552 | 12/31/2024 | FT-FY25-11082024-001552-A | <2 | FT-FY25-11082024-001552-B | <2 |
| WS-001554 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 220               | Right     | WF-02202024-001554 | 12/31/2024 | FT-FY25-11082024-001554-A | <2 | FT-FY25-11082024-001554-B | <2 |
| WS-001556 | 2/20/2024 | 2/20/2025 | 2 | Combo Fountain | In classroom 221               |           | WF-02202024-001556 | 12/31/2024 | FT-FY25-11082024-001556-A | <2 | FT-FY25-11082024-001556-B | <2 |
| WS-001557 | 2/20/2024 | 2/20/2025 | 3 | Bottle Filler  | In stairwell 7 adjacent to 300 |           | WF-02202024-001557 | 12/31/2024 | FT-FY25-11082024-001557-A | <2 | FT-FY25-11082024-001557-B | <2 |
| WS-001558 | 2/20/2024 | 2/20/2025 | 3 | Cooler         | In stairwell 7 adjacent to 300 | High Left | WF-02202024-001558 | 12/31/2024 | FT-FY25-11082024-001558-A | <2 | FT-FY25-11082024-001558-B | <2 |
| WS-001559 | 2/20/2024 | 2/20/2025 | 3 | Cooler         | In stairwell 7 adjacent to 300 | Low Right | WF-02202024-001559 | 12/31/2024 | FT-FY25-11082024-001559-A | <2 | FT-FY25-11082024-001559-B | <2 |

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

| Record ID  | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location                     | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID      | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID      | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|-------|----------------|-------------------------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| WS- 001286 | 12/23/2024            | 12/23/2025             | 1     | Food Prep Sink | In pantry space 123                 | WF-12232024-001286  | 12/31/2024    | FT-FY25-11082024-001286-A | <2                               | FT-FY25-11082024-001286-B | <2                               |
| WS- 001395 | 12/23/2024            | 12/23/2025             | 1     | Food Prep Sink | In pantry space 138                 | WF-12232024-001395  | 12/31/2024    | FT-FY25-11082024-001395-A | <2                               | FT-FY25-11082024-001395-B | <2                               |
| WS- 001397 | 12/23/2024            | 12/23/2025             | 1     | Food Prep Sink | In kitchen 2nd clockwise from entry | WF-12232024-001397  | 12/31/2024    | FT-FY25-11082024-001397-A | <2                               | FT-FY25-11082024-001397-B | <2                               |
| WS- 001411 | 12/23/2024            | 12/23/2025             | 1     | Food Prep Sink | In pantry area 151                  | WF-12232024-001411  | 12/31/2024    | FT-FY25-11082024-001411-A | <2                               | FT-FY25-11082024-001411-B | <2                               |
| WS- 001417 | 12/23/2024            | 12/23/2025             | 1     | Food Prep Sink | In pantry area 145                  | WF-12232024-001417  | 12/31/2024    | FT-FY25-11082024-001417-A | <2                               | FT-FY25-11082024-001417-B | <2                               |
| WS- 001435 | 12/23/2024            | 12/23/2025             | 1     | Food Prep Sink | In pantry area 131                  | WF-12232024-001435  | 12/31/2024    | FT-FY25-11082024-001435-A | <2                               | FT-FY25-11082024-001435-B | <2                               |
| WS- 001512 | 12/23/2024            | 12/23/2025             | 2     | Food Prep Sink | In pantry area 216                  | WF-12232024-001512  | 12/31/2024    | FT-FY25-11082024-001512-A | <2                               | FT-FY25-11082024-001512-B | <2                               |
| WS- 001525 | 12/23/2024            | 12/23/2025             | 2     | Food Prep Sink | In pantry area 230C                 | WF-12232024-001525  | 12/31/2024    | FT-FY25-11082024-001525-A | <2                               | FT-FY25-11082024-001525-B | <2                               |
| WS- 001533 | 12/23/2024            | 12/23/2025             | 2     | Food Prep Sink | In pantry area 239                  | WF-12232024-001533  | 12/31/2024    | FT-FY25-11082024-001533-A | <2                               | FT-FY25-11082024-001533-B | <2                               |
| WS- 001543 | 12/23/2024            | 12/23/2025             | 2     | Food Prep Sink | In pantry area 237                  | WF-12232024-001543  | 12/31/2024    | FT-FY25-11082024-001543-A | <2                               | FT-FY25-11082024-001543-B | <2                               |

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.