



# Capitol Hill Montessori @ Logan Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001269	3/1/2022	3/1/2023	Basement	Health Suite	In wellness room B107	WF-03012022-001269	11/16/2022	FT-FY23-11042022-001269-A	<1	FT-FY23-11042022-001269-B	<1	
WS-001271	3/1/2022	3/1/2023	Basement	Bottle Filler	In hallway adjacent to B111	WF-03012022-001271	11/16/2022	FT-FY23-11042022-001271-A	<1	FT-FY23-11042022-001271-B	<1	
WS-001272	3/1/2022	3/1/2023	Basement	Cooler	In hallway adjacent to B111	High Left	WF-03012022-001272	11/16/2022	FT-FY23-11042022-001272-A	<1	FT-FY23-11042022-001272-B	<1
WS-001273	3/1/2022	3/1/2023	Basement	Cooler	In hallway adjacent to B111	Low Right	WF-03012022-001273	11/16/2022	FT-FY23-11042022-001273-A	<1	FT-FY23-11042022-001273-B	<1
WS-001274	3/1/2022	3/1/2023	Basement	Break Room	In staff lounge B113	WF-03012022-001274	11/16/2022	FT-FY23-11042022-001274-A	<1	FT-FY23-11042022-001274-B	<1	
WS-001276	3/1/2022	3/1/2023	1	Combo Fountain	In MS tech lab 103	Left	WF-03012022-001276	11/16/2022	FT-FY23-11042022-001276-A	<1	FT-FY23-11042022-001276-B	<1
WS-001278	3/1/2022	3/1/2023	1	Combo Fountain	In MS tech lab 103	Right	WF-03012022-001278	11/16/2022	FT-FY23-11042022-001278-A	<1	FT-FY23-11042022-001278-B	<1
WS-001279	3/1/2022	3/1/2023	1	Bottle Filler	In hallway adjacent to 108	WF-03012022-001279	11/16/2022	FT-FY23-11042022-001279-A	<1	FT-FY23-11042022-001279-B	<1	
WS-001282	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 108	High Left	WF-03012022-001282	11/16/2022	FT-FY23-11042022-001282-A	<1	FT-FY23-11042022-001282-B	<1
WS-001283	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 108	Low Right	WF-03012022-001283	11/16/2022	FT-FY23-11042022-001283-A	<1	FT-FY23-11042022-001283-B	<1
WS-001284	3/1/2022	3/1/2023	1	Break Room	In teacher collaboration room 111	WF-03012022-001284	11/16/2022	FT-FY23-11042022-001284-A	<1	FT-FY23-11042022-001284-B	<1	
WS-001285	3/1/2022	3/1/2023	1	Health Suite	In health suite treatment room 110C	WF-03012022-001285	11/16/2022	FT-FY23-11042022-001285-A	<1	FT-FY23-11042022-001285-B	<1	
WS-001287	3/1/2022	3/1/2023	1	Combo Faucet	In classroom 125	WF-03012022-001287	11/16/2022	FT-FY23-11042022-001287-A	<1	FT-FY23-11042022-001287-B	<1	
WS-001289	3/1/2022	3/1/2023	1	Combo Faucet	In classroom 124	WF-03012022-001289	11/16/2022	FT-FY23-11042022-001289-A	<1	FT-FY23-11042022-001289-B	<1	
WS-001291	3/1/2022	3/1/2023	1	Bottle Filler	In hallway adjacent to 124A	WF-03012022-001291	11/16/2022	FT-FY23-11042022-001291-A	<1	FT-FY23-11042022-001291-B	<1	
WS-001292	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 124A	High Left	WF-03012022-001292	11/16/2022	FT-FY23-11042022-001292-A	<1	FT-FY23-11042022-001292-B	<1
WS-001293	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 124A	Low Right	WF-03012022-001293	11/16/2022	FT-FY23-11042022-001293-A	<1	FT-FY23-11042022-001293-B	<1
WS-001294	3/1/2022	3/1/2023	1	Combo Faucet	In classroom 142	WF-03012022-001294	11/16/2022	FT-FY23-11042022-001294-A	<1	FT-FY23-11042022-001294-B	<1	
WS-001296	3/1/2022	3/1/2023	1	Combo Faucet	In classroom 141	WF-03012022-001296	11/16/2022	FT-FY23-11042022-001296-A	<1	FT-FY23-11042022-001296-B	<1	
WS-001298	3/1/2022	3/1/2023	1	Bottle Filler	In hallway adjacent to 141B	WF-03012022-001298	11/16/2022	FT-FY23-11042022-001298-A	<1	FT-FY23-11042022-001298-B	<1	
WS-001393	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 141B	High Left	WF-03012022-001393	11/16/2022	FT-FY23-11042022-001393-A	<1	FT-FY23-11042022-001393-B	<1
WS-001394	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 141B	Low Right	WF-03012022-001394	11/16/2022	FT-FY23-11042022-001394-A	<1	FT-FY23-11042022-001394-B	<1
WS-001404	3/1/2022	3/1/2023	1	Bottle Filler	In hallway adjacent to 154	WF-03012022-001404	11/16/2022	FT-FY23-11042022-001404-A	<1	FT-FY23-11042022-001404-B	<1	
WS-001405	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 154	High Left	WF-03012022-001405	11/16/2022	FT-FY23-11042022-001405-A	<1	FT-FY23-11042022-001405-B	<1
WS-001406	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 154	Low Right	WF-03012022-001406	11/16/2022	FT-FY23-11042022-001406-A	<1	FT-FY23-11042022-001406-B	<1
WS-001412	3/1/2022	3/1/2023	1	Break Room	In teacher collaboration room 152	WF-03012022-001412	11/16/2022	FT-FY23-11042022-001412-A	<1	FT-FY23-11042022-001412-B	<1	
WS-001413	3/1/2022	3/1/2023	1	Combo Faucet	In classroom 144	WF-03012022-001413	11/16/2022	FT-FY23-11042022-001413-A	<1	FT-FY23-11042022-001413-B	<1	
WS-001415	3/1/2022	3/1/2023	1	Combo Faucet	In classroom 143	WF-03012022-001415	11/16/2022	FT-FY23-11042022-001415-A	<1	FT-FY23-11042022-001415-B	<1	
WS-001427	3/1/2022	3/1/2023	1	Combo Fountain	In classroom 129	WF-03012022-001427	11/16/2022	FT-FY23-11042022-001427-A	<1	FT-FY23-11042022-001427-B	<1	
WS-001432	3/1/2022	3/1/2023	1	Bottle Filler	In hallway adjacent to 133	WF-03012022-001432	11/16/2022	FT-FY23-11042022-001432-A	<1	FT-FY23-11042022-001432-B	<1	
WS-001433	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 133	High Left	WF-03012022-001433	11/16/2022	FT-FY23-11042022-001433-A	<1	FT-FY23-11042022-001433-B	<1
WS-001434	3/1/2022	3/1/2023	1	Cooler	In hallway adjacent to 133	Low Right	WF-03012022-001434	11/16/2022	FT-FY23-11042022-001434-A	<1	FT-FY23-11042022-001434-B	<1
WS-001446	3/1/2022	3/1/2023	2	Bottle Filler	In hallway adjacent to 211	WF-03012022-001446	11/16/2022	FT-FY23-11042022-001446-A	<1	FT-FY23-11042022-001446-B	<1	
WS-001447	3/1/2022	3/1/2023	2	Cooler	In hallway adjacent to 211	High Left	WF-03012022-001447	11/16/2022	FT-FY23-11042022-001447-A	<1	FT-FY23-11042022-001447-B	<1
WS-001448	3/1/2022	3/1/2023	2	Cooler	In hallway adjacent to 211	Low Right	WF-03012022-001448	11/16/2022	FT-FY23-11042022-001448-A	<1	FT-FY23-11042022-001448-B	<1

WS- 001530	3/1/2022	3/1/2023	2	Bottle Filler	In gym 243		WF-03012022-001530	11/16/2022	FT-FY23-11042022-001530-A	<1	FT-FY23-11042022-001530-B	<1
WS- 001531	3/1/2022	3/1/2023	2	Cooler	In gym 243	High Left	WF-03012022-001531	11/16/2022	FT-FY23-11042022-001531-A	<1	FT-FY23-11042022-001531-B	<1
WS- 001532	3/1/2022	3/1/2023	2	Cooler	In gym 243	Low Right	WF-03012022-001532	11/16/2022	FT-FY23-11042022-001532-A	<1	FT-FY23-11042022-001532-B	<1
WS- 001538	3/1/2022	3/1/2023	2	Bottle Filler	In hallway adjacent to 239		WF-03012022-001538	11/16/2022	FT-FY23-11042022-001538-A	<1	FT-FY23-11042022-001538-B	<1
WS- 001539	3/1/2022	3/1/2023	2	Cooler	In hallway adjacent to 239	High Left	WF-03012022-001539	11/16/2022	FT-FY23-11042022-001539-A	<1	FT-FY23-11042022-001539-B	<1
WS- 001540	3/1/2022	3/1/2023	2	Cooler	In hallway adjacent to 239	Low Right	WF-03012022-001540	11/16/2022	FT-FY23-11042022-001540-A	<1	FT-FY23-11042022-001540-B	<1
WS- 001548	3/1/2022	3/1/2023	2	Bottle Filler	In hallway adjacent to 223		WF-03012022-001548	11/16/2022	FT-FY23-11042022-001548-A	<1	FT-FY23-11042022-001548-B	<1
WS- 001549	3/1/2022	3/1/2023	2	Cooler	In hallway adjacent to 223	High Left	WF-03012022-001549	11/16/2022	FT-FY23-11042022-001549-A	<1	FT-FY23-11042022-001549-B	<1
WS- 001550	3/1/2022	3/1/2023	2	Cooler	In hallway adjacent to 223	Low Right	WF-03012022-001550	11/16/2022	FT-FY23-11042022-001550-A	<1	FT-FY23-11042022-001550-B	<1
WS- 001557	3/1/2022	3/1/2023	3	Bottle Filler	In stairwell 7 adjacent to 300		WF-03012022-001557	11/16/2022	FT-FY23-11042022-001557-A	<1	FT-FY23-11042022-001557-B	<1
WS- 001558	3/1/2022	3/1/2023	3	Cooler	In stairwell 7 adjacent to 300	High Left	WF-03012022-001558	11/16/2022	FT-FY23-11042022-001558-A	<1	FT-FY23-11042022-001558-B	<1
WS- 001559	3/1/2022	3/1/2023	3	Cooler	In stairwell 7 adjacent to 300	Low Right	WF-03012022-001559	11/16/2022	FT-FY23-11042022-001559-A	<1	FT-FY23-11042022-001559-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001286	2/18/2022	2/18/2023	1	Food Prep Sink	In pantry space 123	WF-02182022-001286	11/16/2022	FT-FY23-11042022-001286-A	<1	FT-FY23-11042022-001286-B	<1
WS- 001395	2/18/2022	2/18/2023	1	Food Prep Sink	In pantry space 138	WF-02182022-001395	11/16/2022	FT-FY23-11042022-001395-A	<1	FT-FY23-11042022-001395-B	<1
WS- 001397	2/18/2022	2/18/2023	1	Food Prep Sink	In kitchen 2nd clockwise from entry	WF-02182022-001397	11/16/2022	FT-FY23-11042022-001397-A	<1	FT-FY23-11042022-001397-B	<1
WS- 001411	2/18/2022	2/18/2023	1	Food Prep Sink	In pantry area 151	WF-02182022-001411	11/16/2022	FT-FY23-11042022-001411-A	<1	FT-FY23-11042022-001411-B	<1
WS- 001417	2/18/2022	2/18/2023	1	Food Prep Sink	In pantry area 145	WF-02182022-001417	11/16/2022	FT-FY23-11042022-001417-A	<1	FT-FY23-11042022-001417-B	<1
WS- 001435	2/18/2022	2/18/2023	1	Food Prep Sink	In pantry area 131	WF-02182022-001435	11/16/2022	FT-FY23-11042022-001435-A	<1	FT-FY23-11042022-001435-B	<1
WS- 001512	2/18/2022	2/18/2023	2	Food Prep Sink	In pantry area 216	WF-02182022-001512	11/16/2022	FT-FY23-11042022-001512-A	<1	FT-FY23-11042022-001512-B	<1
WS- 001525	2/18/2022	2/18/2023	2	Food Prep Sink	In pantry area 230C	WF-02182022-001525	11/16/2022	FT-FY23-11042022-001525-A	<1	FT-FY23-11042022-001525-B	<1
WS- 001533	2/18/2022	2/18/2023	2	Food Prep Sink	In pantry area 239	WF-02182022-001533	11/16/2022	FT-FY23-11042022-001533-A	<1	FT-FY23-11042022-001533-B	<1
WS- 001543	2/18/2022	2/18/2023	2	Food Prep Sink	In pantry area 237	WF-02182022-001543	11/16/2022	FT-FY23-11042022-001543-A	<1	FT-FY23-11042022-001543-B	<1