



Capitol Hill Montessori @Logan Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001269	2/21/2023	2/21/2024	Basement	Health Suite	In wellness room B107	WF-02212023-001269	1/28/2024	FT-FY24-11012023-001269-A	<1	FT-FY24-11012023-001269-B	<1	
WS-001270	2/21/2023	2/21/2024	Basement	Combo Fountain	In wellness room B107	WF-02212023-001270	1/28/2024	FT-FY24-11012023-001270-A	<1	FT-FY24-11012023-001270-B	<1	
WS-001274	2/21/2023	2/21/2024	Basement	Break Room	In staff lounge B113	WF-02212023-001274	1/28/2024	FT-FY24-11012023-001274-A	<1	FT-FY24-11012023-001274-B	<1	
WS-001279	2/21/2023	2/21/2024	1	Bottle Filler	In hallway adjacent to 108	WF-02212023-001279	1/28/2024	FT-FY24-11012023-001279-A	<1	FT-FY24-11012023-001279-B	<1	
WS-001282	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 108	High Left	WF-02212023-001282	1/28/2024	FT-FY24-11012023-001282-A	<1	FT-FY24-11012023-001282-B	<1
WS-001283	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 108	Low Right	WF-02212023-001283	1/28/2024	FT-FY24-11012023-001283-A	<1	FT-FY24-11012023-001283-B	<1
WS-001284	2/21/2023	2/21/2024	1	Break Room	In teacher collaboration room 111	WF-02212023-001284	1/28/2024	FT-FY24-11012023-001284-A	<1	FT-FY24-11012023-001284-B	<1	
WS-001285	2/21/2023	2/21/2024	1	Health Suite	In health suite treatment room 110C	WF-02212023-001285	1/28/2024	FT-FY24-11012023-001285-A	<1	FT-FY24-11012023-001285-B	<1	
WS-001287	2/21/2023	2/21/2024	1	Combo Faucet	In classroom 125	WF-02212023-001287	1/28/2024	FT-FY24-11012023-001287-A	<1	FT-FY24-11012023-001287-B	<1	
WS-001288	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 125	WF-02212023-001288	1/28/2024	FT-FY24-11012023-001288-A	<1	FT-FY24-11012023-001288-B	<1	
WS-001289	2/21/2023	2/21/2024	1	Combo Faucet	In classroom 124	WF-02212023-001289	1/28/2024	FT-FY24-11012023-001289-A	<1	FT-FY24-11012023-001289-B	<1	
WS-001290	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 124	WF-02212023-001290	1/28/2024	FT-FY24-11012023-001290-A	<1	FT-FY24-11012023-001290-B	<1	
WS-001291	2/21/2023	2/21/2024	1	Bottle Filler	In hallway adjacent to 124A	WF-02212023-001291	1/28/2024	FT-FY24-11012023-001291-A	<1	FT-FY24-11012023-001291-B	<1	
WS-001292	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 124A	High Left	WF-02212023-001292	1/28/2024	FT-FY24-11012023-001292-A	<1	FT-FY24-11012023-001292-B	<1
WS-001293	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 124A	Low Right	WF-02212023-001293	1/28/2024	FT-FY24-11012023-001293-A	<1	FT-FY24-11012023-001293-B	<1
WS-001294	2/21/2023	2/21/2024	1	Combo Faucet	In classroom 142	WF-02212023-001294	1/28/2024	FT-FY24-11012023-001294-A	<1	FT-FY24-11012023-001294-B	<1	
WS-001295	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 142	WF-02212023-001295	1/28/2024	FT-FY24-11012023-001295-A	<1	FT-FY24-11012023-001295-B	<1	
WS-001394	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 141B	Low Right	WF-02212023-001394	1/28/2024	FT-FY24-11012023-001394-A	<1	FT-FY24-11012023-001394-B	<1
WS-001404	2/21/2023	2/21/2024	1	Bottle Filler	In hallway adjacent to 154	WF-02212023-001404	1/28/2024	FT-FY24-11012023-001404-A	<1	FT-FY24-11012023-001404-B	<1	
WS-001405	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 154	High Left	WF-02212023-001405	1/28/2024	FT-FY24-11012023-001405-A	<1	FT-FY24-11012023-001405-B	<1
WS-001406	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 154	Low Right	WF-02212023-001406	1/28/2024	FT-FY24-11012023-001406-A	<1	FT-FY24-11012023-001406-B	<1
WS-001407	2/21/2023	2/21/2024	1	Combo Faucet	In classroom 153	WF-02212023-001407	1/28/2024	FT-FY24-11012023-001407-A	<1	FT-FY24-11012023-001407-B	<1	
WS-001408	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 153	WF-02212023-001408	1/28/2024	FT-FY24-11012023-001408-A	<1	FT-FY24-11012023-001408-B	<1	
WS-001409	2/21/2023	2/21/2024	1	Combo Faucet	In classroom 147	WF-02212023-001409	1/28/2024	FT-FY24-11012023-001409-A	<1	FT-FY24-11012023-001409-B	<1	
WS-001410	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 147	WF-02212023-001410	1/28/2024	FT-FY24-11012023-001410-A	<1	FT-FY24-11012023-001410-B	<1	
WS-001415	2/21/2023	2/21/2024	1	Combo Faucet	In classroom 143	WF-02212023-001415	1/28/2024	FT-FY24-11012023-001415-A	<1	FT-FY24-11012023-001415-B	<1	
WS-001416	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 143	WF-02212023-001416	1/28/2024	FT-FY24-11012023-001416-A	<1	FT-FY24-11012023-001416-B	<1	
WS-001419	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 139	WF-02212023-001419	1/28/2024	FT-FY24-11012023-001419-A	<1	FT-FY24-11012023-001419-B	<1	
WS-001421	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 136	WF-02212023-001421	1/28/2024	FT-FY24-11012023-001421-A	<1	FT-FY24-11012023-001421-B	<1	
WS-001423	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 137	WF-02212023-001423	1/28/2024	FT-FY24-11012023-001423-A	<1	FT-FY24-11012023-001423-B	<1	
WS-001425	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 134	WF-02212023-001425	1/28/2024	FT-FY24-11012023-001425-A	<1	FT-FY24-11012023-001425-B	<1	
WS-001429	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 128	WF-02212023-001429	1/28/2024	FT-FY24-11012023-001429-A	<1	FT-FY24-11012023-001429-B	<1	
WS-001431	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 127	WF-02212023-001431	1/28/2024	FT-FY24-11012023-001431-A	<1	FT-FY24-11012023-001431-B	<1	
WS-001432	2/21/2023	2/21/2024	1	Bottle Filler	In hallway adjacent to 133	WF-02212023-001432	1/28/2024	FT-FY24-11012023-001432-A	<1	FT-FY24-11012023-001432-B	<1	
WS-001433	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 133	High Left	WF-02212023-001433	1/28/2024	FT-FY24-11012023-001433-A	<1	FT-FY24-11012023-001433-B	<1

WS-001434	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to 133	Low Right	WF-02212023-001434	1/28/2024	FT-FY24-11012023-001434-A	<1	FT-FY24-11012023-001434-B	<1
WS-001437	2/21/2023	2/21/2024	1	Combo Fountain	In library room 101F		WF-02212023-001437	1/28/2024	FT-FY24-11012023-001437-A	<1	FT-FY24-11012023-001437-B	<1
WS-001439	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 206		WF-02212023-001439	1/28/2024	FT-FY24-11012023-001439-A	<1	FT-FY24-11012023-001439-B	<1
WS-001441	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 207		WF-02212023-001441	1/28/2024	FT-FY24-11012023-001441-A	<1	FT-FY24-11012023-001441-B	<1
WS-001445	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 211		WF-02212023-001445	1/28/2024	FT-FY24-11012023-001445-A	<1	FT-FY24-11012023-001445-B	<1
WS-001446	2/21/2023	2/21/2024	2	Bottle Filler	In hallway adjacent to 211		WF-02212023-001446	1/28/2024	FT-FY24-11012023-001446-A	<1	FT-FY24-11012023-001446-B	<1
WS-001447	2/21/2023	2/21/2024	2	Cooler	In hallway adjacent to 211	High Left	WF-02212023-001447	1/28/2024	FT-FY24-11012023-001447-A	1.0	FT-FY24-11012023-001447-B	<1
WS-001448	2/21/2023	2/21/2024	2	Cooler	In hallway adjacent to 211	Low Right	WF-02212023-001448	1/28/2024	FT-FY24-11012023-001448-A	<1	FT-FY24-11012023-001448-B	<1
WS-001509	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 214		WF-02212023-001509	1/28/2024	FT-FY24-11012023-001509-A	<1	FT-FY24-11012023-001509-B	<1
WS-001511	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 215		WF-02212023-001511	1/28/2024	FT-FY24-11012023-001511-A	<1	FT-FY24-11012023-001511-B	<1
WS-001524	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 232		WF-02212023-001524	1/28/2024	FT-FY24-11012023-001524-A	<1	FT-FY24-11012023-001524-B	<1
WS-001527	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 233		WF-02212023-001527	1/28/2024	FT-FY24-11012023-001527-A	<1	FT-FY24-11012023-001527-B	<1
WS-001529	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 234		WF-02212023-001529	1/28/2024	FT-FY24-11012023-001529-A	<1	FT-FY24-11012023-001529-B	<1
WS-001530	2/21/2023	2/21/2024	2	Bottle Filler	In gym 243		WF-02212023-001530	1/28/2024	FT-FY24-11012023-001530-A	<1	FT-FY24-11012023-001530-B	<1
WS-001531	2/21/2023	2/21/2024	2	Cooler	In gym 243	High Left	WF-02212023-001531	1/28/2024	FT-FY24-11012023-001531-A	<1	FT-FY24-11012023-001531-B	<1
WS-001532	2/21/2023	2/21/2024	2	Cooler	In gym 243	Low Right	WF-02212023-001532	1/28/2024	FT-FY24-11012023-001532-A	<1	FT-FY24-11012023-001532-B	<1
WS-001535	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 241		WF-02212023-001535	1/28/2024	FT-FY24-11012023-001535-A	<1	FT-FY24-11012023-001535-B	<1
WS-001537	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 240		WF-02212023-001537	1/28/2024	FT-FY24-11012023-001537-A	<1	FT-FY24-11012023-001537-B	<1
WS-001538	2/21/2023	2/21/2024	2	Bottle Filler	In hallway adjacent to 239		WF-02212023-001538	1/28/2024	FT-FY24-11012023-001538-A	<1	FT-FY24-11012023-001538-B	<1
WS-001539	2/21/2023	2/21/2024	2	Cooler	In hallway adjacent to 239	High Left	WF-02212023-001539	1/28/2024	FT-FY24-11012023-001539-A	<1	FT-FY24-11012023-001539-B	<1
WS-001540	2/21/2023	2/21/2024	2	Cooler	In hallway adjacent to 239	Low Right	WF-02212023-001540	1/28/2024	FT-FY24-11012023-001540-A	<1	FT-FY24-11012023-001540-B	<1
WS-001542	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 238		WF-02212023-001542	1/28/2024	FT-FY24-11012023-001542-A	<1	FT-FY24-11012023-001542-B	<1
WS-001545	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 236		WF-02212023-001545	1/28/2024	FT-FY24-11012023-001545-A	<1	FT-FY24-11012023-001545-B	<1
WS-001547	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 235		WF-02212023-001547	1/28/2024	FT-FY24-11012023-001547-A	<1	FT-FY24-11012023-001547-B	<1
WS-001552	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 220	Left	WF-02212023-001552	1/28/2024	FT-FY24-11012023-001552-A	<1	FT-FY24-11012023-001552-B	<1
WS-001554	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 220	Right	WF-02212023-001554	1/28/2024	FT-FY24-11012023-001554-A	<1	FT-FY24-11012023-001554-B	<1
WS-001556	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 221		WF-02212023-001556	1/28/2024	FT-FY24-11012023-001556-A	<1	FT-FY24-11012023-001556-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001286	1/23/2023	1/23/2024	1	Food Prep Sink	In pantry space 123	WF-01232023-001286	1/28/2024	FT-FY24-11012023-001286-A	<1	FT-FY24-11012023-001286-B	<1
WS-001395	1/23/2023	1/23/2024	1	Food Prep Sink	In pantry space 138	WF-01232023-001395	1/28/2024	FT-FY24-11012023-001395-A	<1	FT-FY24-11012023-001395-B	<1
WS-001397	1/23/2023	1/23/2024	1	Food Prep Sink	In kitchen 2nd clockwise from entry	WF-01232023-001397	1/28/2024	FT-FY24-11012023-001397-A	<1	FT-FY24-11012023-001397-B	<1
WS-001411	1/23/2023	1/23/2024	1	Food Prep Sink	In pantry area 151	WF-01232023-001411	1/28/2024	FT-FY24-11012023-001411-A	<1	FT-FY24-11012023-001411-B	<1
WS-001417	1/23/2023	1/23/2024	1	Food Prep Sink	In pantry area 145	WF-01232023-001417	1/28/2024	FT-FY24-11012023-001417-A	<1	FT-FY24-11012023-001417-B	<1
WS-001435	1/23/2023	1/23/2024	1	Food Prep Sink	In pantry area 131	WF-01232023-001435	1/28/2024	FT-FY24-11012023-001435-A	<1	FT-FY24-11012023-001435-B	<1
WS-001512	1/23/2023	1/23/2024	2	Food Prep Sink	In pantry area 216	WF-01232023-001512	1/28/2024	FT-FY24-11012023-001512-A	<1	FT-FY24-11012023-001512-B	<1
WS-001525	1/23/2023	1/23/2024	2	Food Prep Sink	In pantry area 230C	WF-01232023-001525	1/28/2024	FT-FY24-11012023-001525-A	<1	FT-FY24-11012023-001525-B	<1
WS-001533	1/23/2023	1/23/2024	2	Food Prep Sink	In pantry area 239	WF-01232023-001533	1/28/2024	FT-FY24-11012023-001533-A	<1	FT-FY24-11012023-001533-B	<1
WS-001543	1/23/2023	1/23/2024	2	Food Prep Sink	In pantry area 237	WF-01232023-001543	1/28/2024	FT-FY24-11012023-001543-A	<1	FT-FY24-11012023-001543-B	<1