



Cardozo Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004122	4/12/2022	4/12/2023	3	Cooler	In hallway across from 3502 High Left	WF-04122022-004122	1/25/2023	FT-FY23-12292022-004122-A	<1	FT-FY23-12292022-004122-B	<1
WS-004123	4/12/2022	4/12/2023	3	Cooler	In hallway across from 3502 Low Right	WF-04122022-004123	1/25/2023	FT-FY23-12292022-004123-A	<1	FT-FY23-12292022-004123-B	<1
WS-004128	4/12/2022	4/12/2023	Basement	Cooler	On LT level, In gym hallway across from girls' locker room LT55 High Left	WF-04122022-004128	1/25/2023	FT-FY23-12292022-004128-A	<1	FT-FY23-12292022-004128-B	<1
WS-004129	4/12/2022	4/12/2023	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58 High Left	WF-04122022-004129	1/25/2023	FT-FY23-12292022-004129-A	<1	FT-FY23-12292022-004129-B	<1
WS-004130	4/12/2022	4/12/2023	Basement	Cooler	On LT level, In gym hallway across from girls' locker room LT55 Low Right	WF-04122022-004130	1/25/2023	FT-FY23-12292022-004130-A	<1	FT-FY23-12292022-004130-B	<1
WS-004131	4/12/2022	4/12/2023	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58 Low Right	WF-04122022-004131	1/25/2023	FT-FY23-12292022-004131-A	<1	FT-FY23-12292022-004131-B	<1
WS-004132	4/12/2022	4/12/2023	Basement	Cooler	On T level, gym lobby adjacent to T04A High Left	WF-04122022-004132	1/25/2023	FT-FY23-12292022-004132-A	<1	FT-FY23-12292022-004132-B	<1
WS-004133	4/12/2022	4/12/2023	Basement	Cooler	On T level, gym lobby adjacent to T04A Low Right	WF-04122022-004133	1/25/2023	FT-FY23-12292022-004133-A	<1	FT-FY23-12292022-004133-B	<1
WS-004136	4/12/2022	4/12/2023	Basement	Cooler	On LT level, in LT410 (pool) High Left	WF-04122022-004136	1/25/2023	FT-FY23-12292022-004136-A	<1	FT-FY23-12292022-004136-B	<1
WS-004137	4/12/2022	4/12/2023	Basement	Cooler	On LT level, in LT410 (pool) Low Right	WF-04122022-004137	1/25/2023	FT-FY23-12292022-004137-A	<1	FT-FY23-12292022-004137-B	<1
WS-004139	4/12/2022	4/12/2023	Basement	Cooler	In stadium locker room	WF-04122022-004139	1/25/2023	FT-FY23-12292022-004139-A	<1	FT-FY23-12292022-004139-B	<1
WS-004803	4/12/2022	4/12/2023	1	Break Room	In office room 1130 in room 1119	WF-04122022-004803	1/25/2023	FT-FY23-12292022-004803-A	<1	FT-FY23-12292022-004803-B	<1
WS-004805	4/12/2022	4/12/2023	2	Break Room	In staff workroom 2501	WF-04122022-004805	1/25/2023	FT-FY23-12292022-004805-A	<1	FT-FY23-12292022-004805-B	<1
WS-008321	4/12/2022	4/12/2023	Ground Floor	Health Suite	On C level, in health suite C137	WF-04122022-008321	1/25/2023	FT-FY23-12292022-008321-A	<1	FT-FY23-12292022-008321-B	<1
WS-008323	4/12/2022	4/12/2023	Ground Floor	Health Suite	On C level, in health suite C140	WF-04122022-008323	1/25/2023	FT-FY23-12292022-008323-A	<1	FT-FY23-12292022-008323-B	<1
WS-008324	4/12/2022	4/12/2023	Ground Floor	Health Suite	On C level, in health suite C144	WF-04122022-008324	1/25/2023	FT-FY23-12292022-008324-A	<1	FT-FY23-12292022-008324-B	<1
WS-008325	4/12/2022	4/12/2023	Ground Floor	Health Suite	On C level, in health suite C151	WF-04122022-008325	1/25/2023	FT-FY23-12292022-008325-A	<1	FT-FY23-12292022-008325-B	<1
WS-008326	4/12/2022	4/12/2023	Ground Floor	Health Suite	On C level, in health suite C146	WF-04122022-008326	1/25/2023	FT-FY23-12292022-008326-A	<1	FT-FY23-12292022-008326-B	<1
WS-008327	4/12/2022	4/12/2023	Ground Floor	Health Suite	On C level, in health suite C148	WF-04122022-008327	1/25/2023	FT-FY23-12292022-008327-A	<1	FT-FY23-12292022-008327-B	<1
WS-008328	4/12/2022	4/12/2023	Ground Floor	Health Suite	On C level, in health suite C149	WF-04122022-008328	1/25/2023	FT-FY23-12292022-008328-A	<1	FT-FY23-12292022-008328-B	<1
WS-008332	4/12/2022	4/12/2023	Ground Floor	Cooler	On C level, in hallway across from room C205 High Left	WF-04122022-008332	1/25/2023	FT-FY23-12292022-008332-A	<1	FT-FY23-12292022-008332-B	<1
WS-008333	4/12/2022	4/12/2023	Ground Floor	Cooler	On C level, in hallway across from room C205 Low Right	WF-04122022-008333	1/25/2023	FT-FY23-12292022-008333-A	<1	FT-FY23-12292022-008333-B	<1
WS-008346	4/12/2022	4/12/2023	Basement	Cooler	On T level, in hallway across from room T203	WF-04122022-008346	1/25/2023	FT-FY23-12292022-008346-A	<1	FT-FY23-12292022-008346-B	<1
WS-008363	4/12/2022	4/12/2023	1	Cooler	In hallway across from 1203 High Left	WF-04122022-008363	1/25/2023	FT-FY23-12292022-008363-A	<1	FT-FY23-12292022-008363-B	<1
WS-008364	4/12/2022	4/12/2023	1	Cooler	In hallway across from 1203 Low Right	WF-04122022-008364	1/25/2023	FT-FY23-12292022-008364-A	<1	FT-FY23-12292022-008364-B	<1
WS-008369	4/12/2022	4/12/2023	1	Break Room	In staff lounge 1304	WF-04122022-008369	1/25/2023	FT-FY23-12292022-008369-A	<1	FT-FY23-12292022-008369-B	<1
WS-008395	4/12/2022	4/12/2023	1	Cooler	In hallway across from room 1603 High Left	WF-04122022-008395	1/25/2023	FT-FY23-12292022-008395-A	<1	FT-FY23-12292022-008395-B	<1
WS-008396	4/12/2022	4/12/2023	1	Cooler	In hallway across from room 1603 Low Right	WF-04122022-008396	1/25/2023	FT-FY23-12292022-008396-A	<1	FT-FY23-12292022-008396-B	<1
WS-008408	4/12/2022	4/12/2023	1	Break Room	In staff lounge 1611	WF-04122022-008408	1/25/2023	FT-FY23-12292022-008408-A	<1	FT-FY23-12292022-008408-B	<1
WS-008410	9/12/2022	9/12/2023	1	Classroom Faucet	In office room 1610 in room 1611	WF-09122022-008410	1/25/2023	FT-FY23-12292022-008410-A	<1	FT-FY23-12292022-008410-B	<1
WS-008416	4/12/2022	4/12/2023	2	Cooler	In hallway across from room 2204 High Left	WF-04122022-008416	1/25/2023	FT-FY23-12292022-008416-A	<1	FT-FY23-12292022-008416-B	<1
WS-008417	4/12/2022	4/12/2023	2	Cooler	In hallway across from room 2205 Low Right	WF-04122022-008417	1/25/2023	FT-FY23-12292022-008417-A	<1	FT-FY23-12292022-008417-B	<1
WS-008419	4/12/2022	4/12/2023	2	Cooler	In hallway across from room 2602 High Left	WF-04122022-008419	1/25/2023	FT-FY23-12292022-008419-A	<1	FT-FY23-12292022-008419-B	<1
WS-008420	4/12/2022	4/12/2023	2	Cooler	In hallway across from room 2602 Low Right	WF-04122022-008420	1/25/2023	FT-FY23-12292022-008420-A	<1	FT-FY23-12292022-008420-B	<1
WS-008465	4/12/2022	4/12/2023	3	Health Suite	In health suite 3202	WF-04122022-008465	1/25/2023	FT-FY23-12292022-008465-A	<1	FT-FY23-12292022-008465-B	<1
WS-008467	4/12/2022	4/12/2023	3	Cooler	In hallway adjacent to room 3204 High Left	WF-04122022-008467	1/25/2023	FT-FY23-12292022-008467-A	<1	FT-FY23-12292022-008467-B	<1
WS-008468	4/12/2022	4/12/2023	3	Cooler	In hallway adjacent to room 3204 Low Right	WF-04122022-008468	1/25/2023	FT-FY23-12292022-008468-A	<1	FT-FY23-12292022-008468-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004134	12/19/2022	12/19/2023	Basement	Food Prep Sink	On T level, in T02 concession stand (sink)	WF-12192022-004134	1/25/2023	FT-FY23-12292022-004134-A	<1	FT-FY23-12292022-004134-B	<1
WS- 008335	12/19/2022	12/19/2023	Ground Floor	Food Prep Sink	On C level, in kitchen room C122 west wall	WF-12192022-008335	1/25/2023	FT-FY23-12292022-008335-A	<1	FT-FY23-12292022-008335-B	<1
WS- 008336	12/19/2022	12/19/2023	Ground Floor	Food Prep Sink	On C level, in kitchen C122 middle	WF-12192022-008336	1/25/2023	FT-FY23-12292022-008336-A	<1	FT-FY23-12292022-008336-B	<1