



Cardozo Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004122	5/18/2020	5/18/2021	3	Cooler	In hallway across from 3502	High Left	WF-05182020-004122	3/27/2021	FT-FY21-032021-004122-A	<1	FT-FY21-032021-004122-B	<1
WS- 004123	5/18/2020	5/18/2021	3	Cooler	In hallway across from 3502	Low Right	WF-05182020-004123	3/27/2021	FT-FY21-032021-004123-A	<1	FT-FY21-032021-004123-B	<1
WS- 004132	5/18/2020	5/18/2021	Basement	Cooler	On T level, gym lobby adjacent to T04A	High Left	WF-05182020-004132	3/27/2021	FT-FY21-032021-004132-A	<1	FT-FY21-032021-004132-B	<1
WS- 004133	5/18/2020	5/18/2021	Basement	Cooler	On T level, gym lobby adjacent to T04A	Low Right	WF-05182020-004133	3/27/2021	FT-FY21-032021-004133-A	<1	FT-FY21-032021-004133-B	<1
WS- 004136	5/18/2020	5/18/2021	Basement	Cooler	On LT level, in LT410 (pool)	High Left	WF-05182020-004136	3/27/2021	FT-FY21-032021-004136-A	<1	FT-FY21-032021-004136-B	<1
WS- 004137	5/18/2020	5/18/2021	Basement	Cooler	On LT level, in LT410 (pool)	Low Right	WF-05182020-004137	3/27/2021	FT-FY21-032021-004137-A	<1	FT-FY21-032021-004137-B	<1
WS- 004139	5/18/2020	5/18/2021	Basement	Cooler	In stadium locker room		WF-05182020-004139	3/27/2021	FT-FY21-032021-004139-A	<1	FT-FY21-032021-004139-B	<1
WS- 004803	5/18/2020	5/18/2021	1	Break Room	In office room 1130 in room 1119		WF-05182020-004803	3/27/2021	FT-FY21-032021-004803-A	<1	FT-FY21-032021-004803-B	<1
WS- 004805	5/18/2020	5/18/2021	2	Break Room	In staff workroom 2501		WF-05182020-004805	3/27/2021	FT-FY21-032021-004805-A	<1	FT-FY21-032021-004805-B	<1
WS- 004807	5/18/2020	5/18/2021	Basement	Cooler	In stadium locker room east side		WF-05182020-004807	3/27/2021	FT-FY21-032021-004807-A	<1	FT-FY21-032021-004807-B	<1
WS- 008321	5/18/2020	5/18/2021	Ground Floor	Health Suite	On C level, in health suite C137		WF-05182020-008321	3/27/2021	FT-FY21-032021-008321-A	<1	FT-FY21-032021-008321-B	<1
WS- 008323	5/18/2020	5/18/2021	Ground Floor	Health Suite	On C level, in health suite C140		WF-05182020-008323	3/27/2021	FT-FY21-032021-008323-A	<1	FT-FY21-032021-008323-B	<1
WS- 008324	5/18/2020	5/18/2021	Ground Floor	Health Suite	On C level, in health suite C144		WF-05182020-008324	3/27/2021	FT-FY21-032021-008324-A	<1	FT-FY21-032021-008324-B	<1
WS- 008325	5/18/2020	5/18/2021	Ground Floor	Health Suite	On C level, in health suite C151		WF-05182020-008325	3/27/2021	FT-FY21-032021-008325-A	<1	FT-FY21-032021-008325-B	<1
WS- 008326	5/18/2020	5/18/2021	Ground Floor	Health Suite	On C level, in health suite C146		WF-05182020-008326	3/27/2021	FT-FY21-032021-008326-A	<1	FT-FY21-032021-008326-B	<1
WS- 008332	5/18/2020	5/18/2021	Ground Floor	Cooler	On C level, in hallway across from room C205	High Left	WF-05182020-008332	3/27/2021	FT-FY21-032021-008332-A	<1	FT-FY21-032021-008332-B	<1
WS- 008333	5/18/2020	5/18/2021	Ground Floor	Cooler	On C level, in hallway across from room C205	Low Right	WF-05182020-008333	3/27/2021	FT-FY21-032021-008333-A	<1	FT-FY21-032021-008333-B	<1
WS- 008346	5/18/2020	5/18/2021	Basement	Cooler	On T level, in hallway across from room T203		WF-05182020-008346	3/27/2021	FT-FY21-032021-008346-A	<1	FT-FY21-032021-008346-B	<1
WS- 008363	5/18/2020	5/18/2021	1	Cooler	In hallway across from 1203	High Left	WF-05182020-008363	3/27/2021	FT-FY21-032021-008363-A	<1	FT-FY21-032021-008363-B	<1
WS- 008364	5/18/2020	5/18/2021	1	Cooler	In hallway across from 1203	Low Right	WF-05182020-008364	3/27/2021	FT-FY21-032021-008364-A	<1	FT-FY21-032021-008364-B	<1
WS- 008369	5/18/2020	5/18/2021	1	Break Room	In staff lounge 1304		WF-05182020-008369	3/27/2021	FT-FY21-032021-008369-A	<1	FT-FY21-032021-008369-B	<1
WS- 008395	5/18/2020	5/18/2021	1	Cooler	In hallway across from room 1603	High Left	WF-05182020-008395	3/27/2021	FT-FY21-032021-008395-A	<1	FT-FY21-032021-008395-B	<1
WS- 008396	5/18/2020	5/18/2021	1	Cooler	In hallway across from room 1603	Low Right	WF-05182020-008396	3/27/2021	FT-FY21-032021-008396-A	<1	FT-FY21-032021-008396-B	<1
WS- 008408	5/18/2020	5/18/2021	1	Break Room	In staff lounge 1611		WF-05182020-008408	3/27/2021	FT-FY21-032021-008408-A	<1	FT-FY21-032021-008408-B	<1
WS- 008410	10/7/2020	10/7/2021	1	Classroom Faucet	In office room 1610 in room 1611		WF-10072020-008410	3/27/2021	FT-FY21-032021-008410-A	<1	FT-FY21-032021-008410-B	<1
WS- 008416	5/18/2020	5/18/2021	2	Cooler	In hallway across from room 2204	High Left	WF-05182020-008416	3/27/2021	FT-FY21-032021-008416-A	<1	FT-FY21-032021-008416-B	<1
WS- 008417	5/18/2020	5/18/2021	2	Cooler	In hallway across from room 2205	Low Right	WF-05182020-008417	3/27/2021	FT-FY21-032021-008417-A	<1	FT-FY21-032021-008417-B	<1
WS- 008419	5/18/2020	5/18/2021	2	Cooler	In hallway across from room 2602	High Left	WF-05182020-008419	3/27/2021	FT-FY21-032021-008419-A	<1	FT-FY21-032021-008419-B	<1
WS- 008420	5/18/2020	5/18/2021	2	Cooler	In hallway across from room 2602	Low Right	WF-05182020-008420	3/27/2021	FT-FY21-032021-008420-A	<1	FT-FY21-032021-008420-B	<1
WS- 008465	5/18/2020	5/18/2021	3	Health Suite	In health suite 3202		WF-05182020-008465	3/27/2021	FT-FY21-032021-008465-A	<1	FT-FY21-032021-008465-B	<1
WS- 008467	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3204	High Left	WF-05182020-008467	3/27/2021	FT-FY21-032021-008467-A	<1	FT-FY21-032021-008467-B	<1
WS- 008468	5/18/2020	5/18/2021	3	Cooler	In hallway adjacent to room 3204	Low Right	WF-05182020-008468	3/27/2021	FT-FY21-032021-008468-A	<1	FT-FY21-032021-008468-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004134	1/4/2021	1/4/2022	Basement	Food Prep Sink	On T level, in T02 concession stand (sink)	WF-01042021-004134	3/27/2021	FT-FY21-032021-004134-A	<1	FT-FY21-032021-004134-B	<1
WS- 008335	1/4/2021	1/4/2022	Ground Floor	Food Prep Sink	On C level, in kitchen room C122 west wall	WF-01042021-008335	3/27/2021	FT-FY21-032021-008335-A	<1	FT-FY21-032021-008335-B	<1
WS- 008336	1/4/2021	1/4/2022	Ground Floor	Food Prep Sink	On C level, in kitchen C122 middle	WF-01042021-008336	3/27/2021	FT-FY21-032021-008336-A	<1	FT-FY21-032021-008336-B	<1