



Cardozo Education Campus Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004122	4/20/2021	4/20/2022	3	Cooler	In hallway across from 3502 High Left	WF-04202021-004122	11/15/2021	FT-FY22-11022021-004122-A	<1	FT-FY22-11022021-004122-B	<1
WS-004123	4/20/2021	4/20/2022	3	Cooler	In hallway across from 3502 Low Right	WF-04202021-004123	11/15/2021	FT-FY22-11022021-004123-A	<1	FT-FY22-11022021-004123-B	<1
WS-004128	4/20/2021	4/20/2022	Basement	Cooler	On LT level, In gym hallway across from girls' locker room LT55 High Left	WF-04202021-004128	11/15/2021	FT-FY22-11022021-004128-A	<1	FT-FY22-11022021-004128-B	<1
WS-004129	4/20/2021	4/20/2022	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58 High Left	WF-04202021-004129	11/15/2021	FT-FY22-11022021-004129-A	<1	FT-FY22-11022021-004129-B	<1
WS-004130	4/20/2021	4/20/2022	Basement	Cooler	On LT level, In gym hallway across from girls' locker room LT55 Low Right	WF-04202021-004130	11/15/2021	FT-FY22-11022021-004130-A	<1	FT-FY22-11022021-004130-B	<1
WS-004131	4/20/2021	4/20/2022	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58 Low Right	WF-04202021-004131	11/15/2021	FT-FY22-11022021-004131-A	<1	FT-FY22-11022021-004131-B	<1
WS-004132	4/20/2021	4/20/2022	Basement	Cooler	On T level, gym lobby adjacent to T04A High Left	WF-04202021-004132	11/15/2021	FT-FY22-11022021-004132-A	<1	FT-FY22-11022021-004132-B	<1
WS-004133	4/20/2021	4/20/2022	Basement	Cooler	On T level, gym lobby adjacent to T04A Low Right	WF-04202021-004133	11/15/2021	FT-FY22-11022021-004133-A	<1	FT-FY22-11022021-004133-B	<1
WS-004136	4/20/2021	4/20/2022	Basement	Cooler	On LT level, in LT410 (pool) High Left	WF-04202021-004136	11/15/2021	FT-FY22-11022021-004136-A	<1	FT-FY22-11022021-004136-B	<1
WS-004137	4/20/2021	4/20/2022	Basement	Cooler	On LT level, in LT410 (pool) Low Right	WF-04202021-004137	11/15/2021	FT-FY22-11022021-004137-A	<1	FT-FY22-11022021-004137-B	<1
WS-004803	4/20/2021	4/20/2022	1	Break Room	In office room 1130 in room 1119	WF-04202021-004803	11/15/2021	FT-FY22-11022021-004803-A	<1	FT-FY22-11022021-004803-B	<1
WS-004805	4/20/2021	4/20/2022	2	Break Room	In staff workroom 2501	WF-04202021-004805	11/15/2021	FT-FY22-11022021-004805-A	<1	FT-FY22-11022021-004805-B	<1
WS-008321	4/20/2021	4/20/2022	Ground Floor	Health Suite	On C level, in health suite C137	WF-04202021-008321	11/15/2021	FT-FY22-11022021-008321-A	<1	FT-FY22-11022021-008321-B	<1
WS-008323	4/20/2021	4/20/2022	Ground Floor	Health Suite	On C level, in health suite C140	WF-04202021-008323	11/15/2021	FT-FY22-11022021-008323-A	<1	FT-FY22-11022021-008323-B	<1
WS-008324	4/20/2021	4/20/2022	Ground Floor	Health Suite	On C level, in health suite C144	WF-04202021-008324	11/15/2021	FT-FY22-11022021-008324-A	<1	FT-FY22-11022021-008324-B	<1
WS-008325	4/20/2021	4/20/2022	Ground Floor	Health Suite	On C level, in health suite C151	WF-04202021-008325	11/15/2021	FT-FY22-11022021-008325-A	<1	FT-FY22-11022021-008325-B	<1
WS-008326	4/20/2021	4/20/2022	Ground Floor	Health Suite	On C level, in health suite C146	WF-04202021-008326	11/15/2021	FT-FY22-11022021-008326-A	<1	FT-FY22-11022021-008326-B	<1
WS-008332	4/20/2021	4/20/2022	Ground Floor	Cooler	On C level, in hallway across from room C205 High Left	WF-04202021-008332	11/15/2021	FT-FY22-11022021-008332-A	<1	FT-FY22-11022021-008332-B	<1
WS-008333	4/20/2021	4/20/2022	Ground Floor	Cooler	On C level, in hallway across from room C205 Low Right	WF-04202021-008333	11/15/2021	FT-FY22-11022021-008333-A	<1	FT-FY22-11022021-008333-B	<1
WS-008346	4/20/2021	4/20/2022	Basement	Cooler	On T level, in hallway across from room T203	WF-04202021-008346	11/15/2021	FT-FY22-11022021-008346-A	<1	FT-FY22-11022021-008346-B	1.1
WS-008363	4/20/2021	4/20/2022	1	Cooler	In hallway across from 1203 High Left	WF-04202021-008363	11/15/2021	FT-FY22-11022021-008363-A	<1	FT-FY22-11022021-008363-B	<1
WS-008364	4/20/2021	4/20/2022	1	Cooler	In hallway across from 1203 Low Right	WF-04202021-008364	11/15/2021	FT-FY22-11022021-008364-A	<1	FT-FY22-11022021-008364-B	<1
WS-008369	4/20/2021	4/20/2022	1	Break Room	In staff lounge 1304	WF-04202021-008369	11/15/2021	FT-FY22-11022021-008369-A	<1	FT-FY22-11022021-008369-B	<1
WS-008408	4/20/2021	4/20/2022	1	Break Room	In staff lounge 1611	WF-04202021-008408	11/15/2021	FT-FY22-11022021-008408-A	<1	FT-FY22-11022021-008408-B	<1
WS-008410	9/27/2021	9/27/2022	1	Classroom Faucet	In office room 1610 in room 1611	WF-09272021-008410	11/15/2021	FT-FY22-11022021-008410-A	<1	FT-FY22-11022021-008410-B	<1
WS-008416	4/20/2021	4/20/2022	2	Cooler	In hallway across from room 2204 High Left	WF-04202021-008416	11/15/2021	FT-FY22-11022021-008416-A	<1	FT-FY22-11022021-008416-B	<1
WS-008417	4/20/2021	4/20/2022	2	Cooler	In hallway across from room 2205 Low Right	WF-04202021-008417	11/15/2021	FT-FY22-11022021-008417-A	<1	FT-FY22-11022021-008417-B	<1
WS-008465	4/20/2021	4/20/2022	3	Health Suite	In health suite 3202	WF-04202021-008465	11/15/2021	FT-FY22-11022021-008465-A	<1	FT-FY22-11022021-008465-B	<1
WS-008467	4/20/2021	4/20/2022	3	Cooler	In hallway adjacent to room 3204 High Left	WF-04202021-008467	11/15/2021	FT-FY22-11022021-008467-A	<1	FT-FY22-11022021-008467-B	<1
WS-008468	4/20/2021	4/20/2022	3	Cooler	In hallway adjacent to room 3204 Low Right	WF-04202021-008468	11/15/2021	FT-FY22-11022021-008468-A	<1	FT-FY22-11022021-008468-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004134	1/4/2021	1/4/2022	Basement	Food Prep Sink	On T level, in T02 concession stand (sink)	WF-01042021-004134	11/15/2021	FT-FY22-11022021-004134-A	<1	FT-FY22-11022021-004134-B	<1
WS-008335	1/4/2021	1/4/2022	Ground Floor	Food Prep Sink	On C level, in kitchen room C122 west wall	WF-01042021-008335	11/15/2021	FT-FY22-11022021-008335-A	<1	FT-FY22-11022021-008335-B	<1
WS-008336	1/4/2021	1/4/2022	Ground Floor	Food Prep Sink	On C level, in kitchen C122 middle	WF-01042021-008336	11/15/2021	FT-FY22-11022021-008336-A	<1	FT-FY22-11022021-008336-B	<1