



CARDOZO HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	CARDOZO HIGH SCHOOL	WS- 004122	8/20/2016	3	Cooler	In hallway across from 3502 High Left	FT-82016-004122-A	< 1	FT-82016-004122-B	< 1
2	CARDOZO HIGH SCHOOL	WS- 004123	8/20/2016	3	Cooler	In hallway across from 3502 Low Right	FT-82016-004123-A	< 1	FT-82016-004123-B	< 1
3	CARDOZO HIGH SCHOOL	WS- 004128	8/20/2016	Basement	Cooler	On LT level, In gym hallway across from girls' locker room LT55 High Left	FT-82016-004128-A	< 1	FT-82016-004128-B	< 1
4	CARDOZO HIGH SCHOOL	WS- 004129	8/20/2016	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58 High Left	FT-82016-004129-A	< 1	FT-82016-004129-B	< 1
5	CARDOZO HIGH SCHOOL	WS- 004130	8/20/2016	Basement	Cooler	On LT level, In gym hallway across from locker room LT55 Low Right	FT-82016-004130-A	< 1	FT-82016-004130-B	< 1
6	CARDOZO HIGH SCHOOL	WS- 004131	8/20/2016	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58 Low Right	FT-82016-004131-A	< 1	FT-82016-004131-B	< 1
7	CARDOZO HIGH SCHOOL	WS- 004132	8/20/2016	Basement	Cooler	On T level, gym lobby adjacent to T04A High Left	FT-82016-004132-A	< 1	FT-82016-004132-B	< 1
8	CARDOZO HIGH SCHOOL	WS- 004133	8/20/2016	Basement	Cooler	On T level, gym lobby adjacent to T04A Low Right	FT-82016-004133-A	< 1	FT-82016-004133-B	< 1
9	CARDOZO HIGH SCHOOL	WS- 004134	8/20/2016	Basement	Other	On T level, in T02 concession stand (sink)	FT-72016-004134-A	< 1	FT-72016-004134-B	< 1
10	CARDOZO HIGH SCHOOL	WS- 004136	8/20/2016	Basement	Cooler	On LT level, in LT410 (pool) High Left	FT-82016-004136-A	< 1	FT-82016-004136-B	< 1
11	CARDOZO HIGH SCHOOL	WS- 004137	8/20/2016	Basement	Cooler	On LT level, in LT410 (pool) Low Right	FT-82016-004137-A	< 1	FT-82016-004137-B	< 1
12	CARDOZO HIGH SCHOOL	WS- 004139	8/20/2016	Basement	Cooler	In stadium locker room	FT-82016-004139-A	< 1	FT-82016-004139-B	< 1
13	CARDOZO HIGH SCHOOL	WS- 004807	8/20/2016	Basement	Cooler	In stadium locker room east side	FT-82016-004807-A	< 1	FT-82016-004807-B	< 1
14	CARDOZO HIGH SCHOOL	WS- 008321	8/20/2016	Ground Floor	Health Suite	On C level, in health suite C137	FT-82016-008321-A	< 1	FT-82016-008321-B	< 1
15	CARDOZO HIGH SCHOOL	WS- 008323	8/20/2016	Ground Floor	Health Suite	On C level, in health suite C140	FT-82016-008323-A	< 1	FT-82016-008323-B	< 1
16	CARDOZO HIGH SCHOOL	WS- 008324	8/20/2016	Ground Floor	Health Suite	On C level, in health suite C144	FT-82016-008324-A	< 1	FT-82016-008324-B	< 1
17	CARDOZO HIGH SCHOOL	WS- 008325	8/20/2016	Ground Floor	Health Suite	On C level, in health suite C151	FT-82016-008325-A	< 1	FT-82016-008325-B	< 1
18	CARDOZO HIGH SCHOOL	WS- 008326	8/20/2016	Ground Floor	Health Suite	On C level, in health suite C146	FT-82016-008326-A	< 1	FT-82016-008326-B	< 1
19	CARDOZO HIGH SCHOOL	WS- 008327	8/20/2016	Ground Floor	Health Suite	On C level, in health suite C148	FT-82016-008327-A	< 1	FT-82016-008327-B	< 1
20	CARDOZO HIGH SCHOOL	WS- 008328	8/20/2016	Ground Floor	Health Suite	On C level, in health suite C149	FT-82016-008328-A	< 1	FT-82016-008328-B	< 1
21	CARDOZO HIGH SCHOOL	WS- 008332	8/20/2016	Ground Floor	Cooler	On C level, in hallway across from room C205 High Left	FT-82016-008332-A	< 1	FT-82016-008332-B	< 1
22	CARDOZO HIGH SCHOOL	WS- 008333	8/20/2016	Ground Floor	Cooler	On C level, in hallway across from room C205 Low Right	FT-82016-008333-A	< 1	FT-82016-008333-B	< 1
23	CARDOZO HIGH SCHOOL	WS- 008335	8/20/2016	Ground Floor	Food Prep Sink	On C level, in kitchen room C122 west wall	FT-82016-008335-A	< 1	FT-82016-008335-B	< 1
24	CARDOZO HIGH SCHOOL	WS- 008337	8/20/2016	Ground Floor	Ice Maker	On C level, in kitchen C122 in room C118 (ice maker)	FT-82016-008337-A	< 1	FT-82016-008337-B	< 1
25	CARDOZO HIGH SCHOOL	WS- 008346	8/20/2016	Basement	Cooler	On T level, in hallway across from room T203	FT-82016-008346-A	< 1	FT-82016-008346-B	< 1
26	CARDOZO HIGH SCHOOL	WS- 008363	8/20/2016	1	Cooler	In hallway across from 1203 High Left	FT-82016-008363-A	< 1	FT-82016-008363-B	< 1
27	CARDOZO HIGH SCHOOL	WS- 008364	8/20/2016	1	Cooler	In hallway across from 1203 Low Right	FT-82016-008364-A	< 1	FT-82016-008364-B	< 1
28	CARDOZO HIGH SCHOOL	WS- 008395	8/20/2016	1	Cooler	In hallway across from room 1603 High Left	FT-82016-008395-A	< 1	FT-82016-008395-B	< 1
29	CARDOZO HIGH SCHOOL	WS- 008396	8/20/2016	1	Cooler	In hallway across from room 1603 Low Right	FT-82016-008396-A	< 1	FT-82016-008396-B	< 1
30	CARDOZO HIGH SCHOOL	WS- 008416	8/20/2016	2	Cooler	In hallway across from room 2204 High Left	FT-82016-008416-A	< 1	FT-82016-008416-B	< 1
31	CARDOZO HIGH SCHOOL	WS- 008417	8/20/2016	2	Cooler	In hallway across from room 2205 Low Right	FT-82016-008417-A	< 1	FT-82016-008417-B	< 1
32	CARDOZO HIGH SCHOOL	WS- 008419	8/20/2016	2	Cooler	In hallway across from room 2602 High Left	FT-82016-008419-A	< 1	FT-82016-008419-B	< 1
33	CARDOZO HIGH SCHOOL	WS- 008420	8/20/2016	2	Cooler	In hallway across from room 2602 Low Right	FT-82016-008420-A	< 1	FT-82016-008420-B	< 1
34	CARDOZO HIGH SCHOOL	WS- 008424	8/20/2016	2	Cooler	In science lab room 2602 seventh clockwise from entry door	FT-82016-008424-A	< 1	FT-82016-008424-B	< 1
35	CARDOZO HIGH SCHOOL	WS- 008425	8/20/2016	2	Cooler	In science lab room 2602 sixth clockwise from entry door Left	FT-82016-008425-A	< 1	FT-82016-008425-B	< 1
36	CARDOZO HIGH SCHOOL	WS- 008465	8/20/2016	3	Health Suite	In health suite 3202	FT-82016-008465-A	< 1	FT-82016-008465-B	< 1

37	CARDOZO HIGH SCHOOL	WS- 008467	8/20/2016	3	Cooler	In hallway adjacent to room 3204	High	FT-82016-008467-A	< 1	FT-82016-008467-B	< 1
38	CARDOZO HIGH SCHOOL	WS- 008468	8/20/2016	3	Cooler	In hallway adjacent to room 3204	Low	FT-82016-008468-A	< 1	FT-82016-008468-B	< 1