



Cardozo HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004122	5/28/2019	5/28/2020	3	Cooler	In hallway across from 3502	High Left	WF-05282019-004122	1/4/2020	FT-FY20-122019-004122-A	<1	FT-FY20-122019-004122-B	<1
WS-004123	5/28/2019	5/28/2020	3	Cooler	In hallway across from 3502	Low Right	WF-05282019-004123	1/4/2020	FT-FY20-122019-004123-A	<1	FT-FY20-122019-004123-B	<1
WS-004128	5/28/2019	5/28/2020	Basement	Cooler	On LT level, In gym hallway across from girls' locker room LT55	High Left	WF-05282019-004128	1/4/2020	FT-FY20-122019-004128-A	<1	FT-FY20-122019-004128-B	<1
WS-004129	5/28/2019	5/28/2020	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58	High Left	WF-05282019-004129	1/4/2020	FT-FY20-122019-004129-A	<1	FT-FY20-122019-004129-B	<1
WS-004130	5/28/2019	5/28/2020	Basement	Cooler	On LT level, In gym hallway across from girls' locker room LT55	Low Right	WF-05282019-004130	1/4/2020	FT-FY20-122019-004130-A	<1	FT-FY20-122019-004130-B	<1
WS-004131	5/28/2019	5/28/2020	Basement	Cooler	On LT level, In gym hallway across from custodial closet LT58	Low Right	WF-05282019-004131	1/4/2020	FT-FY20-122019-004131-A	<1	FT-FY20-122019-004131-B	<1
WS-004132	5/28/2019	5/28/2020	Basement	Cooler	On T level, gym lobby adjacent to T04A	High Left	WF-05282019-004132	1/4/2020	FT-FY20-122019-004132-A	<1	FT-FY20-122019-004132-B	<1
WS-004133	5/28/2019	5/28/2020	Basement	Cooler	On T level, gym lobby adjacent to T04A	Low Right	WF-05282019-004133	1/4/2020	FT-FY20-122019-004133-A	<1	FT-FY20-122019-004133-B	<1
WS-004136	5/28/2019	5/28/2020	Basement	Cooler	On LT level, in LT410 (pool)	High Left	WF-05282019-004136	1/4/2020	FT-FY20-122019-004136-A	<1	FT-FY20-122019-004136-B	<1
WS-004137	5/28/2019	5/28/2020	Basement	Cooler	On LT level, in LT410 (pool)	Low Right	WF-05282019-004137	1/4/2020	FT-FY20-122019-004137-A	<1	FT-FY20-122019-004137-B	<1
WS-004139	5/28/2019	5/28/2020	Basement	Cooler	In stadium locker room		WF-05282019-004139	1/4/2020	FT-FY20-122019-004139-A	<1	FT-FY20-122019-004139-B	<1
WS-004803	5/28/2019	5/28/2020	1	Break Room	In office room 1130 in room 1119		WF-05282019-004803	1/4/2020	FT-FY20-122019-004803-A	<1	FT-FY20-122019-004803-B	<1
WS-004805	5/28/2019	5/28/2020	2	Break Room	In staff workroom 2501		WF-05282019-004805	1/4/2020	FT-FY20-122019-004805-A	<1	FT-FY20-122019-004805-B	<1
WS-004807	5/28/2019	5/28/2020	Basement	Cooler	In stadium locker room east side		WF-05282019-004807	1/4/2020	FT-FY20-122019-004807-A	<1	FT-FY20-122019-004807-B	<1
WS-008321	5/28/2019	5/28/2020	Ground Floor	Health Suite	On C level, in health suite C137		WF-05282019-008321	1/4/2020	FT-FY20-122019-008321-A	<1	FT-FY20-122019-008321-B	<1
WS-008323	5/28/2019	5/28/2020	Ground Floor	Health Suite	On C level, in health suite C140		WF-05282019-008323	1/4/2020	FT-FY20-122019-008323-A	<1	FT-FY20-122019-008323-B	<1
WS-008324	5/28/2019	5/28/2020	Ground Floor	Health Suite	On C level, in health suite C144		WF-05282019-008324	1/4/2020	FT-FY20-122019-008324-A	<1	FT-FY20-122019-008324-B	<1
WS-008325	5/28/2019	5/28/2020	Ground Floor	Health Suite	On C level, in health suite C151		WF-05282019-008325	1/4/2020	FT-FY20-122019-008325-A	<1	FT-FY20-122019-008325-B	<1
WS-008326	5/28/2019	5/28/2020	Ground Floor	Health Suite	On C level, in health suite C146		WF-05282019-008326	1/4/2020	FT-FY20-122019-008326-A	<1	FT-FY20-122019-008326-B	<1
WS-008327	5/28/2019	5/28/2020	Ground Floor	Health Suite	On C level, in health suite C148		WF-05282019-008327	1/4/2020	FT-FY20-122019-008327-A	<1	FT-FY20-122019-008327-B	<1
WS-008328	5/28/2019	5/28/2020	Ground Floor	Health Suite	On C level, in health suite C149		WF-05282019-008328	1/4/2020	FT-FY20-122019-008328-A	<1	FT-FY20-122019-008328-B	<1
WS-008332	5/28/2019	5/28/2020	Ground Floor	Cooler	On C level, in hallway across from room C205	High Left	WF-05282019-008332	1/4/2020	FT-FY20-122019-008332-A	<1	FT-FY20-122019-008332-B	<1
WS-008333	5/28/2019	5/28/2020	Ground Floor	Cooler	On C level, in hallway across from room C205	Low Right	WF-05282019-008333	1/4/2020	FT-FY20-122019-008333-A	<1	FT-FY20-122019-008333-B	<1
WS-008337	5/28/2019	5/28/2020	Ground Floor	Ice Maker	On C level, in kitchen C122 in room C118 (ice maker)		WF-05282019-008337	1/4/2020	FT-FY20-122019-008337-A	<1	FT-FY20-122019-008337-B	<1
WS-008346	5/28/2019	5/28/2020	Basement	Cooler	On T level, in hallway across from room T203		WF-05282019-008346	1/4/2020	FT-FY20-122019-008346-A	<1	FT-FY20-122019-008346-B	<1
WS-008363	5/28/2019	5/28/2020	1	Cooler	In hallway across from 1203	High Left	WF-05282019-008363	1/4/2020	FT-FY20-122019-008363-A	<1	FT-FY20-122019-008363-B	<1
WS-008364	5/28/2019	5/28/2020	1	Cooler	In hallway across from 1203	Low Right	WF-05282019-008364	1/4/2020	FT-FY20-122019-008364-A	<1	FT-FY20-122019-008364-B	<1
WS-008369	5/28/2019	5/28/2020	1	Break Room	In staff lounge 1304		WF-05282019-008369	1/4/2020	FT-FY20-122019-008369-A	<1	FT-FY20-122019-008369-B	<1
WS-008395	5/28/2019	5/28/2020	1	Cooler	In hallway across from room 1603	High Left	WF-05282019-008395	1/4/2020	FT-FY20-122019-008395-A	<1	FT-FY20-122019-008395-B	<1
WS-008396	5/28/2019	5/28/2020	1	Cooler	In hallway across from room 1603	Low Right	WF-05282019-008396	1/4/2020	FT-FY20-122019-008396-A	<1	FT-FY20-122019-008396-B	<1
WS-008408	5/28/2019	5/28/2020	1	Break Room	In staff lounge 1611		WF-05282019-008408	1/4/2020	FT-FY20-122019-008408-A	<1	FT-FY20-122019-008408-B	<1
WS-008410	10/14/2019	10/14/2020	1	Classroom Faucet	In office room 1610 in room 1611		WF-10142019-008410	1/4/2020	FT-FY20-122019-008410-A	2.6	FT-FY20-122019-008410-B	<1
WS-008416	5/28/2019	5/28/2020	2	Cooler	In hallway across from room 2204	High Left	WF-05282019-008416	1/4/2020	FT-FY20-122019-008416-A	<1	FT-FY20-122019-008416-B	<1
WS-008417	5/28/2019	5/28/2020	2	Cooler	In hallway across from room 2205	Low Right	WF-05282019-008417	1/4/2020	FT-FY20-122019-008417-A	<1	FT-FY20-122019-008417-B	<1
WS-008419	5/28/2019	5/28/2020	2	Cooler	In hallway across from room 2602	High Left	WF-05282019-008419	1/4/2020	FT-FY20-122019-008419-A	<1	FT-FY20-122019-008419-B	<1
WS-008420	5/28/2019	5/28/2020	2	Cooler	In hallway across from room 2602	Low Right	WF-05282019-008420	1/4/2020	FT-FY20-122019-008420-A	<1	FT-FY20-122019-008420-B	<1
WS-008465	5/28/2019	5/28/2020	3	Health Suite	In health suite 3202		WF-05282019-008465	1/4/2020	FT-FY20-122019-008465-A	<1	FT-FY20-122019-008465-B	<1

WS-008467	5/28/2019	5/28/2020	3	Cooler	In hallway adjacent to room 3204	High Left	WF-05282019-008467	1/4/2020	FT-FY20-122019-008467-A	<1	FT-FY20-122019-008467-B	<1
WS-008468	5/28/2019	5/28/2020	3	Cooler	In hallway adjacent to room 3204	Low Right	WF-05282019-008468	1/4/2020	FT-FY20-122019-008468-A	<1	FT-FY20-122019-008468-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004134	5/28/2019	5/28/2020	Basement	Food Prep Sink	On T level, in T02 concession stand (sink)	WF-05282019-004134	1/4/2020	FT-FY20-122019-004134-A	<1	FT-FY20-122019-004134-B	<1
WS-008335	7/12/2019	7/12/2020	Ground Floor	Food Prep Sink	On C level, in kitchen room C122 west wall	WF-07122019-008335	1/4/2020	FT-FY20-122019-008335-A	<1	FT-FY20-122019-008335-B	<1
WS-008336	7/12/2019	7/12/2020	Ground Floor	Food Prep Sink	On C level, in kitchen C122 middle	WF-07122019-008336	1/4/2020	FT-FY20-122019-008336-A	<1	FT-FY20-122019-008336-B	<1