



CARDOZO HS LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	CARDOZO HIGH SCHOOL	WS- 008410	12/11/2016	1	Classroom Faucet	In office room 1610 in room 1611	FT-122016-008410-A	< 1	FT-122016-008410-B	< 1
2	CARDOZO HIGH SCHOOL	WS- 004805	12/11/2016	2	Break Room	In staff workroom 2501	FT-112016-004805-A	< 1	FT-112016-004805-B	< 1
3	CARDOZO HIGH SCHOOL	WS- 004803	12/11/2016	1	Break Room	In office room 1130 in room 1119	FT-112016-004803-A	< 1	FT-112016-004803-B	< 1
4	CARDOZO HIGH SCHOOL	WS- 008369	12/11/2016	1	Break Room	In staff lounge 1304	FT-112016-008369-A	< 1	FT-112016-008369-B	< 1
5	CARDOZO HIGH SCHOOL	WS- 008408	12/11/2016	1	Break Room	In staff lounge 1611	FT-112016-008408-A	< 1	FT-112016-008408-B	< 1

Note :
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb