



Cardozo EC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004122	6/4/2018	6/4/2019	3	Cooler	In hallway across from 3502	High Left	WF-06042018-004122	12/17/2018	FT-FY19-122018-004122-A	<1	FT-FY19-122018-004122-B	<1
WS-004123	6/4/2018	6/4/2019	3	Cooler	In hallway across from 3502	Low Right	WF-06042018-004123	12/17/2018	FT-FY19-122018-004123-A	<1	FT-FY19-122018-004123-B	<1
WS-004128	6/4/2018	6/4/2019	Basement	Cooler	On LT level, in gym hallway across from girls' locker room LT55	High Left	WF-06042018-004128	12/17/2018	FT-FY19-122018-004128-A	<1	FT-FY19-122018-004128-B	<1
WS-004129	6/4/2018	6/4/2019	Basement	Cooler	On LT level, in gym hallway across from custodial closet LT58	High Left	WF-06042018-004129	12/17/2018	FT-FY19-122018-004129-A	<1	FT-FY19-122018-004129-B	<1
WS-004130	6/4/2018	6/4/2019	Basement	Cooler	On LT level, in gym hallway across from girls' locker room LT55	Low Right	WF-06042018-004130	12/17/2018	FT-FY19-122018-004130-A	<1	FT-FY19-122018-004130-B	<1
WS-004131	6/4/2018	6/4/2019	Basement	Cooler	On LT level, in gym hallway across from custodial closet LT58	Low Right	WF-06042018-004131	12/17/2018	FT-FY19-122018-004131-A	<1	FT-FY19-122018-004131-B	<1
WS-004132	6/4/2018	6/4/2019	Basement	Cooler	On T level, gym lobby adjacent to T04A	High Left	WF-06042018-004132	12/17/2018	FT-FY19-122018-004132-A	<1	FT-FY19-122018-004132-B	<1
WS-004133	6/4/2018	6/4/2019	Basement	Cooler	On T level, gym lobby adjacent to T04A	Low Right	WF-06042018-004133	12/17/2018	FT-FY19-122018-004133-A	<1	FT-FY19-122018-004133-B	<1
WS-004134	6/4/2018	6/4/2019	Basement	Other	On T level, in T02 concession stand (sink)		WF-06042018-004134	12/17/2018	FT-FY19-122018-004134-A	<1	FT-FY19-122018-004134-B	<1
WS-004136	6/4/2018	6/4/2019	Basement	Cooler	On LT level, in LT410 (pool)	High Left	WF-06042018-004136	12/17/2018	FT-FY19-122018-004136-A	<1	FT-FY19-122018-004136-B	<1
WS-004137	6/4/2018	6/4/2019	Basement	Cooler	On LT level, in LT410 (pool)	Low Right	WF-06042018-004137	12/17/2018	FT-FY19-122018-004137-A	<1	FT-FY19-122018-004137-B	<1
WS-004139	6/4/2018	6/4/2019	Basement	Cooler	In stadium locker room		WF-06042018-004139	12/17/2018	FT-FY19-122018-004139-A	<1	FT-FY19-122018-004139-B	<1
WS-004803	6/4/2018	6/4/2019	1	Break Room	In office room 1130 in room 1119		WF-06042018-004803	12/17/2018	FT-FY19-122018-004803-A	<1	FT-FY19-122018-004803-B	<1
WS-004805	6/4/2018	6/4/2019	2	Break Room	In staff workroom 2501		WF-06042018-004805	12/17/2018	FT-FY19-122018-004805-A	<1	FT-FY19-122018-004805-B	<1
WS-004807	6/4/2018	6/4/2019	Basement	Cooler	In stadium locker room east side		WF-06042018-004807	12/17/2018	FT-FY19-122018-004807-A	<1	FT-FY19-122018-004807-B	<1
WS-008321	6/4/2018	6/4/2019	Ground Floor	Health Suite	On C level, in health suite C137		WF-06042018-008321	12/17/2018	FT-FY19-122018-008321-A	<1	FT-FY19-122018-008321-B	<1
WS-008323	6/4/2018	6/4/2019	Ground Floor	Health Suite	On C level, in health suite C140		WF-06042018-008323	12/17/2018	FT-FY19-122018-008323-A	<1	FT-FY19-122018-008323-B	<1
WS-008324	6/4/2018	6/4/2019	Ground Floor	Health Suite	On C level, in health suite C144		WF-06042018-008324	12/17/2018	FT-FY19-122018-008324-A	<1	FT-FY19-122018-008324-B	<1
WS-008325	6/4/2018	6/4/2019	Ground Floor	Health Suite	On C level, in health suite C151		WF-06042018-008325	12/17/2018	FT-FY19-122018-008325-A	<1	FT-FY19-122018-008325-B	<1
WS-008326	6/4/2018	6/4/2019	Ground Floor	Health Suite	On C level, in health suite C146		WF-06042018-008326	12/17/2018	FT-FY19-122018-008326-A	<1	FT-FY19-122018-008326-B	<1
WS-008332	6/4/2018	6/4/2019	Ground Floor	Cooler	On C level, in hallway across from room C205	High Left	WF-06042018-008332	12/17/2018	FT-FY19-122018-008332-A	<1	FT-FY19-122018-008332-B	<1
WS-008333	6/4/2018	6/4/2019	Ground Floor	Cooler	On C level, in hallway across from room C205	Low Right	WF-06042018-008333	12/17/2018	FT-FY19-122018-008333-A	<1	FT-FY19-122018-008333-B	<1
WS-008337	6/4/2018	6/4/2019	Ground Floor	Ice Maker	On C level, in kitchen C122 in room C118 (ice maker)		WF-06042018-008337	12/17/2018	FT-FY19-122018-008337-A	<1	FT-FY19-122018-008337-B	<1
WS-008346	6/4/2018	6/4/2019	Basement	Cooler	On T level, in hallway across from room T203		WF-06042018-008346	12/17/2018	FT-FY19-122018-008346-A	<1	FT-FY19-122018-008346-B	<1
WS-008363	6/4/2018	6/4/2019	1	Cooler	In hallway across from 1203	High Left	WF-06042018-008363	12/17/2018	FT-FY19-122018-008363-A	<1	FT-FY19-122018-008363-B	<1
WS-008364	6/4/2018	6/4/2019	1	Cooler	In hallway across from 1203	Low Right	WF-06042018-008364	12/17/2018	FT-FY19-122018-008364-A	<1	FT-FY19-122018-008364-B	<1
WS-008369	6/4/2018	6/4/2019	1	Break Room	In staff lounge 1304		WF-06042018-008369	12/17/2018	FT-FY19-122018-008369-A	<1	FT-FY19-122018-008369-B	<1
WS-008395	6/4/2018	6/4/2019	1	Cooler	In hallway across from room 1603	High Left	WF-06042018-008395	12/17/2018	FT-FY19-122018-008395-A	<1	FT-FY19-122018-008395-B	<1
WS-008396	6/4/2018	6/4/2019	1	Cooler	In hallway across from room 1603	Low Right	WF-06042018-008396	12/17/2018	FT-FY19-122018-008396-A	<1	FT-FY19-122018-008396-B	<1
WS-008408	6/4/2018	6/4/2019	1	Break Room	In staff lounge 1611		WF-06042018-008408	12/17/2018	FT-FY19-122018-008408-A	<1	FT-FY19-122018-008408-B	<1
WS-008410	10/23/2018	10/23/2019	1	Classroom Faucet	In office room 1610 in room 1611		WF-10232018-008410	12/17/2018	FT-FY19-122018-008410-A	<1	FT-FY19-122018-008410-B	<1
WS-008416	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 2204	High Left	WF-06042018-008416	12/17/2018	FT-FY19-122018-008416-A	<1	FT-FY19-122018-008416-B	<1
WS-008417	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 2205	Low Right	WF-06042018-008417	12/17/2018	FT-FY19-122018-008417-A	<1	FT-FY19-122018-008417-B	<1
WS-008419	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 2602	High Left	WF-06042018-008419	12/17/2018	FT-FY19-122018-008419-A	<1	FT-FY19-122018-008419-B	<1
WS-008420	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 2602	Low Right	WF-06042018-008420	12/17/2018	FT-FY19-122018-008420-A	<1	FT-FY19-122018-008420-B	<1
WS-008465	6/4/2018	6/4/2019	3	Health Suite	In health suite 3202		WF-06042018-008465	12/17/2018	FT-FY19-122018-008465-A	<1	FT-FY19-122018-008465-B	<1
WS-008467	6/4/2018	6/4/2019	3	Cooler	In hallway adjacent to room 3204	High Left	WF-06042018-008467	12/17/2018	FT-FY19-122018-008467-A	<1	FT-FY19-122018-008467-B	<1
WS-008468	6/4/2018	6/4/2019	3	Cooler	In hallway adjacent to room 3204	Low Right	WF-06042018-008468	12/17/2018	FT-FY19-122018-008468-A	<1	FT-FY19-122018-008468-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008335	Ground Floor	Food Prep Sink	On C level, in kitchen room C122 west wall	12/17/2018	FT-FY19-122018-008335-A	<1	FT-FY19-122018-008335-B	<1