



CARDOZO LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008466	Health Suite	3	In room 3202 (ice maker)	WT-042916-8483- A	< 1	WT-042916-8483- B	< 1			
2	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008465	Health Suite	3	In room 3202	WT-042916-8482- A	< 1	WT-042916-8482- B	< 1			
3	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008464	Classroom	3	In classroom 3502 west wall fourth from the left	WT-042916-8481- A	37.5	WT-042916-8481- B	19.3	labeled "not for drinking"		
4	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008463	Classroom	3	In classroom 3502 west wall third from the left	WT-042916-8480- A	20.5	WT-042916-8480- B	< 1	labeled "not for drinking"		
5	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008462	Classroom	3	In classroom 3502 west wall second from left	WT-042916-8479- A	333	WT-042916-8479- B	4.1	labeled "not for drinking"		
6	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008461	Classroom	3	In classroom 3502 west wall first from left	WT-042916-8478- A	42.1	WT-042916-8478- B	2.9	labeled "not for drinking"		
7	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008460	Classroom	3	In classroom 3502 south middle Right	WT-042916-8477- A	178	WT-042916-8477- B	1.1	labeled "not for drinking"		
8	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008459	Classroom	3	In classroom 3502 south middle Left	WT-042916-8476- A	158	WT-042916-8476- B	2.7	labeled "not for drinking"		
9	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008458	Classroom	3	In classroom 3502 east wall third from left	WT-042916-8475- A	10.2	WT-042916-8475- B	< 1			
10	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008457	Classroom	3	In classroom 3502 east wall fourth from left	WT-042916-8474- A	71.2	WT-042916-8474- B	1	labeled "not for drinking"		
11	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008456	Classroom	3	In classroom 3502 east wall second from left	WT-042916-8473- A	326	WT-042916-8473- B	1	labeled "not for drinking"		
12	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008455	Classroom	3	In classroom 3502 east wall first from left	WT-042916-8472- A	155	WT-042916-8472- B	2.3	labeled "not for drinking"		
13	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008454	Other	3	In room 3503 Left	WT-042916-8471- A	< 1	WT-042916-8471- B	< 1			
14	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008453	Other	3	In room 3503 Right	WT-042916-8470- A	1.7	WT-042916-8470- B	< 1			
15	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008452	Classroom	3	In classroom 3504 east wall fourth from left	WT-042916-8469- A	8.8	WT-042916-8469- B	< 1			
16	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008451	Classroom	3	In classroom 3504 east wall third from left	WT-042916-8468- A	< 1	WT-042916-8468- B	< 1			
17	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008450	Classroom	3	In classroom 3504 east wall second from left	WT-042916-8467- A	63.1	WT-042916-8467- B	1.1	labeled "not for drinking"		
18	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008449	Classroom	3	In classroom 3504 east wall first from left	WT-042916-8466- A	< 1	WT-042916-8466- B	< 1			
19	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008448	Classroom	3	In classroom 3504 west wall fourth from left	WT-042916-8465- A	18.8	WT-042916-8465- B	1.6	labeled "not for drinking"		
20	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008447	Classroom	3	In classroom 3504 west wall third from left	WT-042916-8464- A	15.7	WT-042916-8464- B	< 1	labeled "not for drinking"		
21	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008446	Classroom	3	In classroom 3504 west wall second from left	WT-042916-8463- A	< 1	WT-042916-8463- B	< 1			
22	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008445	Classroom	3	In classroom 3504 west wall first from left	WT-042916-8462- A	43.3	WT-042916-8462- B	1.1	labeled "not for drinking"		
23	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008444	Classroom	3	In classroom 3504 south middle Right	WT-042916-8461- A	< 1	WT-042916-8461- B	< 1			
24	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008443	Classroom	3	In classroom 3504 south middle Left	WT-042916-8460- A	< 1	WT-042916-8460- B	< 1			
25	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008442	Classroom	2	In room 2103	WT-042916-8459- A	< 1	WT-042916-8459- B	< 1			
26	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008441	Other	2	In classroom 2602 in room 2603 south wall	WT-042916-8458- A	< 1	WT-042916-8458- B	< 1			
27	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008440	Classroom	2	In classroom 2604 west wall first from left	WT-042916-8457- A	11.2	WT-042916-8457- B	< 1			
28	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008439	Classroom	2	In classroom 2604 west wall from second left	WT-042916-8456- A	3.8	WT-042916-8456- B	4.3			
29	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008438	Classroom	2	In classroom 2604 west wall third from left side	WT-042916-8455- A	< 1	WT-042916-8455- B	1.8			
30	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008437	Classroom	2	In classroom 2604 west wall fourth from the left	WT-042916-8454- A	168	WT-042916-8454- B	2	labeled "not for drinking"		
31	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008436	Classroom	2	In classroom 2604 east wall first from left	WT-042916-8453- A	10.3	WT-042916-8453- B	4			
32	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008435	Classroom	2	In classroom 2604 east wall second from left	WT-042916-8452- A	28.8	WT-042916-8452- B	< 1	labeled "not for drinking"		
33	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008434	Classroom	2	In classroom 2604 east wall third from left	WT-042916-8451- A	25.7	WT-042916-8451- B	< 1	labeled "not for drinking"		
34	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008433	Classroom	2	In classroom 2604 east wall fourth from left	WT-042916-8450- A	206	WT-042916-8450- B	2.5	labeled "not for drinking"		
35	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008432	Classroom	2	In classroom 2604 middle south Left	WT-042916-8449- A	3	WT-042916-8449- B	< 1			



CARDOZO LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
36	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008431	Classroom	2	In classroom 2604 middle south Right	WT-042916-8448- A	< 1	WT-042916-8448- B	< 1			
37	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008430	Classroom	2	In classroom 2602 in room 2603 north wall	WT-042916-8447- A	5.8	WT-042916-8447- B	< 1			
38	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008429	Classroom	2	In classroom 2602 west wall 1st from left	WT-042916-8446- A	1.2	WT-042916-8446- B	< 1			
39	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008428	Classroom	2	In classroom 2602 west wall second from left	WT-042916-8445- A	28.3	WT-042916-8445- B	< 1	labeled "not for drinking"		
40	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008427	Classroom	2	In classroom 2602 west wall third from left	WT-042916-8444- A	25.5	WT-042916-8444- B	< 1	labeled "not for drinking"		
41	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008426	Classroom	2	In classroom 2602 west wall fourth from left	WT-042916-8443- A	60.7	WT-042916-8443- B	< 1	labeled "not for drinking"		
42	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008425	Cooler	2	In classroom 2602 east wall Left	WT-042916-8442- A	3.7	WT-042916-8442- B	< 1			
43	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008424	Cooler	2	In classroom 2602 east wall middle	WT-042916-8441- A	9.6	WT-042916-8441- B	< 1			
44	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008423	Classroom	2	In classroom 2602 east wall Right	WT-042916-8440- A	1.1	WT-042916-8440- B	< 1			
45	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008422	Classroom	2	In classroom 2602 south middle Right	WT-042916-8439- A	< 1	WT-042916-8439- B	< 1			
46	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008421	Classroom	2	In classroom 2602 south middle Left	WT-042916-8438- A	1	WT-042916-8438- B	< 1			
47	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008420	Cooler	2	In hallway across from 2602 Right Low	WT-042916-8437- A	< 1	WT-042916-8437- B	< 1			
48	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008419	Cooler	2	In hallway across from 2602 Left High	WT-042916-8436- A	< 1	WT-042916-8436- B	< 1			
49	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008418	Classroom	2	In classroom 2305	WT-042916-8435- A	< 1	WT-042916-8435- B	< 1			
50	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008417	Cooler	2	In hallway across from 2204 Right Low	WT-042916-8434- A	< 1	WT-042916-8434- B	< 1			
51	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008416	Cooler	2	In hallway across from 2204 Left High	WT-042916-8433- A	< 1	WT-042916-8433- B	< 1			
52	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008415	Classroom	2	In classroom 2204 (ice maker)	WT-042916-8432- A	< 1	WT-042916-8432- B	< 1			
53	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008414	Classroom	2	In classroom 2204 west wall Left	WT-042916-8431- A	1	WT-042916-8431- B	< 1			
54	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008413	Classroom	2	In classroom 2204 west wall Mid	WT-042916-8430- A	1.9	WT-042916-8430- B	< 1			
55	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008412	Classroom	2	In classroom 2204 west wall Right	WT-042916-8429- A	< 1	WT-042916-8429- B	< 1			
56	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008411	Classroom	2	In classroom 2204 in island counter	WT-042916-8428- A	1.3	WT-042916-8428- B	< 1			
57	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008410	Classroom	1	In room 1611 in room 1610	WT-042916-8427- A	3.7	WT-042916-8427- B	< 1			
58	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008409	Other	1	In classroom 1611 (ice maker)	WT-042916-8426- A	< 1	WT-042916-8426- B	< 1			
59	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008408	Classroom	1	In classroom 1611	WT-042916-8425- A	< 1	WT-042916-8425- B	< 1			
60	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008407	Classroom	1	In classroom 1603 west wall first from left	WT-042916-8424- A	< 1	WT-042916-8424- B	< 1			
61	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008406	Classroom	1	In classroom 1603 west wall second from left	WT-042916-8423- A	1.1	WT-042916-8423- B	< 1			
62	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008405	Classroom	1	In classroom 1603 west wall third from left	WT-042916-8422- A	< 1	WT-042916-8422- B	< 1			
63	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008404	Classroom	1	In classroom 1603 west wall fourth from left	WT-042916-8421- A	< 1	WT-042916-8421- B	< 1			
64	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008403	Classroom	1	In classroom 1603 east wall fourth from left	WT-042916-8420- A	6.4	WT-042916-8420- B	< 1			
65	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008402	Classroom	1	In classroom 1603 east wall third from left	WT-042916-8419- A	1.1	WT-042916-8419- B	< 1			
66	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008401	Classroom	1	In classroom 1603 east wall second from left	WT-042916-8418- A	< 1	WT-042916-8418- B	< 1			
67	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008400	Classroom	1	In classroom 1603 east wall first from left	WT-042916-8417- A	< 1	WT-042916-8417- B	< 1			
68	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008399	Classroom	1	In classroom 1603 middle Right	WT-042916-8416- A	9.8	WT-042916-8416- B	< 1			
69	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008398	Classroom	1	In room 1603 middle south Left	WT-042916-8415- A	19.2	WT-042916-8415- B	3.2	labeled "not for drinking"		
70	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008396	Cooler	1	In hallway across from room 1603 Right Low	WT-042916-8413- A	< 1	WT-042916-8413- B	< 1			
71	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008395	Cooler	1	In hallway across from room 1603 Left High	WT-042916-8412- A	< 1	WT-042916-8412- B	< 1			
72	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008394	Other	1	In storage room 1601 (ice maker)	WT-042916-8411- A	< 1	WT-042916-8411- B	1.4			
73	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008393	Classroom	1	In storage room 1601	WT-042916-8410- A	26	WT-042916-8410- B	1.3	labeled "not for drinking"		
74	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008392	Classroom	1	In classroom 1503 middle west Left	WT-042916-8409- A	12.5	WT-042916-8409- B	2.9			
75	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008391	Classroom	1	In classroom 1503 middle west Right	WT-042916-8408- A	8.1	WT-042916-8408- B	< 1			
76	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008390	Classroom	1	In classroom 1501 middle west Right	WT-042916-8407- A	< 1	WT-042916-8407- B	< 1			
77	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008389	Classroom	1	In classroom 1501 middle west Left	WT-042916-8406- A	< 1	WT-042916-8406- B	< 1			
78	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008388	Classroom	1	In classroom 1503 south wall fourth from left	WT-042916-8405- A	1	WT-042916-8405- B	< 1			
79	CARDOZO HIGH SCHOOL	5/7/2016	WS- 008386	Classroom	1	In classroom 1503 south wall third from left	WT-042916-8403- A	1	WT-042916-8403- B	< 1			



CARDOZO LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
80	CARDOZO HIGH SCHOOL	5/7/2016	WS-008385	Classroom	1	In classroom 1503 south wall second from left	WT-042916-8402- A	1.3	WT-042916-8402- B	1.2				
81	CARDOZO HIGH SCHOOL	5/7/2016	WS-008384	Classroom	1	In classroom 1503 south wall first from left	WT-042916-8401- A	2.3	WT-042916-8401- B	1.2				
82	CARDOZO HIGH SCHOOL	5/7/2016	WS-008383	Classroom	1	In classroom 1503 north wall fourth from left	WT-042916-8400- A	< 1	WT-042916-8400- B	< 1				
83	CARDOZO HIGH SCHOOL	5/7/2016	WS-008382	Classroom	1	In classroom 1503 north wall third from left	WT-042916-8399- A	1.4	WT-042916-8399- B	< 1				
84	CARDOZO HIGH SCHOOL	5/7/2016	WS-008381	Classroom	1	In classroom 1503 north wall second from left	WT-042916-8398- A	3.8	WT-042916-8398- B	< 1				
85	CARDOZO HIGH SCHOOL	5/7/2016	WS-008380	Classroom	1	In classroom 1503 north wall first from left	WT-042916-8397- A	< 1	WT-042916-8397- B	< 1				
86	CARDOZO HIGH SCHOOL	5/7/2016	WS-008379	Other	1	In room 1502	WT-042916-8396- A	1.1	WT-042916-8396- B	< 1				
87	CARDOZO HIGH SCHOOL	5/7/2016	WS-008378	Classroom	1	In classroom 1501 outside left west	Left	WT-042916-8395- A	< 1	WT-042916-8395- B	< 1			
88	CARDOZO HIGH SCHOOL	5/7/2016	WS-008377	Classroom	1	In classroom 1501 outside garden lab east	WT-042916-8394- A	< 1	WT-042916-8394- B	< 1				
89	CARDOZO HIGH SCHOOL	5/7/2016	WS-008376	Classroom	1	In classroom 1501 south wall	Right	WT-042916-8393- A	9.3	WT-042916-8393- B	< 1			
90	CARDOZO HIGH SCHOOL	5/7/2016	WS-008374	Classroom	1	In classroom 1501 south wall	Left	WT-042916-8391- A	5.7	WT-042916-8391- B	< 1			
91	CARDOZO HIGH SCHOOL	5/7/2016	WS-008373	Classroom	1	In classroom 1501 north wall	Right	WT-042916-8390- A	5.5	WT-042916-8390- B	< 1			
92	CARDOZO HIGH SCHOOL	5/7/2016	WS-008372	Classroom	1	In classroom 1501 north wall	Left	WT-042916-8389- A	< 1	WT-042916-8389- B	< 1			
93	CARDOZO HIGH SCHOOL	5/7/2016	WS-008371	Classroom	1	In classroom 1405	WT-042916-8388- A	3.7	WT-042916-8388- B	< 1				
94	CARDOZO HIGH SCHOOL	5/7/2016	WS-008370	Classroom	1	In classroom 1401	WT-042916-8387- A	< 1	WT-042916-8387- B	< 1				
95	CARDOZO HIGH SCHOOL	5/7/2016	WS-008369	Break Room	1	In staff room 1304	WT-042916-8386- A	< 1	WT-042916-8386- B	< 1				
96	CARDOZO HIGH SCHOOL	5/7/2016	WS-008368	Classroom	1	In classroom 1301 north wall first from left	WT-042916-8385- A	< 1	WT-042916-8385- B	< 1				
97	CARDOZO HIGH SCHOOL	5/7/2016	WS-008367	Classroom	1	In classroom 1301 north wall fourth from left	WT-042916-8384- A	< 1	WT-042916-8384- B	< 1				
98	CARDOZO HIGH SCHOOL	5/7/2016	WS-008366	Classroom	1	In classroom 1301 north wall third from left	WT-042916-8383- A	< 1	WT-042916-8383- B	< 1				
99	CARDOZO HIGH SCHOOL	5/7/2016	WS-008365	Classroom	1	In classroom 1301 north wall second from left	WT-042916-8382- A	< 1	WT-042916-8382- B	< 1				
100	CARDOZO HIGH SCHOOL	5/7/2016	WS-008364	Cooler	1	In hallway across from 1203	Right Low	WT-042916-8381- A	< 1	WT-042916-8381- B	< 1			
101	CARDOZO HIGH SCHOOL	5/7/2016	WS-008363	Cooler	1	In hallway across from 1203	Left High	WT-042916-8380- A	< 1	WT-042916-8380- B	< 1			
102	CARDOZO HIGH SCHOOL	5/7/2016	WS-008362	Classroom	Basement	In T level in classroom t102c (spray nozzle)	WT-042916-8379- A	8.2	WT-042916-8379- B	< 1				
103	CARDOZO HIGH SCHOOL	5/7/2016	WS-008361	Classroom	Basement	In T level in classroom T 102C	Right	WT-042916-8378- A	6.9	WT-042916-8378- B	< 1			
104	CARDOZO HIGH SCHOOL	5/7/2016	WS-008360	Classroom	Basement	In T level in classroom T102c	Left	WT-042916-8377- A	4.9	WT-042916-8377- B	< 1			
105	CARDOZO HIGH SCHOOL	5/7/2016	WS-008359	Classroom	Basement	In T level in classroom T108	WT-042916-8376- A	< 1	WT-042916-8376- B	< 1				
106	CARDOZO HIGH SCHOOL	5/7/2016	WS-008358	Classroom	Basement	In T level in classroom T 204	Right	WT-042916-8375- A	9.9	WT-042916-8375- B	2.3			
107	CARDOZO HIGH SCHOOL	5/7/2016	WS-008357	Classroom	Basement	In T level in classroom t204	Mid	WT-042916-8374- A	9.2	WT-042916-8374- B	4.3			
108	CARDOZO HIGH SCHOOL	5/7/2016	WS-008356	Classroom	Basement	In T level in classroom T204	Left	WT-042916-8373- A	22.5	WT-042916-8373- B	6.1	labeled "not for drinking"		
109	CARDOZO HIGH SCHOOL	5/7/2016	WS-008355	Classroom	Basement	In T level in classroom t204 (spray nozzle)	WT-042916-8372- A	12.1	WT-042916-8372- B	< 1				
110	CARDOZO HIGH SCHOOL	5/7/2016	WS-008354	Classroom	Basement	In T level in classroom t201	Left	WT-042916-8371- A	6.3	WT-042916-8371- B	2.6			
111	CARDOZO HIGH SCHOOL	5/7/2016	WS-008352	Classroom	Basement	In T level in classroom t201	Mid	WT-042916-8369- A	1.7	WT-042916-8369- B	< 1			
112	CARDOZO HIGH SCHOOL	5/7/2016	WS-008351	Classroom	Basement	In T level in classroom T 201	Right	WT-042916-8368- A	7.4	WT-042916-8368- B	3			
113	CARDOZO HIGH SCHOOL	5/7/2016	WS-008350	Classroom	Basement	In T level in classroom t209 (spray nozzle)	WT-042916-8367- A	< 1	WT-042916-8367- B	< 1				
114	CARDOZO HIGH SCHOOL	5/7/2016	WS-008349	Classroom	Basement	In T level in classroom t209	Right	WT-042916-8366- A	3.2	WT-042916-8366- B	< 1			
115	CARDOZO HIGH SCHOOL	5/7/2016	WS-008348	Classroom	Basement	In T level in classroom t209	Mid	WT-042916-8365- A	4.5	WT-042916-8365- B	< 1			
116	CARDOZO HIGH SCHOOL	5/7/2016	WS-008347	Classroom	Basement	In T level in classroom t 209	Left	WT-042916-8364- A	< 1	WT-042916-8364- B	< 1			
117	CARDOZO HIGH SCHOOL	5/7/2016	WS-008346	Cooler	1	In hallway across from 1203	WT-042916-8363- A	< 1	WT-042916-8363- B	< 1				
118	CARDOZO HIGH SCHOOL	5/7/2016	WS-008345	Classroom	Basement	In T level in classroom t301	Right	WT-042916-8362- A	26.6	WT-042916-8362- B	2.5	labeled "not for drinking"		
119	CARDOZO HIGH SCHOOL	5/7/2016	WS-008344	Classroom	Basement	In T level in classroom t301	Mid	WT-042916-8361- A	34.9	WT-042916-8361- B	< 1	labeled "not for drinking"		
120	CARDOZO HIGH SCHOOL	5/7/2016	WS-008343	Classroom	Basement	In T level in classroom 301	Left	WT-042916-8360- A	37.4	WT-042916-8360- B	1.3	labeled "not for drinking"		
121	CARDOZO HIGH SCHOOL	5/7/2016	WS-008342	Classroom	Ground Floor	In C level in c603 (ice maker)	WT-042916-8359- A	< 1	WT-042916-8359- B	< 1				
122	CARDOZO HIGH SCHOOL	5/7/2016	WS-008341	Classroom	Ground Floor	In C level in room C603	WT-042916-8358- A	< 1	WT-042916-8358- B	< 1				
123	CARDOZO HIGH SCHOOL	5/7/2016	WS-008340	Kitchen	Ground Floor	In C level c122 or c118 (spray nozzle)	WT-042916-8357- A	< 1	WT-042916-8357- B	< 1				



CARDOZO LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
124	CARDOZO HIGH SCHOOL	5/7/2016	WS-008339	Kitchen	Basement	C floor kitchen south wall second from left Right	WT-042916-8356-A	< 1	WT-042916-8356-B	< 1				
125	CARDOZO HIGH SCHOOL	5/7/2016	WS-008338	Kitchen	Ground Floor	C level in kitchen C 122 south wall Left	WT-042916-8355-A	< 1	WT-042916-8355-B	< 1				
126	CARDOZO HIGH SCHOOL	5/7/2016	WS-008337	Other	Ground Floor	In C level in c122 ice maker (c118 kitchen)	WT-042916-8354-A	< 1	WT-042916-8354-B	< 1				
127	CARDOZO HIGH SCHOOL	5/7/2016	WS-008336	Kitchen	Ground Floor	In C level in kitchen c122 middle	WT-042916-8353-A	< 1	WT-042916-8353-B	< 1				
128	CARDOZO HIGH SCHOOL	5/7/2016	WS-008335	Kitchen	Ground Floor	In C level in kitchen C 122 west wall	WT-042916-8352-A	< 1	WT-042916-8352-B	< 1				
129	CARDOZO HIGH SCHOOL	5/7/2016	WS-008334	Classroom	Ground Floor	In C level room 304	WT-042916-8351-A	< 1	WT-042916-8351-B	< 1				
130	CARDOZO HIGH SCHOOL	5/7/2016	WS-008333	Cooler	Ground Floor	In C level in hallway in cross from room C205 Low	WT-042916-8350-A	< 1	WT-042916-8350-B	< 1				
131	CARDOZO HIGH SCHOOL	5/7/2016	WS-008332	Cooler	Ground Floor	In C level in hallway in cross from room C205 Left High	WT-042916-8349-A	< 1	WT-042916-8349-B	< 1				
132	CARDOZO HIGH SCHOOL	5/7/2016	WS-008331	Other	Ground Floor	In C level in room C205 (ice maker)	WT-042916-8348-A	< 1	WT-042916-8348-B	< 1				
133	CARDOZO HIGH SCHOOL	5/7/2016	WS-008330	Classroom	Ground Floor	In C level in room C205	WT-042916-8347-A		WT-042916-8347-B					
134	CARDOZO HIGH SCHOOL	5/7/2016	WS-008329	Health Suite	Ground Floor	In C level in room 149	WT-042916-8346-A	2.3	WT-042916-8346-B	< 1				
135	CARDOZO HIGH SCHOOL	5/7/2016	WS-008328	Health Suite	Ground Floor	In C level in room C149	WT-042916-8345-A	< 1	WT-042916-8345-B	< 1				
136	CARDOZO HIGH SCHOOL	5/7/2016	WS-008327	Health Suite	Ground Floor	In C level in room C148	WT-042916-8344-A	< 1	WT-042916-8344-B	< 1				
137	CARDOZO HIGH SCHOOL	5/7/2016	WS-008326	Health Suite	Ground Floor	In C level in room C146	WT-042916-8343-A	< 1	WT-042916-8343-B	< 1				
138	CARDOZO HIGH SCHOOL	5/7/2016	WS-008325	Health Suite	Ground Floor	In C level in C151	WT-042916-8342-A	< 1	WT-042916-8342-B	< 1				
139	CARDOZO HIGH SCHOOL	5/7/2016	WS-008324	Health Suite	Ground Floor	In C level in room C144	WT-042916-8341-A	4.4	WT-042916-8341-B	< 1				
140	CARDOZO HIGH SCHOOL	5/7/2016	WS-008323	Health Suite	Ground Floor	C level in room C140	WT-042916-8340-A	< 1	WT-042916-8340-B	< 1				
141	CARDOZO HIGH SCHOOL	5/7/2016	WS-008322	Health Suite	Ground Floor	In C level in room C137 (ice maker)	WT-042916-8339-A	< 1	WT-042916-8339-B	< 1				
142	CARDOZO HIGH SCHOOL	5/7/2016	WS-008321	Health Suite	Ground Floor	In C level C 137	WT-042916-8338-A	< 1	WT-042916-8338-B	< 1				
143	CARDOZO HIGH SCHOOL	5/7/2016	WS-008320	Other	Ground Floor	Main water source in C floor in room C04 in C04B in C04C	WT-042916-8337-A	< 1	WT-042916-8337-B	1.2				
144	CARDOZO HIGH SCHOOL	5/7/2016	WS-004807	Fountain	Basement	In stadium locker room on east side	WT-042916-4824-A	2.3	WT-042916-4824-B	< 1				
145	CARDOZO HIGH SCHOOL	5/7/2016	WS-004806	Other	2	In staff workroom 2501 (ice maker)	WT-042916-4823-A	< 1	WT-042916-4823-B	< 1				
146	CARDOZO HIGH SCHOOL	5/7/2016	WS-004805	Break Room	2	In staff workroom 2501	WT-042916-4822-A	< 1	WT-042916-4822-B	< 1				
147	CARDOZO HIGH SCHOOL	5/7/2016	WS-004803	Break Room	1	In office 1130 (through door 119)	WT-042916-4820-A	< 1	WT-042916-4820-B	< 1				
148	CARDOZO HIGH SCHOOL	5/7/2016	WS-004802	Classroom	Ground Floor	In classroom C611	WT-042916-4819-A	< 1	WT-042916-4819-B	< 1				
149	CARDOZO HIGH SCHOOL	5/7/2016	WS-004140	Classroom	3	In classroom 3304	WT-042916-4157-A	< 1	WT-042916-4157-B	< 1				
150	CARDOZO HIGH SCHOOL	5/7/2016	WS-004139	Fountain	Basement	In Stadium locker room east side	WT-042916-4156-A	< 1	WT-042916-4156-B	< 1				
151	CARDOZO HIGH SCHOOL	5/7/2016	WS-004138	Other	Basement	In Stadium locker rooms (ice maker)	WT-042916-4155-A	9.2	WT-042916-4155-B	< 1				
152	CARDOZO HIGH SCHOOL	5/7/2016	WS-004137	Cooler	Basement	In LT level in LT410 (pool) Right Low	WT-042916-4154-A	< 1	WT-042916-4154-B	< 1				
153	CARDOZO HIGH SCHOOL	5/7/2016	WS-004136	Cooler	Basement	In LT level in LT410 (pool) Left High	WT-042916-4153-A	< 1	WT-042916-4153-B	< 1				
154	CARDOZO HIGH SCHOOL	5/7/2016	WS-004135	Classroom	Basement	In LT level room LT403	WT-042916-4152-A	1.7	WT-042916-4152-B	< 1				
155	CARDOZO HIGH SCHOOL	5/7/2016	WS-004134	Other	Basement	In T02 Concessions	WT-042916-4151-A	26	WT-042916-4151-B	2.1	Filtered	7/1/2016	<1	<1
156	CARDOZO HIGH SCHOOL	5/7/2016	WS-004133	Cooler	Basement	In T level gym lobby adjacent to T04a Right Low	WT-042916-4150-A	< 1	WT-042916-4150-B	< 1				
157	CARDOZO HIGH SCHOOL	5/7/2016	WS-004132	Cooler	Basement	In T level gym lobby adjacent to T04a Left High	WT-042916-4149-A	< 1	WT-042916-4149-B	< 1				
158	CARDOZO HIGH SCHOOL	5/7/2016	WS-004131	Cooler	Basement	In gymnasium hallway across from custodial closet LTS8 Low	WT-042916-4148-A	< 1	WT-042916-4148-B	< 1				
159	CARDOZO HIGH SCHOOL	5/7/2016	WS-004130	Cooler	Basement	In gymnasium hallway across from girls locker room LTS5 Low	WT-042916-4147-A	< 1	WT-042916-4147-B	< 1				
160	CARDOZO HIGH SCHOOL	5/7/2016	WS-004129	Cooler	Basement	In gymnasium hallway across from custodial closet LTS8 High	WT-042916-4146-A	< 1	WT-042916-4146-B	< 1				
161	CARDOZO HIGH SCHOOL	5/7/2016	WS-004128	Cooler	Basement	In gymnasium hallway across from girls locker room LTS5 High	WT-042916-4145-A	< 1	WT-042916-4145-B	< 1				
162	CARDOZO HIGH SCHOOL	5/7/2016	WS-004126	Classroom	Basement	In LT level LT31	WT-042916-4143-A	< 1	WT-042916-4143-B	< 1				
163	CARDOZO HIGH SCHOOL	5/7/2016	WS-004125	Other	Basement	In Gym LT 31 Training room	WT-042916-4142-A	< 1	WT-042916-4142-B	< 1				
164	CARDOZO HIGH SCHOOL	5/7/2016	WS-004124	Classroom	3	In classroom 3304 (ice maker)	WT-042916-4141-A	< 1	WT-042916-4141-B	< 1				
165	CARDOZO HIGH SCHOOL	5/7/2016	WS-004123	Cooler	3	In hallway across from 3502 Right Low	WT-042916-4140-A	< 1	WT-042916-4140-B	< 1				
166	CARDOZO HIGH SCHOOL	5/7/2016	WS-004122	Cooler	3	In hallway across from 3502 Left High	WT-042916-4139-A	< 1	WT-042916-4139-B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.