



# Chevy Chase CC Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010051	4/4/2020	4/4/2021	Basement	Cooler	In hallway adjacent to game room	WF-04042020-010051	3/18/2021	FT-FY21-032021-010051-A	<1	FT-FY21-032021-010051-B	<1
WS- 010052	4/4/2020	4/4/2021	Basement	Cooler	In hallway adjacent to exit/game room	WF-04042020-010052	3/18/2021	FT-FY21-032021-010052-A	<1	FT-FY21-032021-010052-B	<1
WS- 010053	4/4/2020	4/4/2021	1	Cooler	In hallway adjacent to room 116	WF-04042020-010053	3/18/2021	FT-FY21-032021-010053-A	<1	FT-FY21-032021-010053-B	<1
WS- 010054	4/4/2020	4/4/2021	1	Cooler	In hallway adjacent to room 114	WF-04042020-010054	3/18/2021	FT-FY21-032021-010054-A	<1	FT-FY21-032021-010054-B	<1
WS- 010059	4/4/2020	4/4/2021	1	Cooler	In classroom 105	WF-04042020-010059	3/18/2021	FT-FY21-032021-010059-A	1.3	FT-FY21-032021-010059-B	<1
WS- 010060	4/4/2020	4/4/2021	2	Cooler	In hallway adjacent to restroom	WF-04042020-010060	3/18/2021	FT-FY21-032021-010060-A	<1	FT-FY21-032021-010060-B	<1
WS- 010061	4/4/2020	4/4/2021	2	Cooler	In hallway adjacent to art room	WF-04042020-010061	3/18/2021	FT-FY21-032021-010061-A	<1	FT-FY21-032021-010061-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010055	2/23/2021	2/23/2022	1	Food Prep Sink	In kitchen	WF-02232021-010055	3/18/2021	FT-FY21-032021-010055-A	<1	FT-FY21-032021-010055-B	<1