



Chevy Chase Community Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010051	3/5/2024	3/5/2025	Basement	Cooler	In hallway adjacent to game room	WF-03052024-010051	3/26/2024	FT-FY24-03112024-010051-A	<1	FT-FY24-03112024-010051-B	<1
WS- 010052	3/5/2024	3/5/2025	Basement	Cooler	In hallway adjacent to exit/game room	WF-03052024-010052	3/26/2024	FT-FY24-03112024-010052-A	<1	FT-FY24-03112024-010052-B	<1
WS- 010053	3/5/2024	3/5/2025	1	Cooler	In hallway adjacent to room 116	WF-03052024-010053	3/26/2024	FT-FY24-03112024-010053-A	<1	FT-FY24-03112024-010053-B	<1
WS- 010054	3/5/2024	3/5/2025	1	Cooler	In hallway adjacent to room 114	WF-03052024-010054	3/26/2024	FT-FY24-03112024-010054-A	<1	FT-FY24-03112024-010054-B	<1
WS- 010055	12/13/2023	12/13/2024	1	Food Prep Sink	In kitchen	WF-12132023-010055	3/26/2024	FT-FY24-03112024-010055-A	<1	FT-FY24-03112024-010055-B	<1
WS- 010059	3/5/2024	3/5/2025	1	Cooler	In classroom 105	WF-03052024-010059	3/26/2024	FT-FY24-03112024-010059-A	1.4	FT-FY24-03112024-010059-B	<1
WS- 010060	3/5/2024	3/5/2025	2	Cooler	In hallway adjacent to restroom	WF-03052024-010060	3/26/2024	FT-FY24-03112024-010060-A	<1	FT-FY24-03112024-010060-B	<1
WS- 010061	3/5/2024	3/5/2025	2	Cooler	In hallway adjacent to art room	WF-03052024-010061	3/26/2024	FT-FY24-03112024-010061-A	<1	FT-FY24-03112024-010061-B	<1