



Chevy Chase Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012535	3/22/2022	3/22/2023	1	Cooler	In hallway adjacent to mechanical room High	WF-03222022-012535	2/6/2023	FT-FY23-01192023-012535-A	<1	FT-FY23-01192023-012535-B	<1
WS- 012536	3/22/2022	3/22/2023	1	Cooler	In hallway adjacent to mechanical room Low	WF-03222022-012536	2/6/2023	FT-FY23-01192023-012536-A	<1	FT-FY23-01192023-012536-B	<1
WS- 012537	12/21/2022	12/21/2023	1	Food Prep Sink	In kitchen	WF-12212022-012537	2/6/2023	FT-FY23-01192023-012537-A	<1	FT-FY23-01192023-012537-B	<1