



# Chevy Chase Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012535	3/5/2024	3/5/2025	1	Cooler	In hallway adjacent to mechanical room High	WF-03052024-012535	3/26/2024	FT-FY24-03112024-012535-A	<1	FT-FY24-03112024-012535-B	<1
WS- 012536	3/5/2024	3/5/2025	1	Cooler	In hallway adjacent to mechanical room Low	WF-03052024-012536	3/26/2024	FT-FY24-03112024-012536-A	<1	FT-FY24-03112024-012536-B	<1
WS- 012537	11/22/2023	11/22/2024	1	Food Prep Sink	In kitchen	WF-11222023-012537	3/26/2024	FT-FY24-03112024-012537-A	<1	FT-FY24-03112024-012537-B	<1